

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 2-15-07

Proposed Facility: SFD

Design Flow (.1949): 360

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring  Pit

Cut

Type of Wastewater:  Sewage  Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 3%	0-22	SL	FR GR NSWP					.4
		22-36	SCL	SILTY / SAND S.P		36		PR	
		36"+	PM						
2	L 3%	0-24	SL	FR GR NSWP					.4
		24-36	SCL	SILTY / SAND S.P		36		PR	
		36"+	PM						
3	L 3%	0-44	SL	FR GR NSWP					.4
		44-48	SCL	SILTY / SAND S.P		48		PR	
		48"+	PM						

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	COM 2570	COM 2570
Site LTAR	.4	.4

Other Factors (.1946): \_\_\_\_\_

Site Classification (.1948):

Evaluated By: 

Others Present: