

HTE# 07-5-16721R

Harnett County Department of Public Health 23469

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Keith Bullak, Inc. PROPERTY LOCATION: SR 1429 Chalybeate Rd
 NEW REPAIR EXPANSION SUBDIVISION: Dexter Field LOT # 32
 Type of Structure: SFD 60x55' Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: Plumbing should be stubbed out shallow if ditch depths
can not be maintained then a pump will be required No expiration

Authorized State Agent: Bryan McSwain, P.E. Date: 3/1/2007 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Keith Bullak, Inc. PROPERTY LOCATION: SR 1429
 Facility Type: SFD 60x55' New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable) LPP 2400 Ft² (Repair)

Installation Requirements/Conditions

* Septic Tank Size 1000 gallons Exact length of each trench 3x80 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6-18 inches
 if needed Maximum Trench Depth of: 30 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 Conditions: Top ditch should be no deeper than 30" the other 2 ditches _____ inches above pipe
should be less than 30" _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Bryan McSwain, P.E. Date: 3/1/2007 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 3/1/2012


HTE# 07-5-1621R

Permit # 23469

Harnett County Department of Public Health Site Sketch

ISSUED TO: Keith Bullock Inc. PROPERTY LOCATOR: Chalybeate Rd
SUBDIVISION: Dextarfield LOT # 32

Authorized State Agent: Bryan McSwain, P.S. Date: 2/1/2007



Brendamore Ct.