
ADDRESS . . : 320 REMINGTON HILL DR
CONTRACTOR : QUEST DEVELOPMENT
OWNER . . . : EVEN PAR DEVELOPMENT LLC
PARCEL . . . : 01-0525-01- -0095- -10-
APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 10 JB

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 237-1853
PHONE :

STRUCTURE: 000 000 65X65 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10 <u>4/30/10</u>	TI <u>AP DI</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642

----- COMMENTS AND NOTES -----

ADDRESS . . : 320 REMINGTON HILL DR
CONTRACTOR : QUEST DEVELOPMENT
OWNER . . . : EVEN PAR DEVELOPMENT LLC
PARCEL . . . : 01-0525-01- -0095- -10-
APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 237-1853
PHONE :

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 10 JB

STRUCTURE: 000 000 65X65 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642
	4/30/10	AP	
A814 01	5/04/10	TI	ADDRESS CONFIRMATION VRU #: 001919679
B103 01	<u>5/04/10</u>	<u>TI</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001919687

COMMENTS AND NOTES

ADDRESS . . : 320 REMINGTON HILL DR
CONTRACTOR : QUEST DEVELOPMENT
OWNER . . . : EVEN PAR DEVELOPMENT LLC
PARCEL . . . : 01-0525-01- -0095- -10-
APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 10 JB

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 237-1853
PHONE :

STRUCTURE: 000 000 65X65 3BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642
	4/30/10	AP	
B103 01	5/04/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001919687
	5/04/10	AP	
A814 01	5/04/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919679
	5/04/10	AP	320 REMINGTON HILL DR LOT 10 BUNNLEVEL 28323 T/S: 05/04/2010 09:26 AM TWARD
B105 01	5/06/10	TI	R*OPEN FLOOR VRU #: 001921488
	<i>5/6/10</i>	<i>AP DT</i>	VOICE MESSAGE LEFT

----- COMMENTS AND NOTES -----

ADDRESS . . : 320 REMINGTON HILL DR
CONTRACTOR : QUEST DEVELOPMENT
OWNER . . . : EVEN PAR DEVELOPMENT LLC
PARCEL . . . : 01-0525-01- -0095- -10-
APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 10 JB

STRUCTURE: 000 000 65X65 3BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642
	4/30/10	AP	
B103 01	5/04/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001919687
	5/04/10	AP	
A814 01	5/04/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919679
	5/04/10	AP	320 REMINGTON HILL DR LOT 10 BUNNLEVEL 28323 T/S: 05/04/2010 09:26 AM TWARD
B105 01	5/06/10	DT	R*OPEN FLOOR VRU #: 001921488
	5/06/10	AP	VOICE MESSAGE LEFT
R427 01	6/03/10	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001935840
	<u>6/3/10</u>	<u>DADT</u>	T/S: 06/02/2010 02:02 PM NTART

----- COMMENTS AND NOTES -----

ADDRESS . . : 320 REMINGTON HILL DR
CONTRACTOR : QUEST DEVELOPMENT
OWNER . . . : EVEN PAR DEVELOPMENT LLC
PARCEL . . . : 01-0525-01- -0095- -10-
APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 10 JB

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 237-1853
PHONE :

STRUCTURE: 000 000 65X65 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642
	4/30/10	AP	
B103 01	5/04/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001919687
	5/04/10	AP	
A814 01	5/04/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919679
	5/04/10	AP	320 REMINGTON HILL DR LOT 10 BUNNLEVEL 28323 T/S: 05/04/2010 09:26 AM TWARD
B105 01	5/06/10	DT	R*OPEN FLOOR VRU #: 001921488
	5/06/10	AP	VOICE MESSAGE LEFT
R427 01	6/03/10	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001935840
	6/03/10	DA	T/S: 06/02/2010 02:02 PM NTART 1. Data/cable lines not installed/caulked. 2. Attic access must be moved, trunk line blocking unit. Okay to side, do not insulate. T/S: 06/03/2010 12:42 PM DETAYLOR
R427 02	6/07/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001936640
	<u>6/7/10</u>	<u>APV</u>	

COMMENTS AND NOTES

 ADDRESS . . : 320 REMINGTON HILL DR
 CONTRACTOR : QUEST DEVELOPMENT
 OWNER . . . : EVEN PAR DEVELOPMENT LLC
 PARCEL . . . : 01-0525-01- -0095- -10-
 APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 10 JB

SUBDIV: GATEWEST 53 LOTS
 PHONE : (910) 237-1853
 PHONE :

STRUCTURE: 000 000 65X65 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642
	4/30/10	AP	
B103 01	5/04/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001919687
	5/04/10	AP	
A814 01	5/04/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919679
	5/04/10	AP	320 REMINGTON HILL DR LOT 10 BUNNLEVEL 28323 T/S: 05/04/2010 09:26 AM TWARD
B105 01	5/06/10	DT	R*OPEN FLOOR VRU #: 001921488
	5/06/10	AP	VOICE MESSAGE LEFT
R427 01	6/03/10	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001935840
	6/03/10	DA	T/S: 06/02/2010 02:02 PM NTART 1. Data/cable lines not installed/caulked. 2. Attic access must be moved, trunk line blocking unit. Okay to side, do not insulate.
R427 02	6/07/10	DT	T/S: 06/03/2010 12:42 PM DETAYLOR
	6/07/10	DA	FOUR TRADE ROUGH IN >2500 VRU #: 001936640 Trunk line still blocking access to unit. Must have 30x24 clear path to unit.
I129 01	6/09/10	TI	T/S: 06/07/2010 11:54 AM DETAYLOR
	6/9/10	AP DI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001938125
R427 03	6/09/10	TI	T/S: 06/08/2010 01:00 PM JBROCK
	6/9/10	AP DI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001938141 T/S: 06/08/2010 01:00 PM JBROCK

 COMMENTS AND NOTES

 ADDRESS . : 320 REMINGTON HILL DR SUBDIV: GATEWEST 53 LOTS
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853
 OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL . . : 01-0525-01- -0095- -10-
 APPL NUMBER: 07-50016736 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 10 JB

STRUCTURE: 000 000 65X65 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918642
	4/30/10	AP	
B103 01	5/04/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001919687
	5/04/10	AP	
A814 01	5/04/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919679
	5/04/10	AP	√ 320 REMINGTON HILL DR LOT 10 ----- BUNNLEVEL 28323 T/S: 05/04/2010 09:26 AM TWARD -----
B105 01	5/06/10	DT	R*OPEN FLOOR VRU #: 001921488
	5/06/10	AP	VOICE MESSAGE LEFT
R427 01	6/03/10	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001935840
	6/03/10	DA	T/S: 06/02/2010 02:02 PM NTART ----- 1. Data/cable lines not installed/caulked. 2. Attic access must be moved, trunk line blocking unit. Okay to side, do not insulate. T/S: 06/03/2010 12:42 PM DETAYLOR -----
R427 02	6/07/10	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001936640
	6/07/10	DA	Trunk line still blocking access to unit. Must have 30x24 clear path to unit. T/S: 06/07/2010 11:54 AM DETAYLOR-----
I129 01	6/09/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001938125
	6/09/10	AP	T/S: 06/08/2010 01:00 PM JBRUCK -----
R427 03	6/09/10	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001938141
	6/09/10	AP	T/S: 06/08/2010 01:00 PM JBRUCK -----
H824 01	8/03/10	OT	√ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001963388
	8/03/10	AP	T/S: 08/03/2010 09:15 AM SZIMMER ----- T/S: 08/03/2010 09:15 AM SZIMMER -----
R431 01	8/04/10	TI	FOUR TRADE FINAL >2500 VRU #: 001963651

8/4/10 AP DT

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Quest Development

Building: _____

Electrical: _____

Address: 320 Remington Hill Dr
Bunn level, NC 28323

Insulation: _____

Plumbing: _____

Mechanical: 07-50016736

MFG Home: _____

Date: 8/4/10

Building Official: [Signature]