

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: X Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

**Permit Numbers**

Name: Bill Clark Homes LLC

Building: 07-50016738

Address: 15 Mossburg Ct

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: \_\_\_\_\_

Date: 5-15-12

Building Official: T. Michael Ream

ADDRESS : 15 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER : BILL CLARK HOMES #12 PHONE : (910) 263-9026  
 PARCEL : 01-0525-01- -0095- -12-  
 APPL NUMBER: 07-50016738 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
 LOT 12 JB

STRUCTURE: 000 000 43.5X36 3BDR SLAB W/ GARAGE  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/13/12 1/13/12	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002180974 T/S: 01/12/2012 12:33 PM VBROWN ----- T/S: 01/12/2012 12:47 PM VBROWN ----- PAUL LEFT A MESSAGE ASKING FOR A AM INSP THAT THE CONCREATE TRUCK WILL COME AT NOON. T/S: 01/13/2012 01:04 PM MREARIC -----
B103 01	1/18/12 1/18/12	DT DA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002181917 T/S: 01/17/2012 11:46 AM VBROWN ----- Paul requested am insp Please, please. T/S: 01/18/2012 10:44 AM DETAYLOR ----- 1. Foundation wall highlighted on plan is not sitting on footer. Dig out, and get engineered repair and call for re-inspection. Do not pour until repair is inspected.
B103 02	1/24/12 1/24/12	DT AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002184711 T/S: 01/23/2012 12:50 PM VBROWN ----- T/S: 01/24/2012 10:23 AM DETAYLOR -----
A814 01	1/27/12 2/01/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002186146 T/S: 01/26/2012 12:59 PM DJOHNSON ----- 15 mossburg ct lot 12 bunnlevel 28323----- T/S: 02/01/2012 08:31 AM TWARD -----
P309 01	1/27/12 1/27/12	DT AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002186120 T/S: 01/26/2012 12:58 PM DJOHNSON ----- T/S: 01/27/2012 10:54 AM DETAYLOR -----
B111 01	1/31/12 1/31/12	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002186807 T/S: 01/30/2012 10:24 AM DJOHNSON ----- T/S: 01/31/2012 12:33 PM MREARIC -----
R427 01	3/02/12 3/02/12	JH DA	FOUR TRADE ROUGH IN >2500 VRU #: 002198874 1)Missing anchor bolts throughout house per code.2)Fire caulk wire @ top plate in hall @ the top of stairs. 3)3' head of water on drain line test.
R427 02	3/05/12 3/05/12	MR AP	FOUR TRADE ROUGH IN >2500 VRU #: 002199604 T/S: 03/05/2012 12:48 PM MREARIC -----
I129 01	3/07/12 3/07/12	DT AP	R*INSULATION INSPECTION VRU #: 002200790 T/S: 03/07/2012 10:16 AM DETAYLOR -----
H824 01	3/26/12 3/28/12	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002208676 T/S: 03/28/2012 11:49 AM SZIMMER ----- T/S: 03/28/2012 11:49 AM SZIMMER -----

-----  
ADDRESS . : 15 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . : BILL CLARK HOMES #12 PHONE : (910) 263-9026  
PARCEL . . : 01-0525-01- -0095- -12-  
APPL NUMBER: 07-50016738 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R431 01	3/28/12 3/27/12	DJ CA	FOUR TRADE FINAL >2500 VRU #: 002207962 T/S: 03/27/2012 03:25 PM DJOHNSON ----- NO OPERATIONS PERMIT ISSUED
R431 02	5/09/12 5/09/12	DT DA	FOUR TRADE FINAL >2500 VRU #: 002224872 T/S: 05/09/2012 11:14 AM DETAYLOR ----- House locked
R431 03	5/10/12 5/10/12	MR DP	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002225522 T/S: 05/10/2012 01:10 PM MREARIC ----- outlets needed at counter space in pantry area
R431 04	5/14/12 5/14/12	MR DP	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002226512 T/S: 05/11/2012 02:41 PM VBROWN ----- T/S: 05/14/2012 11:25 AM MREARIC ----- house locked
R431 05	5/15/12 <u>5-15-12</u>	TI <u>AP-MR</u>	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002226868

----- COMMENTS AND NOTES -----