

ADDRESS : 35 MOSSBURG CT
CONTRACTOR : QUEST DEVELOPMENT
OWNER : STEADMAN GIL & REBECCA #13
PARCEL : 01-0525-01- -0095- -13-
APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 13 JB
LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 237-1853
PHONE : (919) 395-1815

STRUCTURE: 000 000 65X55 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10 <u>3-31-10</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501 T/S: 03/30/2010 10:47 AM RDCONTE

COMMENTS AND NOTES

ADDRESS : 35 MOSSBURG CT
CONTRACTOR : QUEST DEVELOPMENT
OWNER : STEADMAN GIL & REBECCA #13
PARCEL : 01-0525-01- -0095- -13-
APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
LOT 13 JB

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 237-1853
PHONE : (919) 395-1815

LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

STRUCTURE: 000 000 65X55 3BDR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10 3/31/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501 T/S: 03/30/2010 10:47 AM RDCONTE ----- T/S: 03/31/2010 01:20 PM MREARIC -----
A814 01	4/05/10	TI	ADDRESS CONFIRMATION VRU #: 001903749
B103 01	<u>4/05/10</u> <u>4-5-10</u>	<u>TI</u> <u>AAB</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903756

----- COMMENTS AND NOTES -----

ADDRESS : 35 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853
 OWNER : STEADMAN GIL & REBECCA #13 PHONE : (919) 395-1815
 PARCEL : 01-0525-01- -0095- -13-
 APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 13 JB

LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

STRUCTURE: 000 000 65X55 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10 3/31/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501 T/S: 03/30/2010 10:47 AM RDCONTE ----- T/S: 03/31/2010 01:20 PM MREARIC -----
B103 01	4/05/10 4/05/10	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903756 T/S: April 05, 2010 12:13 PM BSUTTON -----
A814 01	4/05/10 4/06/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001903749 35 mossburg ct lot 13 ----- bunnlevel 28323 T/S: 04/06/2010 01:18 PM TWARD -----
B105 01	4/14/10 <u>4/14/10</u>	TI <u>AP IX</u>	R*OPEN FLOOR VRU #: 001909288

COMMENTS AND NOTES

ADDRESS : 35 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853
 OWNER : STEADMAN GIL & REBECCA #13 PHONE : (919) 395-1815
 PARCEL : 01-0525-01- -0095- -13-
 APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 13 JB

LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

STRUCTURE: 000 000 65X55 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10 3/31/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501 T/S: 03/30/2010 10:47 AM RDCONTE ----- T/S: 03/31/2010 01:20 PM MREARIC -----
B103 01	4/05/10 4/05/10	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903756 T/S: April 05, 2010 12:13 PM BSUTTON -----
A814 01	4/05/10 4/06/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001903749 35 mossburg ct lot 13 ----- bunnlevel 28323 T/S: 04/06/2010 01:18 PM TWARD -----
B105 01	4/14/10 4/14/10	DT AP	R*OPEN FLOOR VRU #: 001909288
R427 01	5/05/10 <u>5-5</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001919874

COMMENTS AND NOTES

ADDRESS : 35 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853
 OWNER : STEADMAN GIL & REBECCA #13 PHONE : (919) 395-1815
 PARCEL : 01-0525-01- -0095- -13-
 APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 13 JB

LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

STRUCTURE: 000 000 65X55 3BDR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501
	3/31/10	AP	T/S: 03/30/2010 10:47 AM RDCONTE ----- T/S: 03/31/2010 01:20 PM MREARIC -----
B103 01	4/05/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903756
	4/05/10	AP	T/S: April 05, 2010 12:13 PM BSUTTON -----
A814 01	4/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001903749
	4/06/10	AP	35 mossburg ct lot 13 ----- bunlevel 28323 T/S: 04/06/2010 01:18 PM TWARD -----
B105 01	4/14/10	DT	R*OPEN FLOOR VRU #: 001909288
	4/14/10	AP	
R427 01	5/05/10	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001919874
	5/05/10	DA	1. Insulation baffles not installed. Next house no inspection. 2. Install blocking beneath knee wall in garageto prevent air infiltration. See N1102.4.1 attached. OK to side, and insulate T/S: 05/05/2010 11:18 AM KSLATTUM ----- T/S: 05/05/2010 11:20 AM KSLATTUM
I129 01	5/07/10	TI	R*INSULATION INSPECTION VRU #: 001922533
	<u>5/7/10</u>	<u>AP DT</u>	
R427 02	5/07/10	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001922582
	<u>5/7/10</u>	<u>AP DT</u>	T/S: 05/06/2010 02:02 PM NTART -----

COMMENTS AND NOTES

ADDRESS : 35 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853
 OWNER : STEADMAN GIL & REBECCA #13 PHONE : (919) 395-1815
 PARCEL : 01-0525-01- -0095- -13-
 APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 13 JB
 LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

STRUCTURE: 000 000 65X55 3BDR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501
	3/31/10	AP	T/S: 03/30/2010 10:47 AM RDCONTE ----- T/S: 03/31/2010 01:20 PM MREARIC -----
B103 01	4/05/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903756
	4/05/10	AP	T/S: April 05, 2010 12:13 PM BSUTTON -----
A814 01	4/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001903749
	4/06/10	AP	✓ 35 mossburg ct lot 13 ----- bunnlevel 28323 T/S: 04/06/2010 01:18 PM TWARD -----
B105 01	4/14/10	DT	R*OPEN FLOOR VRU #: 001909288
	4/14/10	AP	
R427 01	5/05/10	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001919874
	5/05/10	DA	1. Insulation baffles not installed. Next house no inspection. 2. Install blocking beneath knee wall in garageto prevent air infiltration. See N1102.4.1 attached. OK to side, and insulate T/S: 05/05/2010 11:18 AM KSLATTUM ----- T/S: 05/05/2010 11:20 AM KSLATTUM -----
I129 01	5/07/10	DT	R*INSULATION INSPECTION VRU #: 001922533
	5/07/10	AP	
R427 02	5/07/10	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001922582
	5/07/10	AP	T/S: 05/06/2010 02:02 PM NTART -----
H824 01	6/11/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001940568
	6/11/10	AP	T/S: 06/14/2010 09:48 AM SZIMMER ----- T/S: 06/14/2010 09:50 AM SZIMMER -----
R431 01	7/01/10	TI	FOUR TRADE FINAL >2500 VRU #: 001948566

7/1/10 DA DT

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 7/02/10

ADDRESS : 35 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853
 OWNER : STEADMAN GIL & REBECCA #13 PHONE : (919) 395-1815
 PARCEL : 01-0525-01- -0095- -13-
 APPL NUMBER: 07-50016739 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT
 LOT 13 JB
 LAND NOTES : LXMN 11/03/06 SEWER EASEMENT

STRUCTURE: 000 000 65X55 3BDR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001902501
	3/31/10	AP	T/S: 03/30/2010 10:47 AM RDCONTE ----- T/S: 03/31/2010 01:20 PM MREARIC -----
B103 01	4/05/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903756
	4/05/10	AP	T/S: April 05, 2010 12:13 PM BSUTTON -----
A814 01	4/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001903749
	4/06/10	AP	✓ 35 mossburg ct lot 13 ----- bunnlevel 28323 T/S: 04/06/2010 01:18 PM TWARD -----
B105 01	4/14/10	DT	R*OPEN FLOOR VRU #: 001909288
	4/14/10	AP	
R427 01	5/05/10	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001919874
	5/05/10	DA	1. Insulation baffles not installed. Next house no inspection. 2. Install blocking beneath knee wall in garageto prevent air infiltration. See N1102.4.1 attached. OK to side, and insulate T/S: 05/05/2010 11:18 AM KSLATTUM ----- T/S: 05/05/2010 11:20 AM KSLATTUM -----
I129 01	5/07/10	DT	R*INSULATION INSPECTION VRU #: 001922533
	5/07/10	AP	
R427 02	5/07/10	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001922582
	5/07/10	AP	T/S: 05/06/2010 02:02 PM NTART -----
H824 01	6/11/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001940568
	6/11/10	AP	T/S: 06/14/2010 09:48 AM SZIMMER ----- T/S: 06/14/2010 09:50 AM SZIMMER -----
R431 01	7/01/10	DT	FOUR TRADE FINAL >2500 VRU #: 001948566
	7/01/10	DA	Need access door for master tub Attic platform must extend all the way to access. T/S: 07/01/2010 11:00 AM DETAYLOR -----
R431 02	7/02/10	TI	FOUR TRADE FINAL >2500 VRU #: 001949057

7/2/10 AR DC

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Quest Development

Building: _____

Electrical: _____

Address: 35 Mossburg Ct

Insulation: _____

Bunnlevel, NC 28323

Plumbing: _____

Mechanical: DT-50016739

Date: 7/2/10

Building Official: D-E T-R