

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 Bedroom House Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

Profile #	.1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2.5	0-19	SL gr	vfr NSMP					PS .4
		19-47	SCL sbk	fr SSSP	2.547/1 @ 47"				
2		0-17	SL gr	vfr NSMP					US
		17-21		maxine @ 20"					
3		0-29	SL gr	vfr NSMP					PS .4
		29-40	SCL sbk	fr SSSP					
4		0-15	SL gr	vfr NSMP					PS .4
		15-32	SCL sbk	fr SSSP	2.57/1 @ 29"				
5		0-24"	G SL	FR NS/MP					PS .5
		24-30"	SB+ SCL	FR SS/MP					
6		0-12"	G SL	VFR NS/MP					PS .4
		12-24"	SB+ SCL	FR SS/SP	2.57 7/1 @ 24"				
7		0-10"	G SL	VFR NS/MP					US
		10-18"	SB+ SCL	FR SS/SP	2.547/1 @ 18"				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	35" x 260	35" x 260
Site LTAR	.5	.4

Other Factors (.1946): _____

Site Classification (.1948): P3

Evaluated By: [Signature]

Others Present: