

ADDRESS : 116 MOSSBURG CT  
CONTRACTOR : QUEST DEVELOPMENT  
OWNER : EVEN PAR DEVELOPMENT LLC #21  
PARCEL : 01-0525-01- -0095- -21-  
APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
LOT 21 JB

SUBDIV: GATEWEST 53 LOTS  
PHONE : (910) 237-1853  
PHONE :

LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT

STRUCTURE: 000 000 60X60 3BDR

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 <u>6-29</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 <u>NO T-POLE</u>

COMMENTS AND NOTES

-----  
ADDRESS . . : 116 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853  
OWNER . . : EVEN PAR DEVELOPMENT LLC #21 PHONE :  
PARCEL . . : 01-0525-01- -0095- -21-  
APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
LOT 21 JB  
LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT  
-----

**STRUCTURE: 000 000 60X60 3BDR**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : UNKNOWN  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 6/29/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 No t-pole up at footing inspection T/S: 06/29/2009 01:48 PM KSLATTUM -----
A814 01	7/08/09	TI	ADDRESS CONFIRMATION VRU #: 001791383
B103 01	7/08/09 <u>7/10/09</u>	TI <u>AP TI</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791391

----- COMMENTS AND NOTES -----

-----

ADDRESS . . : 116 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853  
 OWNER . . : EVEN PAR DEVELOPMENT LLC #21 PHONE :  
 PARCEL . . : 01-0525-01- -0095- -21-  
 APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
 LOT 21 JB  
 LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT

-----

**STRUCTURE: 000 000 60X60 3BDR**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : UNKNOWN

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 6/29/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 No t-pole up at footing inspection T/S: 06/29/2009 01:48 PM KSLATTUM -----
B103 01	7/08/09 7/08/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791391
A814 01	7/08/09 7/13/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791383 116 mossburg ct lot 21 ----- bunnlevel 28323 T/S: 07/13/2009 01:06 PM TWARD -----
B105 01	7/15/09 <u>7-15</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001794455

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 116 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853  
OWNER : EVEN PAR DEVELOPMENT LLC #21 PHONE :  
PARCEL : 01-0525-01- -0095- -21-  
APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
LOT 21 JB  
LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT  
-----

STRUCTURE: 000 000 60X60 3BDR  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 6/29/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 No t-pole up at footing inspection T/S: 06/29/2009 01:48 PM KSLATTUM -----
B103 01	7/08/09 7/08/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791391
A814 01	7/08/09 7/13/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791383 116 mossburg ct lot 21 ----- bunnlevel 28323 T/S: 07/13/2009 01:06 PM TWARD -----
B105 01	7/15/09 7/15/09	KS AP	R*OPEN FLOOR VRU #: 001794455
R427 01	8/18/09 <u>8/18/09</u>	TI <u>DA DT</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001810213

----- COMMENTS AND NOTES -----

ADDRESS : 116 MOSSBURG CT  
CONTRACTOR : QUEST DEVELOPMENT  
OWNER : EVEN PAR DEVELOPMENT LLC #21  
PARCEL : 01-0525-01- -0095- -21-  
APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)

SUBDIV: GATEWEST 53 LOTS  
PHONE : (910) 237-1853  
PHONE :

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
LOT 21 JB

LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT

STRUCTURE: 000 000 60X60 3BDR

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 6/29/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 No t-pole up at footing inspection T/S: 06/29/2009 01:48 PM KSLATTUM -----
B103 01	7/08/09 7/08/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791391
A814 01	7/08/09 7/13/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791383 116 mossburg ct lot 21 ----- bunlevel 28323 T/S: 07/13/2009 01:06 PM TWARD -----
B105 01	7/15/09 7/15/09	KS AP	R*OPEN FLOOR VRU #: 001794455
R427 01	8/18/09 8/18/09	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001810213 1. A, B, and C trusses missing braces. 2. A and C trusses missing uplift straps. Okay to side and insulate. T/S: 08/18/2009 02:02 PM DETAYLOR -----
I129 01	8/21/09 <u>8-21-09</u>	TI <u>DPBS</u>	R*INSULATION INSPECTION VRU #: 001811917
R427 02	8/21/09	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001811991 T/S: 08/20/2009 02:31 PM NTART -----

COMMENTS AND NOTES

ADDRESS : 116 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853  
 OWNER : EVEN PAR DEVELOPMENT LLC #21 PHONE :  
 PARCEL : 01-0525-01- -0095- -21-  
 APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
 LOT 21 JB  
 LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT

**STRUCTURE: 000 000 60X60 3BDR**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 6/29/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 No t-pole up at footing inspection T/S: 06/29/2009 01:48 PM KSLATTUM -----
B103 01	7/08/09 7/08/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791391
A814 01	7/08/09 7/13/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791383 116 mossburg ct lot 21 ----- bunnlevel 28323 T/S: 07/13/2009 01:06 PM TWARD -----
B105 01	7/15/09 7/15/09	KS AP	R*OPEN FLOOR VRU #: 001794455
R427 01	8/18/09 8/18/09	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001810213 1. A, B, and C trusses missing braces. 2. A and C trusses missing uplift straps. Okay to side and insulate. T/S: 08/18/2009 02:02 PM DETAYLOR -----
I129 01	8/21/09 8/21/09	BS DP	R*INSULATION INSPECTION VRU #: 001811917 insulation incomplete \$50 referee -----
R427 02	8/21/09 8/21/09	BS DA	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001811991 T/S: 08/20/2009 02:31 PM NTART ----- T/S: 08/21/2009 01:01 PM DJOHNSON ----- T/S: 08/21/2009 01:02 PM DJOHNSON -----
I129 02	8/24/09 <i>8-24-09</i>	TI <i>AP JH</i>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001812346 T/S: 08/21/2009 01:13 PM DJOHNSON -----
R427 03	8/24/09 <i>8-24-09</i>	TI <i>AP JH</i>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001812353 T/S: 08/21/2009 01:13 PM DJOHNSON -----

COMMENTS AND NOTES

ADDRESS . . : 116 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853  
 OWNER . . : EVEN PAR DEVELOPMENT LLC #21 PHONE :  
 PARCEL . . : 01-0525-01- -0095- -21-  
 APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN  
 RIGHT ON LEMUEL BLACK RD S/D ON RIGHT  
 LOT 21 JB

LAND NOTES : LXMN 11/03/06 2 SEWER EASEMENTS 1 DRAINAGE EASEMENT

**STRUCTURE: 000 000 60X60 3BDR**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . : UNKNOWN

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/29/09 6/29/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001787454 No t-pole up at footing inspection T/S: 06/29/2009 01:48 PM KSLATTUM -----
B103 01	7/08/09 7/08/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791391
A814 01	7/08/09 7/13/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791383 ✓ 116 mossburg ct lot 21 ----- bunlevel 28323 T/S: 07/13/2009 01:06 PM TWARD -----
B105 01	7/15/09 7/15/09	KS AP	R*OPEN FLOOR VRU #: 001794455
R427 01	8/18/09 8/18/09	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001810213 1. A, B, and C trusses missing braces. 2. A and C trusses missing uplift straps. Okay to side and insulate. T/S: 08/18/2009 02:02 PM DETAYLOR -----
I129 01	8/21/09 8/21/09	BS DP	R*INSULATION INSPECTION VRU #: 001811917 insulation incomplete \$50 refee -----
R427 02	8/21/09 8/21/09	BS DA	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001811991 T/S: 08/20/2009 02:31 PM NTART ----- T/S: 08/21/2009 01:01 PM DJOHNSON ----- T/S: 08/21/2009 01:02 PM DJOHNSON -----
I129 02	8/24/09 8/24/09	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001812346 T/S: 08/21/2009 01:13 PM DJOHNSON ----- T/S: 08/24/2009 01:14 PM JHALL -----
R427 03	8/24/09 8/24/09	JH AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001812353 T/S: 08/21/2009 01:13 PM DJOHNSON ----- T/S: 08/24/2009 01:14 PM JHALL -----
H824 01	9/24/09 9/24/09	OT DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001826999 PER OLIVER TOLKSDORF ON HOLD FOR PUMP AND ALARM INSPECTION - CALL HIM TO SCHEDULE. T/S: 09/24/2009 09:29 AM SSTEWART ----- T/S: 09/24/2009 09:32 AM SSTEWART -----
H824 02	10/15/09 10/15/09	BM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001837913 T/S: 10/16/2009 10:40 AM SSTEWART -----

-----  
ADDRESS . : 116 MOSSBURG CT SUBDIV: GATEWEST 53 LOTS  
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 237-1853  
OWNER . . : EVEN PAR DEVELOPMENT LLC #21 PHONE :  
PARCEL . . : 01-0525-01- -0095- -21-  
APPL NUMBER: 07-50016746 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R431 01	12/10/09 <u>12/10/09</u>	TI <u>AR X</u>	T/S: 10/16/2009 10:40 AM S STEWART FOUR TRADE FINAL >2500 VRU #: 001859885

----- COMMENTS AND NOTES -----



**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Quest Development

911 Address: 116 Mossburg Ct.  
Bunnlevel

State: NC Zip Code: 28323

Date: 12/10/09

[Signature]  
Building Official

PERMIT NUMBERS

Building Permit No.: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

Insulation Permit No.: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

MFG. Home: \_\_\_\_\_

07-52016746