

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public     Individual     Well     Spring     Other

Evaluation Method:

Auger Boring     Pit

Type of Wastewater:

Sewage     Industrial Process     Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS	0-33'	G LS	VFL NS/VP					PS .4
		33-43'	SBL SL	R2 SS/S					
2	LS	0-17"	G LS	VFL NS/VP					PS .35
		17-43"	SBL SL	R2 S/P	10712 8/1 @ 24"				
3	LS	5-10"	G LS	VFL NS/VP					R3 .35
		10-27"	SBL SCL	R2 SS/S					
		27-44"	SBL SCL	R2 S/P	10712 8/1 @ 27"				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	SEE PROPOSAL	
Site LTAR		

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: \_\_\_\_\_  
 Others Present: \_\_\_\_\_