

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Address: \_\_\_\_\_ Date Evaluated: \_\_\_\_\_  
 Proposed Facility: \_\_\_\_\_ Design Flow (.1949): \_\_\_\_\_ Property Size: \_\_\_\_\_  
 Location of Site: \_\_\_\_\_ Property Recorded: \_\_\_\_\_  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr. Horiz	
1	LS 5-7%	0-12	G SL	VFR NS/NP					PS .3
		12-28 <sup>1/2</sup>	SBK S22	F S/P	10YR 8/1 @ 22"				
2	LS 0-2%	0-16"	G SL						PS .3
		16-18"	SBK S22	F S/P	10YR 8/1 @ 24"				
3		0-16	G LS	VFR NS/NP					US/PS dep
		16-31	SBK S22	FR S/P	10YR 8/1 @ 23"				
4		0-6"	G LS	VFR NS/NP					PS .6
		6-32"	SBK S22	FR S3/S					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	SEE PROPOSAL	
Site LTAR		

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): \_\_\_\_\_  
 Evaluated By: \_\_\_\_\_  
 Others Present: \_\_\_\_\_