

Sheet:  
 Property ID:  
 Lot #:  
 File #:  
 Code:

### SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 Bedroom House Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring  Pit

Cut

Type of Wastewater:  Sewage  Industrial Process

Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class. & LTAR
			1941 Structure/Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr. Horiz	
1	LS 0-2%	0-8"	SBK SL	VER SS/NP					PS .3
		8-36"	SBK SCL	FR S/SP					
2		0-10"	SBK SL	VFRLSS/NP					PS .3
		10-36"	SBK SCL	FR S/SP					
3		0-24"	SBK SL	VFRL NS/NP					PS .35
		24-36"	SBK SCL	FR SS/SP					

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25%	25%
Site LTAR	.3	.3

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: OT  
 Others Present: