



July 23, 2007

Harnett County Government Complex  
307 Cornelius Harnett Boulevard  
Lillington, NC 27546

Hampton Custom Builders, Inc.  
P O Box 655  
Holly Springs, NC 27540

ph: 910-893-7550  
fax: 910-893-9429

**RE: Harnett County Land Use Application HTE #07-5-16784R Magnolia Crest Lt 5**

To Whom It May Concern:

Several attempts have been made to evaluate your property for the purpose of issuing an Operation Permit. The evaluation could not be completed for one or more of the following reasons:

- 1. Property lines/corners not marked or labeled
- 2. House corners not marked or labeled
- 3. Directions not clear to property
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required
- 6. Other ***It is required that you show proof that the water line is 10' from the septic tank and/or lines. Until you give proof of this, I cannot issue an Operation Permit.***

Your application will be put on hold until the selected items above have been addressed. When completed please call 910-893-7547 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

James E. Manhart, R.S.  
Environmental Health Specialist  
Harnett County Department of Public Health  
Environmental Health

JEM/sgw

Copy: Central Permitting