

HTE# 07-50016801

Har... County Department of Public Health

23667

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Lonnie Jones
PROPERTY LOCATION: Old 421
SUBDIVISION: Shaylah's Knoll LOT # 18
Type of Structure: SFD - 51x60 - 3BR
Proposed Wastewater System Type: 25% Reduction system
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement: No
Pump Required: No
Type of Water Supply: Public
Permit conditions: Meet onsite - maintain All s/d Docks
S&B out Plumbing shallow - at ground level or higher

Authorized State Agent: J. W. [Signature] Date: 02-22-07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Lonnie Jones
PROPERTY LOCATION: Old 421
SUBDIVISION: Shaylah's Knoll LOT # 18
Facility Type: SFD-51x60-3BR New
Basement? No
Type of Wastewater System: 25% Reduction system (Initial)
Wastewater Flow: 360 GPD
(See note below, if applicable) 360 LF of LPP Repair (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons
Pump Tank Size
Exact length of each trench 4x60 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
Maximum Trench Depth of: 18 max inches
(Pump Requirements: ft. TDH vs. GPM)
Aggregate Depth: inches below pipe, inches above pipe, inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. [Signature] Date: 02-22-07 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 02-22-2012

HTE# 07-50016801

Permit # 23667

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Old 421


ISSUED TO: Lannie Jones

SUBDIVISION Shaylah's Knoll LOT # 18

Authorized State Agent: Jo Waters

Date: 02-27-07

115' Road to Old 421 →



Meet onsite for
Final Layout

MAINTAIN ALL SETBACKS

STUB OUT PLUMBING
SHALLOW, AT GRADE LEVEL
OR HIGHER

INSTALL 4x60 at
25% REDUCTION SYSTEM
AT 18"