

ADDRESS : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER : SHC HOLDINGS INC
PARCEL : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

STRUCTURE: 000 000 75X45 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07 <u>2-2</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777 <u>KS</u>

COMMENTS AND NOTES

*Would like
PM*

ADDRESS . : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER . . : SHC HOLDINGS INC
PARCEL . . : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

STRUCTURE: 000 000 75X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777
	5/02/07	AP	
A814 01	5/14/07	TI	ADDRESS CONFIRMATION VRU #: 001408723
B103 01	5/14/07 <u>5.14.07</u>	TI <u>APBS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001408731

----- COMMENTS AND NOTES -----

ADDRESS . : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER . . : SHC HOLDINGS INC
PARCEL . . : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

STRUCTURE: 000 000 75X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777
	5/02/07	AP	
B103 01	5/14/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001408731
	5/14/07	AP	
A814 01	5/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001408723
	5/17/07	AP	81 Hunters Point Ct
B105 01	5/24/07	TI	R*OPEN FLOOR VRU #: 001415280
	<u>5/24/07</u>	<u>AP KS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER . . : SHC HOLDINGS INC
PARCEL . . : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

STRUCTURE: 000 000 75X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777
	5/02/07	AP	
B103 01	5/14/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001408731
	5/14/07	AP	
A814 01	5/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001408723
	5/17/07	AP	81 Hunters Point Ct
B105 01	5/24/07	KS	R*OPEN FLOOR VRU #: 001415280
	5/24/07	AP	
R425 01	6/08/07	TI	FOUR TRADE ROUGH IN VRU #: 001425255

6-8 DA

LS

COMMENTS AND NOTES

ADDRESS : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER : SHC HOLDINGS INC
PARCEL : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

STRUCTURE: 000 000 75X45 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777
	5/02/07	AP	
B103 01	5/14/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001408731
	5/14/07	AP	
A814 01	5/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001408723
	5/17/07	AP	81 Hunters Point Ct
B105 01	5/24/07	KS	R*OPEN FLOOR VRU #: 001415280
	5/24/07	AP	
R425 01	6/08/07	KS	FOUR TRADE ROUGH IN VRU #: 001425255
	6/10/07	DA	1. Tie cut floor joists at toilets with adjacent joists 2. GR2 needs a hurricane clip at wall intersection 3. Brace web above bedroom. OK to side and insulate.
I129 01	6/12/07	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001427848
R425 02	6/12/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001427855

6-12

HP
AP

COMMENTS AND NOTES

[Handwritten signatures]

ADDRESS . : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER . . : SHC HOLDINGS INC
PARCEL . . : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

STRUCTURE: 000 000 75X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777
	5/02/07	AP	
B103 01	5/14/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001408731
	5/14/07	AP	
A814 01	5/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001408723
	5/17/07	AP	✓81 Hunters Point Ct
B105 01	5/24/07	KS	R*OPEN FLOOR VRU #: 001415280
	5/24/07	AP	
R425 01	6/08/07	KS	FOUR TRADE ROUGH IN VRU #: 001425255
	6/10/07	DA	1. Tie cut floor joists at toilets with adjacent joists 2. GR2 needs a hurricane clip at wall intersection 3. Brace web above bedroom. OK to side and insulate.
I129 01	6/12/07	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001427848
	6/12/07	AP	
R425 02	6/12/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001427855
	6/12/07	AP	
H824 01	6/19/07	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001432905
	6/19/07	AP	
R429 01	7/16/07	TI	FOUR TRADE FINAL VRU #: 001446624

DA-148

COMMENTS AND NOTES

bath exhaust vents
need screens

ADDRESS : 81 HUNTERS POINT CT
CONTRACTOR : EVANS, INC., DARRYL D.
OWNER : SHC HOLDINGS INC
PARCEL : 07-0691- - -0023- -04-
APPL NUMBER: 07-50016823 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TO ANGIER RIGH ON 55 TO COAST
LEFT ON SILAS HAYES RD HUNTERS POINT
1/4 MILE ON RIGHT LOT 4 JB

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 934-8048
PHONE :

STRUCTURE: 000 000 75X45 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/02/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001401777
	5/02/07	AP	
B103 01	5/14/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001408731
	5/14/07	AP	
A814 01	5/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001408723
	5/17/07	AP	81 Hunters Point Ct
B105 01	5/24/07	KS	R*OPEN FLOOR VRU #: 001415280
	5/24/07	AP	
R425 01	6/08/07	KS	FOUR TRADE ROUGH IN VRU #: 001425255
	6/10/07	DA	1. Tie cut floor joists at toilets with adjacent joists 2. GR2 needs a hurricane clip at wall intersection 3. Brace web above bedroom. OK to side and insulate.
I129 01	6/12/07	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001427848
	6/12/07	AP	
R425 02	6/12/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001427855
	6/12/07	AP	
H824 01	6/19/07	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001432905
	6/19/07	AP	
R429 01	7/16/07	MR	FOUR TRADE FINAL VRU #: 001446624
	7/16/07	DA	
R429 02	7/18/07	KS	FOUR TRADE FINAL VRU #: 001448463
	7/18/07	CA	
R429 03	7/19/07	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001449974
			house was locked 7/18.

7-19 AP

KS COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Daryl Cross Electrical Permit No.: _____
Building Address: 81 Hunters Point Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: 5-16823
Zoning Permit No.: _____ Mech. Permit No.: 07-5-16823
Date: 7-19-07 Envir. C.O. No.: _____
Ken Stahl _____

Building Official

Zoning Official