HTE# 07-5-16827

Harnest County Department of Public nealth 23727

Improvement Permit

A building permit cannot be issued with only an Improvement Permit ISSUED TO: SHC HOIDINGS FNC SUBDIVISION HUNTERS POINT

NEW REPAIR D EXPANSION D SITE IMPRESSION SITE IMPRESSIONS TO SITE IMPRESSION D PROPERTY LOCATION:57 1565 STIAS HAYET Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 25%0126-0007100 System Projected Daily Flow: 36D GPD Number of bedrooms: 3 Number of Occupants: 6 max Basement Yes No ☐ No ☐ May be required based on final location and elevations of facilities Pump Required: Yes Type of Water Supply:

Community Public Well Distance from well feet Five years Permit valid for: Permit conditions: ■ No expiration Authorized State Agent: James Mashantons Date: 3-1-07 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: SHC HOLDINGS IN L PROPERTY LOCATION: SC 1565 SELMS HAZES
SUBDIVISION HUNTERS POINT LOT # 12 Facility Type: SFD New Expansion Repair Type of Wastewater System** 25% reform (Initial) Wastewater Flow: 360 GPD (See note below, if applicable (See note below) Fup to Marches 25% PREDUCTION System (Repair)

Ons / X 3001 Installation Requirements/Conditions Septic Tank Size 1000 gallons Pump Tank Size 1000 gallons Maximum Trench Depth of: 24" maxinches (Maximum soil cover shall not exceed 4-1/2'scl40 VALES (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) Pump Requirements: _____ft. TDH vs. __ in all directions) Aggregate Depth: inches below pipe inches above pipe Conditions: System ARRAS TO BE FEW COL OFF. I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. ** If applicable: Owner/Legal Representative Signature: __ This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent James EManhantons Date: 3-1-07 Construction Authorization Expiration Date: 3-1-12

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: SN 1565 Silas Horgs

ISSUED TO: SHC HOIDINGS INC SUBDIVISION Hunters Point LOT # 12

Authorized State Agent: Date: 3-2-07

