

PREPARED 3/29/07, 13:58:46
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 38
DATE 3/30/07

ADDRESS : 10 FARRAH SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER : BARCO DEVELOPMENT INC
PARCEL : 04-0662- - -0024- -25-
APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
S/D LOT 21 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE :

STRUCTURE: 000 000 40X56.5 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	<u>3/30/07</u> 3-30	TI <u>KSHT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001381043

COMMENTS AND NOTES

ADDRESS : 10 FARRAH-SHEA WAY
 CONTRACTOR : HEAVENLY HOMES-KEVIN R.
 OWNER : BARCO DEVELOPMENT INC
 PARCEL : 04-0662- - -0024- -25-
 APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
 CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
 S/D LOT 21 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
 PHONE : (919) 342-5134
 PHONE :

STRUCTURE: 000 000 40X56.5 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001381043
	3/30/07	AP	
B103 01	4/05/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001384674
	4/05/07	CA	
A814 01	4/09/07	TI	ADDRESS CONFIRMATION VRU #: 001385178
B103 02	4/09/07 <u>4-09</u>	TI <u>DA</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001385186 - KS

COMMENTS AND NOTES

ADDRESS : 10 FARRAH-SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER : BARCO DEVELOPMENT INC
PARCEL : 04-0662- - -0024- -25-
APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
S/D LOT 21 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE :

STRUCTURE: 000 000 40X56.5 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001381043
	3/30/07	AP	
B103 01	4/05/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001384674
	4/05/07	CA	
B103 02	4/09/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001385186
	4/09/07	DA	1. rear offset foundation wall hanging off footer. remove mud facade and dig out beneath foundation. Dowell with #4 rebar epoxied in every 4 feet. Leave open for inspection.
A814 01	4/09/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001385178
	4/05/07	AP	10 Farrah-Shea Way
B103 03	4/11/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001387519

4-11 AP KS

COMMENTS AND NOTES


ADDRESS . : 10 FARRAH-SHEA WAY
 CONTRACTOR : HEAVENLY HOMES-KEVIN R.
 OWNER . . : BARCO DEVELOPMENT INC #21
 PARCEL . . : 04-0662- - -0024- -25-
 APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
 CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
 S/D LOT 21 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
 PHONE : (919) 342-5134
 PHONE :

STRUCTURE: 000 000 40X56.5 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	VRU #:
B101 01	3/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE	001381043
	3/30/07	AP		
B103 01	4/05/07	TI	R*BLDG FOUND & TEMP SVC POLE	001384674
	4/05/07	CA		
B103 02	4/09/07	KS	R*BLDG FOUND & TEMP SVC POLE	001385186
	4/09/07	DA	1. rear offset foundation wall hanging off footer. remove mud facade and dig out beneath foundation. Dowell with #4 rebar epoxied in every 4 feet. Leave open for inspection.	
A814 01	4/09/07	TI	ADDRESS CONFIRMATION TIME: 17:00	001385178
	4/05/07	AP	10 Farrah-Shea Way	
B103 03	4/11/07	KS	R*BLDG FOUND & TEMP SVC POLE	001387519
	4/11/07	AP		
B105 01	4/13/07	KS	R*OPEN FLOOR	001388705
	4/13/07	AP		
R427 01	5/22/07	TI	FOUR TRADE ROUGH IN >2500	001413608

5.22 

COMMENTS AND NOTES

ADDRESS . : 10 FARRAH-SHEA WAY SUBDIV: BRIAN KEITH MEADOW 25LOTS
CONTRACTOR : HEAVENLY HOMES-KEVIN R. PHONE : (919) 342-5134
OWNER . . : BARCO DEVELOPMENT INC #21 PHONE :
PARCEL . . : 04-0662- - -0024- -25-
APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
S/D LOT 21 JB

STRUCTURE: 000 000 40X56.5 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001381043
	3/30/07	AP	
B103 01	4/05/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001384674
	4/05/07	CA	
B103 02	4/09/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001385186
	4/09/07	DA	1. rear offset foundation wall hanging off footer. remove mud facade and dig out beneath foundation. Dowell with #4 rebar epoxied in every 4 feet. Leave open for inspection.
A814 01	4/09/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001385178
	4/05/07	AP	10 Farrah-Shea Way
B103 03	4/11/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001387519
	4/11/07	AP	
B105 01	4/13/07	KS	R*OPEN FLOOR VRU #: 001388705
	4/13/07	AP	
R427 01	5/22/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001413608
	5/22/07	AP	
I129 01	5/24/07	TI	R*INSULATION INSPECTION VRU #: 001415409
	<u>5/24/07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 10 FARRAH-SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER . . . : BARCO DEVELOPMENT INC #21
PARCEL . . . : 04-0662- - -0024- -25-
APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
S/D LOT 21 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE :

STRUCTURE: 000 000 40X56.5 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001381043
	3/30/07	AP	
B103 01	4/05/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001384674
	4/05/07	CA	
B103 02	4/09/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001385186
	4/09/07	DA	1. rear offset foundation wall hanging off footer. remove mud facade and dig out beneath foundation. Dowell with #4 rebar epoxied in every 4 feet. Leave open for inspection.
A814 01	4/09/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001385178
	4/05/07	AP	✓ 10 Farrah-Shea Way
B103 03	4/11/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001387519
	4/11/07	AP	
B105 01	4/13/07	KS	R*OPEN FLOOR VRU #: 001388705
	4/13/07	AP	
R427 01	5/22/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001413608
	5/22/07	AP	
I129 01	5/24/07	BS	R*INSULATION INSPECTION VRU #: 001415409
	5/24/07	AP	
H824 01	5/31/07	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001421544
	5/31/07	AP	
R431 01	11/13/07	TI	FOUR TRADE FINAL >2500 VRU #: 001518986

11-13-07 DABS

COMMENTS AND NOTES

 ADDRESS . . : 10 FARRAH-SHEA WAY
 CONTRACTOR : HEAVENLY HOMES-KEVIN R.
 OWNER . . . : BARCO DEVELOPMENT INC #21
 PARCEL . . . : 04-0662- - -0024- -25-
 APPL NUMBER: 07-50016845 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS ANGIER THUR LEFT ON HARNET
 CENTRAL SCHOOL RD BRIAN - KEITH MEADOWS
 S/D LOT 21 JB
 SUBDIV: BRIAN KEITH MEADOW 25LOTS
 PHONE : (919) 342-5134
 PHONE :

STRUCTURE: 000 000 40X56.5 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001381043
	3/30/07	AP	
B103 01	4/05/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001384674
	4/05/07	CA	
B103 02	4/09/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001385186
	4/09/07	DA	1. rear offset foundation wall hanging off footer. remove mud facade and dig out beneath foundation. Dowell with #4 rebar epoxied in every 4 feet. Leave open for inspection.
A814 01	4/09/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001385178
	4/05/07	AP	✓10 Farrah-Shea Way
B103 03	4/11/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001387519
	4/11/07	AP	
B105 01	4/13/07	KS	R*OPEN FLOOR VRU #: 001388705
	4/13/07	AP	
R427 01	5/22/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001413608
	5/22/07	AP	
I129 01	5/24/07	BS	R*INSULATION INSPECTION VRU #: 001415409
	5/24/07	AP	
H824 01	5/31/07	BM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001421544
	5/31/07	AP	
R431 01	11/13/07	BS	FOUR TRADE FINAL >2500 VRU #: 001518986
	11/13/07	DA	1. Clean out crawlspace and install plastic (insufficient ventilatiltion per code) 2. Need a lockout or disconnect on water heater
R431 02	11/15/07	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001520352

11-15-07 APBS

 COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD
Type of Construction: V
Owner of Building: Horvath Homes
Building Address: 16 Fairview Street W. Raleigh
Zoning District: _____
Zoning Permit No.: N/A
Date: 11-15-07
Brad Smith
Building Official

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: AS-16845
Envir. C.O. No.: _____

Zoning Official