

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 07-500 16911

Applicant:

Address:

Date Evaluated: 2-27

Proposed Facility: SFO

Design Flow (.1949): 360

Property Size: .67M

Location of Site: 1272

Property Recorded: *W*

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Saprot Class	1944 Restr. Horiz.		
S 2/1		0-24	GA JL	VKA S					5	
		24-78	SDH JCL	FR S						
		0-30	GA JL	VKA S						5
		30-78	SDH JCL	FR S						
		0-30	GA JL	VKA S						5
		30-78	SDH JCL	FR S						
		0-12	GA JL	VKA S						4
		12-30	SDH JCL	FR S						
		30-78	SDH JCL	FR S						

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	CAO	W
Site LTAR	1.5	2

Other Factors (.1946): _____
 Site Classification (.1948): B)
 Evaluated By: *W*
 Others Present: *51*