

HTE# 07-500-~~16914~~

Harnett County Department of Public Health

23686

Thomas Properties

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: TPT Properties
PROPERTY LOCATION: 1272
SUBDIVISION: Darlington Hills
LOT #: 8
Type of Structure: SFD-45x60 3BR
Proposed Wastewater System Type: Pump to 25% Reduction system
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement: No
Pump Required: Yes
Type of Water Supply: Public
Permit conditions: Meet code maintain all set backs

Authorized State Agent: [Signature] Date: 3-5-07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: TPT Properties
PROPERTY LOCATION: 1272
SUBDIVISION: Darlington Hills
LOT #: 8
Facility Type: SFD-45x60 3BR New
Basement: No
Type of Wastewater System: Pump to 25% Reduction (Initial)
Wastewater Flow: 360 GPD
(See note below, if applicable) 480 LF of 12" (Repair)

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons
Pump Tank Size: 1000 gallons
Exact length of each trench: 1x300 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
Maximum Trench Depth of: 18 inches
Pump Requirements: _____ ft. TDH vs. _____ GPM
Aggregate Depth: _____ inches below pipe, _____ inches above pipe, _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 03-05-07 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 03-05-2012

HTE# 07-500 16914

Permit # 23686

Harnett County Department of Public Health Site Sketch

Thomas Properties

ISSUED TO: *TPT Properties*

PROPERTY LOCATOR: 1272

SUBDIVISION *Darlington Hill*

LOT # 8

Authorized State Agent: *[Signature]*

Date: 3-5-07

