

HTE# 07-5-16959

Harrison County Department of Public Health

23958

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: SHC HOLDINGS INC

PROPERTY LOCATION: 5121565 SELAS HAYES RD

SUBDIVISION HUNTERS POINT

LOT # 29

NEW  REPAIR  EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD

Proposed Wastewater System Type: 25% REDUCTION SYSTEM

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:  Five years

Permit conditions: \_\_\_\_\_  No expiration

Authorized State Agent: James E. Manhart

Date: 6-6-07

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: SHC HOLDINGS INC

PROPERTY LOCATION: 5121565 SELAS HAYES RD

SUBDIVISION HUNTERS POINT

LOT # 29

Facility Type: SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% REDUCTION SYSTEM (Initial)

Wastewater Flow: 360 GPD

(See note below, if applicable )

25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions

Septic Tank Size 1008 gallons Exact length of each trench 80 feet Trench Spacing: 9 Feet on Center  
Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches  
Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)  
(Trench bottoms shall be level to +/- 1/4" in all directions)  
Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe  
2 inches above pipe  
Conditions: \_\_\_\_\_ 12 inches total

\*\*If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manhart

Date: 6-6-07

Construction Authorization Expiration Date: 6-6-12

HTE# 07-5-16959

Permit # 23958

# Harnett County Department of Public Health Site Sketch

ISSUED TO: SHC HOLDINGS INC PROPERTY LOCATOR: SR 1565 SILAS HAYES RD  
SUBDIVISION: HUNTERS POINT LOT # 29

Authorized State Agent: James E. Marshall Date: 6-6-07

