

Property ID:  
Lot #:  
File #:  
Code:

### SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:  
Address:  
Proposed Facility:  
Location of Site:  
Water Supply:  Public  Individual  Well  
Evaluation Method:  Auger Boring  Pit  
Type of Wastewater:  Sewage  Industrial Process

Applicant:  
Date Evaluated:  
Property Size:  
Property Recorded:  Spring  Other  
 Cut  
 Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr. Horiz.	
1	L 5/6	0-17	SL						-35
		17-44	SCL		42" 7.5" R 4.7				
2	L 4/8	0-12	SL						-25
		12-30	SC-CLAY		28" 7.5" R 4.2				
3	L 20/0	0-16	SL						-28
		16-32	SC-CLAY		28" 7.5" R 4.2				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	INNOV-	INNOV
Site LTAR	28 (.3)	25 (.3)

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): **PS**  
 Evaluated By: **OT**  
 Others Present: \_\_\_\_\_

**SYSTEM PROPOSED  
ADDITIONAL  
& SOIL BORINGS  
BY MWE EARL L25**


COMMENTS: \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY		EFI-EXTREMELY FIRM	NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



Lot 3 Hunters Point  
150 High Standard Ln

SITE PLAN APPROVAL

DISTRICT RA30 USE SED

# OF BEDROOMS 3

2.22.07 ALAN KIM

ZONING DISTRICT: STAFF OR

1-50

High Standard Ln.

