HTE# 07-5-17811R

Harriett County Department of Public mealth 23976

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: SC 1565 SILASHAYES MD ISSUED TO: Broadley Built, The
NEW PREPAIR DEXPANSION SUBDIVISION HUNGERS PORNT Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 25% CGD OCTION Projected Daily Flow: 360 GPD Number of Occupants: 6 max Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: ☐Yes ☐ No Type of Water Supply:

Community Public Well Distance from well _______feet Permit valid for: Five years ■ No expiration Permit conditions: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Bradley Butt INC PROPERTY LOCATION: SPC1565 ST/AS HAYES RD
SUBDIVISION HUNTERS POINT LOT # 49 ✓ New ☐ Expansion ☐ Repair Basement Fixtures?

Yes

No Wastewater Flow: 360 GPD Type of Wastewater System** 25% 1250 KTOD System (Initial) (See note below, if applicable

) Installation Requirements/Conditions Exact length of each trench 80 feet Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 20" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. **If applicable: Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Date: 6-25-07

Construction Authorization Expiration Date: 6-25-12

Harnett County Department of Public Health Site Sketch

