
ADDRESS . . : 89 FARRAH SHEA WAY
CONTRACTOR : VUNCANNON CONTRACTING LLC
OWNER . . . : BARCO DEVELOPMENT INC #1
PARCEL . . . : 04-0662- - -0024- -05-
APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #1
 210 TOWARDS ANGIER LEFT ONTO HARNETT
 CENTRAL RD S/D ON RT. JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 868-4923
PHONE : (919) 552-2592

STRUCTURE: 000 000 52X43 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07 <u>3-28</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437 Lot #1 in Brian Keith Meadows - footing inspection

KS

COMMENTS AND NOTES

ADDRESS . : 89 FARRAH-SHEA WAY
CONTRACTOR : VUNCANNON CONTRACTING LLC
OWNER . . : BARCO DEVELOPMENT INC #1
PARCEL . . : 04-0662- - -0024- -05-
APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #1
210 TOWARDS ANGIER LEFT ONTO HARNETT
CENTRAL RD S/D ON RT. JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 868-4923
PHONE : (919) 552-2592

STRUCTURE: 000 000 52X43 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437
	3/28/07	AP	Lot #1 in Brian Keith Meadows - footing inspection
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001389295
B103 01	4/13/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001389287

4-13 AP

KS

COMMENTS AND NOTES

ADDRESS : 89 FARRAH-SHEA WAY
CONTRACTOR : VUNCANNON CONTRACTING LLC
OWNER : BARCO DEVELOPMENT INC #1
PARCEL : 04-0662- - -0024- -05-
APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #1
210 TOWARDS ANGIER LEFT ONTO HARNETT
CENTRAL RD S/D ON RT. JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 868-4923
PHONE : (919) 552-2592

STRUCTURE: 000 000 52X43 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437
	3/28/07	AP	Lot #1 in Brian Keith Meadows - footing inspection
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001389295
	4/13/07	AP	89 FARRAH-SHEA WAY LOT 1
B103 01	4/13/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001389287
	4/13/07	AP	
B105 01	4/18/07	TI	R*OPEN FLOOR VRU #: 001391549
	<u>4/18/07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 89 FARRAH-SHEA WAY
CONTRACTOR : VUNCANNON CONTRACTING LLC
OWNER . . : BARCO DEVELOPMENT INC #1
PARCEL . . : 04-0662- - -0024- -05-
APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #1
210 TOWARDS ANGIER LEFT ONTO HARNETT
CENTRAL RD S/D ON RT. JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 868-4923
PHONE : (919) 552-2592

STRUCTURE: 000 000 52X43 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437
	3/28/07	AP	Lot #1 in Brian Keith Meadows - footing inspection
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001389295
	4/13/07	AP	89 FARRAH-SHEA WAY LOT 1
B103 01	4/13/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001389287
	4/13/07	AP	
B105 01	4/18/07	BS	R*OPEN FLOOR VRU #: 001391549
	4/18/07	AP	Check 3 doubles on left side o house at rough in
R427 01	5/16/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001410448
	<u>5-16-07</u>	<u>DABS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 89 FARRAH-SHEA WAY
 CONTRACTOR : VUNCANNON CONTRACTING LLC
 OWNER . . : BARCO DEVELOPMENT INC #1
 PARCEL . . : 04-0662- - -0024- -05-
 APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)

SUBDIV: BRIAN KEITH MEADOW 25LOTS
 PHONE : (919) 868-4923
 PHONE : (919) 552-2592

DIRECTIONS : BRIAN KEITH MEADOWS #1
 210 TOWARDS ANGIER LEFT ONTO HARNETT
 CENTRAL RD S/D ON RT. JDAVIS

STRUCTURE: 000 000 52X43 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437
	3/28/07	AP	Lot #1 in Brian Keith Meadows - footing inspection
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001389295
	4/13/07	AP	89 FARRAH-SHEA WAY LOT 1
B103 01	4/13/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001389287
	4/13/07	AP	
B105 01	4/18/07	BS	R*OPEN FLOOR VRU #: 001391549
	4/18/07	AP	Check 3 doubles on left side o house at rough in
R427 01	5/16/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001410448
	5/16/07	DA	1. Sheet inside garage. 2. Firestop holes at top plate in garage 3. Need tempered glass at tub. 4. Move ridge support above bedroom to load wall, cannot support on ceiling. ok to side/insulate
I129 01	5-22 5/22/07	TI AP	R*INSULATION INSPECTION VRU #: 001413178
R427 02	5-22 5/22/07	TI AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001414010

COMMENTS AND NOTES

ADDRESS : 89 FARRAH-SHEA WAY
CONTRACTOR : VUNCANNON CONTRACTING LLC
OWNER : BARCO DEVELOPMENT INC #1
PARCEL : 04-0662- - -0024- -05-
APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #1
210 TOWARDS ANGIER LEFT ONTO HARNETT
CENTRAL RD S/D ON RT. JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 868-4923
PHONE : (919) 552-2592

STRUCTURE: 000 000 52X43 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437
	3/28/07	AP	Lot #1 in Brian Keith Meadows - footing inspection
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001389295
	4/13/07	AP	89 FARRAH-SHEA WAY LOT 1
B103 01	4/13/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001389287
	4/13/07	AP	
B105 01	4/18/07	BS	R*OPEN FLOOR VRU #: 001391549
	4/18/07	AP	Check 3 doubles on left side o house at rough in
R427 01	5/16/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001410448
	5/16/07	DA	1. Sheet inside garage. 2. Firestop holes at top plate in garage 3. Need tempered glass at tub. 4. Move ridge support above bedroom to load wall, cannot support on ceiling. ok to side/insulate
I129 01	5/22/07	KS	R*INSULATION INSPECTION VRU #: 001413178
	5/22/07	AP	
R427 02	5/22/07	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001414010
	5/22/07	AP	
H824 01	6/25/07	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001436229
	6/25/07	AP	
R429 01	8/08/07	TI	FOUR TRADE FINAL VRU #: 001461763

8-8 DP

----- COMMENTS AND NOTES -----

 ADDRESS . : 89 FARRAH-SHEA WAY SUBDIV: BRIAN KEITH MEADOW 25LOTS
 CONTRACTOR : VUNCANNON CONTRACTING LLC PHONE : (919) 868-4923
 OWNER . . : BARCO DEVELOPMENT INC #1 PHONE : (919) 552-2592
 PARCEL . . : 04-0662- - -0024- -05-
 APPL NUMBER: 07-50017099 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : BRIAN KEITH MEADOWS #1
 210 TOWARDS ANGIER LEFT ONTO HARNETT
 CENTRAL RD S/D ON RT. JDAVIS

STRUCTURE: 000 000 52X43 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001379437
	3/28/07	AP	Lot #1 in Brian Keith Meadows - footing inspection
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001389295
	4/13/07	AP	✓89 FARRAH-SHEA WAY LOT 1
B103 01	4/13/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001389287
	4/13/07	AP	
B105 01	4/18/07	BS	R*OPEN FLOOR VRU #: 001391549
	4/18/07	AP	Check 3 doubles on left side o house at rough in
R427 01	5/16/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001410448
	5/16/07	DA	1. Sheet inside garage. 2. Firestop holes at top plate in garage 3. Need tempered glass at tub. 4. Move ridge support above bedroom to load wall, cannot support on ceiling. ok to side/insulate
I129 01	5/22/07	KS	R*INSULATION INSPECTION VRU #: 001413178
	5/22/07	AP	
R427 02	5/22/07	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001414010
	5/22/07	AP	
H824 01	6/25/07	BM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001436229
	6/25/07	AP	
R429 01	8/08/07	KS	FOUR TRADE FINAL VRU #: 001461763
	8/08/07	DP	1. Need 911 numbers on house in 3 inch contrasting number 2. Neutrals and grounds reversed in the subpanel. Grounding bar wired with neutrals and vice versa.
R429 02	8/15/07	TI	FOUR TRADE FINAL VRU #: 001467414

8/15 AP

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Vuncannon Cont LLC Electrical Permit No.: _____
Building Address: 89 Farrell - Sea Way Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 8-15-07 Envir. C.O. No.: 6-50017069
K. Stath Building Official _____ Zoning Official