

PREPARED 4/24/07, 14:03:31
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 56
DATE 4/25/07

ADDRESS . : 11 DEXTERFIELD DR
CONTRACTOR : RAYNOR BUILDERS INC
OWNER . . : ATKINS PLACE LLC
PARCEL . . : 08-0653- - -0030- -01-
APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : DEXTERFIELD SUBD LOT 1
401 NORTH 7-8 TURN LEFT ON CHALYBEATE
RD SUBD IS ON LEFT
T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
PHONE : (919) 639-3012
PHONE :

STRUCTURE: 000 000 48X60 3 BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07 <u>4-25-07</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108

COMMENTS AND NOTES -----

ADDRESS . : 11 DEXTERFIELD DR
CONTRACTOR : RAYNOR BUILDERS INC
OWNER . . : ATKINS PLACE LLC
PARCEL . . : 08-0653- - -0030- -01-
APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : DEXTERFIELD SUBD LOT 1
401 NORTH 7-8 TURN LEFT ON CHALYBEATE
RD SUBD IS ON LEFT
T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
PHONE : (919) 639-3012
PHONE :

STRUCTURE: 000 000 48X60 3 BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
B103 01	4/25/07 <u>5-2-07</u>	AP <u>TI</u> <u>APR</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637

COMMENTS AND NOTES

ADDRESS . : 11 DEXTERFIELD DR
CONTRACTOR : RAYNOR BUILDERS INC
OWNER . . : ATKINS PLACE LLC
PARCEL . . : 08-0653- - -0030- -01-
APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : DEXTERFIELD SUBD LOT 1
401 NORTH 7-8 TURN LEFT ON CHALYBEATE
RD SUBD IS ON LEFT
T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
PHONE : (919) 639-3012
PHONE :

STRUCTURE: 000 000 48X60 3 BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
	4/25/07	AP	
B103 01	5/02/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637
	5/02/07	AP	
B105 01	5/07/07	TI	R*OPEN FLOOR VRU #: 001404086
	<u>5-7-07</u>	<u>APBS</u>	

COMMENTS AND NOTES

PREPARED 6/07/07, 14:00:15
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 56
DATE 6/08/07

ADDRESS . . : 11 DEXTERFIELD DR
CONTRACTOR : RAYNOR BUILDERS INC
OWNER . . . : ATKINS PLACE LLC
PARCEL . . . : 08-0653- - -0030- -01-
APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : DEXTERFIELD SUBD LOT 1
401 NORTH 7-8 TURN LEFT ON CHALYBEATE
RD SUBD IS ON LEFT
T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
PHONE : (919) 639-3012
PHONE :

STRUCTURE: 000 000 48X60 3 BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
	4/25/07	AP	
B103 01	5/02/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637
	5/02/07	AP	
B105 01	5/07/07	BS	R*OPEN FLOOR VRU #: 001404086
	5/07/07	AP	
A814 01	6/08/07	TI	ADDRESS CONFIRMATION VRU #: 001425305
R427 01	6/08/07 <i>6-8-7</i>	TI <i>DPB</i>	FOUR TRADE ROUGH IN >2500 VRU #: 001425313

COMMENTS AND NOTES

ADDRESS . : 11 DEXTERFIELD DR
 CONTRACTOR : RAYNOR BUILDERS INC
 OWNER . . : ATKINS PLACE LLC
 PARCEL . . : 08-0653- - -0030- -01-
 APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : DEXTERFIELD SUBD LOT 1
 401 NORTH 7-8 TURN LEFT ON CHALYBEATE
 RD SUBD IS ON LEFT
 T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
 PHONE : (919) 639-3012
 PHONE :

STRUCTURE: 000 000 48X60 3 BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
	4/25/07	AP	
B103 01	5/02/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637
	5/02/07	AP	
B105 01	5/07/07	BS	R*OPEN FLOOR VRU #: 001404086
	5/07/07	AP	
R427 01	6/08/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001425313
	6/08/07	DP	1. Need tempered glass at rear door. 2. No roof boots. 3. Tie back rafters over master, nook, and front. 4. Winders incorrect. 5. Sheet inside garage walls. 6. Close off vents at rear drop deck to prevent rainwater from entering crawlspace. 7. Flash front porch. 8. Install exterior doors. Do not side/insulate \$50. re fee
A814 01	6/08/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001425305
	6/07/07	AP	11 Dexterfield Dr
R425 01	6/14/07	TI	FOUR TRADE ROUGH IN VRU #: 001428671
	<u>6/14/07</u>	<u>AP KS</u>	

COMMENTS AND NOTES

ADDRESS . : 11 DEXTERFIELD DR
 CONTRACTOR : RAYNOR BUILDERS INC
 OWNER . . : ATKINS PLACE LLC
 PARCEL . . : 08-0653- - -0030- -01-
 APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : DEXTERFIELD SUBD LOT 1
 401 NORTH 7-8 TURN LEFT ON CHALYBEATE
 RD SUBD IS ON LEFT
 T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
 PHONE : (919) 639-3012
 PHONE :

STRUCTURE: 000 000 48X60 3 BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
	4/25/07	AP	
B103 01	5/02/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637
	5/02/07	AP	
B105 01	5/07/07	BS	R*OPEN FLOOR VRU #: 001404086
	5/07/07	AP	
R427 01	6/08/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001425313
	6/08/07	DP	1. Need tempered glass at rear door. 2. No roof boots. 3. Tie back rafters over master, nook, and front. 4. Winders incorrect. 5. Sheet inside garage walls. 6. Close off vents at rear drop deck to prevent rainwater from entering crawlspace. 7. Flash front porch. 8. Install exterior doors. Do not side/insulate \$50. re fee
A814 01	6/08/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001425305
	6/07/07	AP	✓ 11 Dexterfield Dr
R425 01	6/14/07	KS	FOUR TRADE ROUGH IN VRU #: 001428671
	6/14/07	AP	
I129 01	6/18/07	DT	R*INSULATION INSPECTION VRU #: 001430537
	6/18/07	AP	
H824 01	6/19/07	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001432921
	6/19/07	AP	
R429 01	8/10/07	TI	FOUR TRADE FINAL VRU #: 001462837
	<u>8-10-07</u>	<u>OPB</u>	

COMMENTS AND NOTES

35,000

ADDRESS . : 11 DEXTERFIELD DR
 CONTRACTOR : RAYNOR BUILDERS INC
 OWNER . . : ATKINS PLACE LLC
 PARCEL . . : 08-0653- - -0030- -01-
 APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : DEXTERFIELD SUBD LOT 1
 401 NORTH 7-8 TURN LEFT ON CHALYBEATE
 RD SUBD IS ON LEFT
 T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
 PHONE : (919) 639-3012
 PHONE :

STRUCTURE: 000 000 48X60 3 BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
	4/25/07	AP	
B103 01	5/02/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637
	5/02/07	AP	
B105 01	5/07/07	BS	R*OPEN FLOOR VRU #: 001404086
	5/07/07	AP	
R427 01	6/08/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001425313
	6/08/07	DP	1. Need tempered glass at rear door. 2. No roof boots. 3. Tie back rafters over master, nook, and front. 4. Winders incorrect. 5. Sheet inside garage walls. 6. Close off vents at rear drop deck to prevent rainwater from entering crawlspace. 7. Flash front porch. 8. Install exterior doors. Do not side/insulate \$50. re fee
A814 01	6/08/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001425305
	6/07/07	AP	✓ 11 Dexterfield Dr
R425 01	6/14/07	KS	FOUR TRADE ROUGH IN VRU #: 001428671
	6/14/07	AP	
I129 01	6/18/07	DT	R*INSULATION INSPECTION VRU #: 001430537
	6/18/07	AP	
H824 01	6/19/07	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001432921
	6/19/07	AP	
R429 01	8/10/07	BS	FOUR TRADE FINAL VRU #: 001462837
	8/10/07	DP	no address, doors locked
R429 02	8/15/07	TI	FOUR TRADE FINAL VRU #: 001466846

8:15:07 DPBS

COMMENTS AND NOTES

ADDRESS : 11 DEXTERFIELD DR
 CONTRACTOR : RAYNOR BUILDERS INC
 OWNER : ATKINS PLACE LLC
 PARCEL : 08-0653- - -0030- -01-
 APPL NUMBER: 07-50017197 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : DEXTERFIELD SUBD LOT 1
 401 NORTH 7-8 TURN LEFT ON CHALYBEATE
 RD SUBD IS ON LEFT
 T/S: 03/26/2007 11:28 AM DJOHNSON --

SUBDIV: DEXTERFIELD
 PHONE : (919) 639-3012
 PHONE :

STRUCTURE: 000 000 48X60 3 BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/25/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001397108
	4/25/07	AP	
B103 01	5/02/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001401637
	5/02/07	AP	
B105 01	5/07/07	BS	R*OPEN FLOOR VRU #: 001404086
	5/07/07	AP	
R427 01	6/08/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001425313
	6/08/07	DP	1. Need tempered glass at rear door. 2. No roof boots. 3. Tie back rafters over master, nook, and front. 4. Winders incorrect. 5. Sheet inside garage walls. 6. Close off vents at rear drop deck to prevent rainwater from entering crawlspace. 7. Flash front porch. 8. Install exterior doors. Do not side/insulate \$50. re fee
A814 01	6/08/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001425305
	6/07/07	AP	✓ 11 Dexterfield Dr
R425 01	6/14/07	KS	FOUR TRADE ROUGH IN VRU #: 001428671
	6/14/07	AP	
I129 01	6/18/07	DT	R*INSULATION INSPECTION VRU #: 001430537
	6/18/07	AP	
H824 01	6/19/07	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001432921
	6/19/07	AP	
R429 01	8/10/07	BS	FOUR TRADE FINAL VRU #: 001462837
	8/10/07	DP	no address, doors locked
R429 02	8/15/07	BS	FOUR TRADE FINAL VRU #: 001466846
	8/15/07	DP	1. No receptacle at peninsula. 2. Both Arc fault breakers in sub panel labeled master bedroom. 3. Cap off and terminate unused heat circuit for rec room. 4. No insulation under house.
R429 03	8/22/07	TI	FOUR TRADE FINAL VRU #: 001470285

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Type of Construction: IV

Owner of Building: Raynor Builders Inc

Building Address: 11 Dufresnefield Dr

Zoning District: _____

Zoning Permit No.: N/A

Date: 8-22-07

Bruce Sutton

Building Official

Conditional Use Permit No.: _____

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: AS

Mech. Permit No.: _____

Envir. C.O. No.: _____

Zoning Official