

ADDRESS . : 86 FARRAH-SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER . . : HEAVENLY HOMES - KEVIN R SWART
PARCEL . . : 04-0662- - -0024- -21-
APPL NUMBER: 07-50017238 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #17
210 LEFT ON HARNETT CENTRAL RD S/D ON
RT LEFT ON FARRAH SHAW LOT ON RT.
JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE : (919) 342-5134

STRUCTURE: 000 000 42X55 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/18/07 <u>6/18/07</u>	TI <u>AD DT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001430641

----- COMMENTS AND NOTES -----

ADDRESS : 86 FARRAH-SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER : HEAVENLY HOMES - KEVIN R SWART
PARCEL : 04-0662- - -0024- -21-
APPL NUMBER: 07-50017238 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #17
210 LEFT ON HARNETT CENTRAL RD S/D ON
RT LEFT ON FARRAH SHAW LOT ON RT.
JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE : (919) 342-5134

STRUCTURE: 000 000 42X55 4BR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/18/07	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001430641
	6/18/07	AP	
A814 01	6/25/07	TI	ADDRESS CONFIRMATION VRU #: 001434406
B103 01	6/25/07	TE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001434398

Handwritten signatures and initials:
CZ (checkmark)
AP
KS

COMMENTS AND NOTES

ADDRESS . : 86 FARRAH-SHEA WAY SUBDIV: BRIAN KEITH MEADOW 25LOTS
CONTRACTOR : HEAVENLY HOMES-KEVIN R. PHONE : (919) 342-5134
OWNER . . : HEAVENLY HOMES - KEVIN R SWART PHONE : (919) 342-5134
PARCEL . . : 04-0662- - -0024- -21-
APPL NUMBER: 07-50017238 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #17
210 LEFT ON HARNETT CENTRAL RD S/D ON
RT LEFT ON FARRAH SHAW LOT ON RT.
JDAVIS

STRUCTURE: 000 000 42X55 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/18/07 6/18/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001430641
A814 01	6/25/07	TI	ADDRESS CONFIRMATION VRU #: 001434406
B103 01	6/25/07 6/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001434398
B105 01	7/02/07 <u>7-2-7</u>	TI <u>ACB</u>	R*OPEN FLOOR VRU #: 001438885

----- COMMENTS AND NOTES -----

ADDRESS : 86 FARRAH-SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER : HEAVENLY HOMES - KEVIN R SWART
PARCEL : 04-0662- - -0024- -21-
APPL NUMBER: 07-50017238 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #17
210 LEFT ON HARNETT CENTRAL RD S/D ON
RT LEFT ON FARRAH SHAW LOT ON RT.
JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE : (919) 342-5134

STRUCTURE: 000 000 42X55 4BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/18/07 6/18/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001430641
A814 01	6/25/07 7/05/07	TI AP	ADDRESS CONFIRMATION VRU #: 001434406 86 FARRAH-SHEA WAY LOT 17
B103 01	6/25/07 6/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001434398
B105 01	7/02/07 7/02/07	BS AE	R*OPEN FLOOR VRU #: 001438885 1. Move foundation vent under cantilever double and brick up hole or provide engineering on steel size needed to carry cantilever load. OK to cover, have corrected before rough in.
R427 01	7/31/07 <u>7-31</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001456935

COMMENTS AND NOTES

ADDRESS : 86 FARRAH-SHEA WAY
 CONTRACTOR : HEAVENLY HOMES-KEVIN R.
 OWNER : HEAVENLY HOMES - KEVIN R SWART
 PARCEL : 04-0662- - -0024- -21-
 APPL NUMBER: 07-50017238 CP NEW RESIDENTIAL (SFD)

SUBDIV: BRIAN KEITH MEADOW 25LOTS
 PHONE : (919) 342-5134
 PHONE : (919) 342-5134

DIRECTIONS : BRIAN KEITH MEADOWS #17
 210 LEFT ON HARNETT CENTRAL RD S/D ON
 RT LEFT ON FARRAH SHAW LOT ON RT.
 JDAVIS

STRUCTURE: 000 000 42X55 4BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/18/07 6/18/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001430641
A814 01	6/25/07 7/05/07	TI AP	ADDRESS CONFIRMATION VRU #: 001434406 86 FARRAH-SHEA WAY LOT 17
B103 01	6/25/07 6/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001434398
B105 01	7/02/07 7/02/07	BS AE	R*OPEN FLOOR VRU #: 001438885 1. Move foundation vent under cantilever double and brick up hole or provide engineering on steel size needed to carry cantilever load. OK to cover, have corrected before rough in.
R427 01	7/31/07 7/31/07	KS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001456935 Where is your portajon? You need one for next inspection. 1. Need tempered glass next to rear door. Both sash. 2. Fire caulk vent for laundry at top plate 3. Flashing for brick can either be behind OSB or you must install felt paper or housewrap on remaining wall and lap over felt currently on the building. 4. Stairs may not meet code when finished. Cannot be more than 3/8 between stairs and top and bottom no more than 3/4 of an inch. Risers not more than 8 1/4 inches. If it will work out, fine but I will check at final and don't want any surprises. OK to insulate
I129 01	8/03/07 8-3	TI AP	R*INSULATION INSPECTION VRU #: 001459841 Tempered sashes on order, Whole house to be wrapped by siding installer. Kevin 422-7623
R427 02	8/03/07 8-3	TI AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001460021

COMMENTS AND NOTES

ADDRESS : 86 FARRAH-SHEA WAY
CONTRACTOR : HEAVENLY HOMES-KEVIN R.
OWNER : HEAVENLY HOMES - KEVIN R SWART
PARCEL : 04-0662- - -0024- -21-
APPL NUMBER: 07-50017238 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BRIAN KEITH MEADOWS #17 (PREMIS NUMBER
FOR PROGRESS ENERGY IS 67492590)
210 LEFT ON HARNETT CENTRAL RD S/D ON
RT LEFT ON FARRAH SHAW LOT ON RT.
JDAVIS

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 342-5134
PHONE : (919) 342-5134

STRUCTURE: 000 000 42X55 4BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/18/07 6/18/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001430641
A814 01	6/25/07 7/05/07	TI AP	ADDRESS CONFIRMATION VRU #: 001434406 ✓86 FARRAH-SHEA WAY LOT 17
B103 01	6/25/07 6/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001434398
B105 01	7/02/07 7/02/07	BS AE	R*OPEN FLOOR VRU #: 001438885 1. Move foundation vent under cantilever double and brick up hole or provide engineering on steel size needed to carry cantilever load. OK to cover, have corrected before rough in.
R427 01	7/31/07 7/31/07	KS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001456935 Where is your portajon? You need one for nexgt inspection. 1. Need tempered glass next to rear door. Both sash. 2. Fire caulk vent for laundry at top plate 3. Flashing for brick can either be behind OSB or you must install felt paperor housewrap on remaining wall and lap over felt currently on the building. 4. Stairs may not meet code when finished. Cannot be more than 3/8 between stairs and top and bottom no more than 3/4 of an inch. Risers not more than 8 1/4 inches. If it will work out, fine but I will check at final and don't want any surprises. OK to insulate
I129 01	8/03/07 8/03/07	KS AP	R*INSULATION INSPECTION VRU #: 001459841 Tempered sashes on order, Whole house to be wrapped by siding installer. Kevin 422-7623
R427 02	8/03/07 8/03/07	KS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001460021
H824 01	9/07/07 9/07/07	JM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001482348
R431 01	1/16/08 <u>1-16</u>	TI <u>PT</u>	FOUR TRADE FINAL >2500 VRU #: 001547785

----- COMMENTS AND NOTES -----

COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Heavenly Home Electrical Permit No.: _____
Building Address: 86 Farrah Shea Way Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: 200
Zoning Permit No.: _____ Mech. Permit No.: 5
Date: 1-16-08 Envir. C.O. No.: 0

K. Slath
Building Official

Zoning Official