

-----  
ADDRESS . : 66 BOULDER DR  
CONTRACTOR : CAVINESS & CATES BUILDING AND  
OWNER . . : CAVINESS & CATES BUILDING  
PARCEL . . : 03-9587-13- -0020- -24-  
APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
ON BUFFALO LAKE RD APPROX 2 MILES TURN  
LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
TIMBERLINE DR INTO S/D LOT 104 JB  
-----

SUBDIV: THE SUMMIT SEC3 50 LOTS  
PHONE : (910) 481-0503  
PHONE : (910) 481-0503

-----  
**STRUCTURE: 000 000 52X51 3BDR**  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

**PERMIT: CPSF 01 CP \* SFD**

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS

B101 01	5/25/07	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382
		<u>DA-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 66 BOULDER DR  
CONTRACTOR : CAVINESS & CATES BUILDING AND  
OWNER . . : CAVINESS & CATES BUILDING  
PARCEL . . : 03-9587-13- -0020- -24-  
APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
ON BUFFALO LAKE RD APPROX 2 MILES TURN  
LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
PHONE : (910) 481-0503  
PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386

           *AP-MR*

----- COMMENTS AND NOTES -----

-----  
ADDRESS . . : 66 BOULDER DR SUBDIV: THE SUMMIT SEC3 50 LOTS  
CONTRACTOR : CAVINESS & CATES BUILDING AND PHONE : (910) 481-0503  
OWNER . . . : CAVINESS & CATES BUILDING PHONE : (910) 481-0503  
PARCEL . . . : 03-9587-13- -0020- -24-  
APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
ON BUFFALO LAKE RD APPROX 2 MILES TURN  
LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
TIMBERLINE DR INTO S/D LOT 104 JB  
-----

**STRUCTURE: 000 000 52X51 3BDR**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

**PERMIT: CPSF 01 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382
	5/25/07	DA	1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468

                     *S.P. 142*

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 66 BOULDER DR SUBDIV: THE SUMMIT SEC3 50 LOTS  
CONTRACTOR : CAVINESS & CATES BUILDING AND PHONE : (910) 481-0503  
OWNER . . : CAVINESS & CATES BUILDING PHONE : (910) 481-0503  
PARCEL . . : 03-9587-13- -0020- -24-  
APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
ON BUFFALO LAKE RD APPROX 2 MILES TURN  
LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
TIMBERLINE DR INTO S/D LOT 104 JB  
-----

STRUCTURE: 000 000 52X51 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382
	5/25/07	DA	1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
	5/29/07	AP	
B103 01	6/01/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
	6/01/07	AP	
P309 01	6/08/07	TI	R*PLUMB UNDER SLAB VRU #: 001425727

AP-MR

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 66 BOULDER DR SUBDIV: THE SUMMIT SEC3 50 LOTS  
CONTRACTOR : CAVINESS & CATES BUILDING AND PHONE : (910) 481-0503  
OWNER . . : CAVINESS & CATES BUILDING PHONE : (910) 481-0503  
PARCEL . . : 03-9587-13- -0020- -24-  
APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
ON BUFFALO LAKE RD APPROX 2 MILES TURN  
LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
TIMBERLINE DR INTO S/D LOT 104 JB  
-----

**STRUCTURE: 000 000 52X51 3BDR**  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

**PERMIT: CPSF 01 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
A814 01	6/11/07	TI	ADDRESS CONFIRMATION VRU #: 001423640
B111 01	6/11/07	TI	R*BLDG SLAB INSP VRU #: 001426790

~~DA-IVR~~  
DA-IVR

-----  
COMMENTS AND NOTES  
-----

-----

ADDRESS . . : 66 BOULDER DR SUBDIV: THE SUMMIT SEC3 50 LOTS  
 CONTRACTOR : CAVINESS & CATES BUILDING AND PHONE : (910) 481-0503  
 OWNER . . : CAVINESS & CATES BUILDING PHONE : (910) 481-0503  
 PARCEL . . : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

-----

**STRUCTURE: 000 000 52X51 3BDR**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW

-----

**PERMIT: CPSF 01 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
A814 01	6/11/07	TI	ADDRESS CONFIRMATION VRU #: 001423640
B111 01	6/11/07 6/11/07	MR DA	R*BLDG SLAB INSP VRU #: 001426790 1. req'd lug footings missing 2. fill needs to be compacted
B111 02	6/12/07	TI	R*BLDG SLAB INSP VRU #: 001427557

*AP-MW*

----- COMMENTS AND NOTES -----

ADDRESS . : 66 BOULDER DR  
 CONTRACTOR : CAVINESS & CATES BUILDING AND  
 OWNER . . : CAVINESS & CATES BUILDING  
 PARCEL . . : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
 PHONE : (910) 481-0503  
 PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
 FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
B111 01	6/11/07 6/11/07	MR DA	R*BLDG SLAB INSP VRU #: 001426790 1. req'd lug footings missing 2. fill needs to be compacted
A814 01	6/11/07 7/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001423640 66 BOULDER DR
B111 02	6/12/07 6/12/07	MR AP	R*BLDG SLAB INSP VRU #: 001427557
R425 01	7/24/07	TI	FOUR TRADE ROUGH IN VRU #: 001452163

*DA-MK*

COMMENTS AND NOTES

ADDRESS : 66 BOULDER DR  
 CONTRACTOR : CAVINESS & CATES BUILDING AND  
 OWNER : CAVINESS & CATES BUILDING  
 PARCEL : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
 PHONE : (910) 481-0503  
 PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
B111 01	6/11/07 6/11/07	MR DA	R*BLDG SLAB INSP VRU #: 001426790 1. req'd lug footings missing 2. fill needs to be compacted
A814 01	6/11/07 7/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001423640 66 BOULDER DR
B111 02	6/12/07 6/12/07	MR AP	R*BLDG SLAB INSP VRU #: 001427557
R425 01	7/24/07 7/24/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001452163 1. truss hgers not nailed to joists , several places 2. fireblock above fireplace at gas line 3. rodent proof under tub, showers 4. nail guards missing on plmb 5. fireblock at double wall by shower 6. install smike detector in upstairs bedroom 7. install bath vent in upstairs bathroom 8. trusses C-2 and B-2 are not strapped for uplift
R425 02	7/27/07 7-27	TI AP	FOUR TRADE ROUGH IN VRU #: 001455801

COMMENTS AND NOTES



ADDRESS . : 66 BOULDER DR  
 CONTRACTOR : CAVINESS & CATES BUILDING AND  
 OWNER . . : CAVINESS & CATES BUILDING  
 PARCEL . . : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
 PHONE : (910) 481-0503  
 PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
 FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
B111 01	6/11/07 6/11/07	MR DA	R*BLDG SLAB INSP VRU #: 001426790 1. req'd lug footings missing 2. fill needs to be compacted
A814 01	6/11/07 7/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001423640 66 BOULDER DR
B111 02	6/12/07 6/12/07	MR AP	R*BLDG SLAB INSP VRU #: 001427557
R425 01	7/24/07 7/24/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001452163 1. truss hgers not nailed to joists , several places 2. fireblock above fireplace at gas line 3. rodent proof under tub, showers 4. nail guards missing on plmb 5. fireblock at double wall by shower 6. install smike detector in upstairs bedroom 7. install bath vent in upstairs bathroom 8. trusses C-2 and B-2 are not strapped for uplift
R425 02	7/27/07 <u>7/20/07</u>	TI AP <i>KS</i>	FOUR TRADE ROUGH IN VRU #: 001455801
I129 01	7/30/07 <u>7/30/07</u>	TI AP <i>DT</i>	R*INSULATION INSPECTION VRU #: 001456203

COMMENTS AND NOTES

ADDRESS : 66 BOULDER DR  
 CONTRACTOR : CAVINESS & CATES BUILDING AND  
 OWNER : CAVINESS & CATES BUILDING  
 PARCEL : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
 PHONE : (910) 481-0503  
 PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382
	5/25/07	DA	1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
	5/29/07	AP	
B103 01	6/01/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
	6/01/07	AP	
P309 01	6/08/07	MR	R*PLUMB UNDER SLAB VRU #: 001425727
	6/08/07	AP	
B111 01	6/11/07	MR	R*BLDG SLAB INSP VRU #: 001426790
	6/11/07	DA	1. req'd lug footings missing 2. fill needs to be compacted
A814 01	6/11/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001423640
	7/03/07	AP	66 BOULDER DR
B111 02	6/12/07	MR	R*BLDG SLAB INSP VRU #: 001427557
	6/12/07	AP	
R425 01	7/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001452163
	7/24/07	DA	1. truss hgers not nailed to joists , several places 2. fireblock above fireplace at gas line 3. rodent proof under tub, showers 4. nail guards missing on plmb 5. fireblock at double wall by shower 6. install smike detector in upstairs bedroom 7. install bath vent in upstairs bathroom 8. trusses C-2 and B-2 are not strapped for uplift
R425 02	7/27/07	KS	FOUR TRADE ROUGH IN VRU #: 001455801
	7/27/07	AP	
I129 01	7/30/07	DT	R*INSULATION INSPECTION VRU #: 001456203
	7/30/07	AP	
H824 01	10/02/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001498013
	10/02/07	AP	
R429 01	12/03/07	TI	FOUR TRADE FINAL VRU #: 001528724

12/3/07 DA DA

COMMENTS AND NOTES

ADDRESS : 66 BOULDER DR  
 CONTRACTOR : CAVINESS & CATES BUILDING AND  
 OWNER : CAVINESS & CATES BUILDING  
 PARCEL : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
 PHONE : (910) 481-0503  
 PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
B111 01	6/11/07 6/11/07	MR DA	R*BLDG SLAB INSP VRU #: 001426790 1. req'd lug footings missing 2. fill needs to be compacted
A814 01	6/11/07 7/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001423640 ✓66 BOULDER DR
B111 02	6/12/07 6/12/07	MR AP	R*BLDG SLAB INSP VRU #: 001427557
R425 01	7/24/07 7/24/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001452163 1. truss hgers not nailed to joists , several places 2. fireblock above fireplace at gas line 3. rodent proof under tub, showers 4. nail guards missing on plmb 5. fireblock at double wall by shower 6. install smike detector in upstairs bedroom 7. install bath vent in upstairs bathroom 8. trusses C-2 and B-2 are not strapped for uplift
R425 02	7/27/07 7/27/07	KS AP	FOUR TRADE ROUGH IN VRU #: 001455801
I129 01	7/30/07 7/30/07	DT AP	R*INSULATION INSPECTION VRU #: 001456203
H824 01	10/02/07 10/02/07	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001498013
R429 01	12/03/07 12/03/07	DT DA	FOUR TRADE FINAL VRU #: 001528724 1. Wiring for stove not installed. 2. Outside air handler not wired. 3. Spare downstairs bath exhaust fan does not terminate to outside air.
R429 02	12/05/07	TI <del>AP</del> DA-IVR	FOUR TRADE FINAL VRU #: 001529668

COMMENTS AND NOTES

cap = cu vent

ADDRESS : 66 BOULDER DR  
 CONTRACTOR : CAVINESS & CATES BUILDING AND  
 OWNER : CAVINESS & CATES BUILDING  
 PARCEL : 03-9587-13- -0020- -24-  
 APPL NUMBER: 07-50017284 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 TOWARDS WESTERN HHS TAKE LEFT  
 ON BUFFALO LAKE RD APPROX 2 MILES TURN  
 LEFT IN ALPINE DR TURN LEFT @ 3RD ST  
 TIMBERLINE DR INTO S/D LOT 104 JB

SUBDIV: THE SUMMIT SEC3 50 LOTS  
 PHONE : (910) 481-0503  
 PHONE : (910) 481-0503

STRUCTURE: 000 000 52X51 3BDR  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/25/07 5/25/07	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001416382 1. clean out footers where they are caved in and make sure they are compacted and 8" deep
B101 02	5/29/07 5/29/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001417468
B103 01	6/01/07 6/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001420386
P309 01	6/08/07 6/08/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001425727
B111 01	6/11/07 6/11/07	MR DA	R*BLDG SLAB INSP VRU #: 001426790 1. req'd lug footings missing 2. fill needs to be compacted
A814 01	6/11/07 7/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001423640 ✓66 BOULDER DR
B111 02	6/12/07 6/12/07	MR AP	R*BLDG SLAB INSP VRU #: 001427557
R425 01	7/24/07 7/24/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001452163 1. truss hgers not nailed to joists , several places 2. fireblock above fireplace at gas line 3. rodent proof under tub, showers 4. nail guards missing on plmb 5. fireblock at double wall by shower 6. install smike detector in upstairs bedroom 7. install bath vent in upstairs bathroom 8. trusses C-2 and B-2 are not strapped for uplift
R425 02	7/27/07 7/27/07	KS AP	FOUR TRADE ROUGH IN VRU #: 001455801
I129 01	7/30/07 7/30/07	DT AP	R*INSULATION INSPECTION VRU #: 001456203
H824 01	10/02/07 10/02/07	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001498013
R429 01	12/03/07 12/03/07	DT DA	FOUR TRADE FINAL VRU #: 001528724 1. Wiring for stove not installed. 2. Outside air handler not wired. 3. Spare downstairs bath exhaust fan does not terminate to outside air.
R429 02	12/05/07 12/05/07	MR DA	FOUR TRADE FINAL VRU #: 001529668 caps are on roof vents
R429 03	12/07/07	TI	FOUR TRADE FINAL VRU #: 001531863

*AP-148*

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3  
Type of Construction: V  
Owner of Building: Govness & Cates  
Building Address: 66 Boulder Dr.  
Zoning District: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_

Conditional Use Permit No.: \_\_\_\_\_  
Building Permit No.: 07-50017284  
Electrical Permit No.: 11  
Insulation Permit No.: 11  
Plumbing Permit No.: 11  
Mech. Permit No.: 11  
Envir. C.O. No.: \_\_\_\_\_

Date: 12-1-7  
Mike Beanie  
Building Official

\_\_\_\_\_  
Zoning Official