

ADDRESS : 176 CURRAGH CV
CONTRACTOR : STRONG BUILT HOMES OF NC, INC.
OWNER : STRONG BUILT HOMES #19
PARCEL : 08-0655- - -0067- -20-
APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
LOT 19 JB

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 662-2624
PHONE : (919) 662-2624

STRUCTURE: 000 000 65X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07 <u>6-7-07</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613

COMMENTS AND NOTES

Nelson
427 6952

ADDRESS . : 176 CURRAGH CV
CONTRACTOR : STRONG BUILT HOMES OF NC, INC.
OWNER . . : STRONG BUILT HOMES #19
PARCEL . . : 08-0655- - -0067- -20-
APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
LOT 19 JB

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 662-2624
PHONE : (919) 662-2624

STRUCTURE: 000 000 65X50 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07 6/07/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
B103 01	6/27/07 <u>6/27/07</u>	TI <u>APP</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817 plans in inspection box

----- COMMENTS AND NOTES -----

ADDRESS : 176 CURRAGH CV
CONTRACTOR : STRONG BUILT HOMES OF NC, INC.
OWNER : STRONG BUILT HOMES #19
PARCEL : 08-0655- - -0067- -20-
APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
LOT 19 JB

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 662-2624
PHONE : (919) 662-2624

STRUCTURE: 000 000 65X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07 6/07/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
B103 01	6/27/07 6/27/07	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817 plans in inspection box
B105 01	6/29/07 <u>6/29/07</u>	TI <u>APBS</u>	R*OPEN FLOOR VRU #: 001438449

COMMENTS AND NOTES

ADDRESS . : 176 CURRAGH CV SUBDIV: MAGNOLIA CREST 29LOTS
CONTRACTOR : STRONG BUILT HOMES OF NC, INC. PHONE : (919) 662-2624
OWNER . . : STRONG BUILT HOMES #19 PHONE : (919) 662-2624
PARCEL . . : 08-0655- - -0067- -20-
APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
LOT 19 JB

STRUCTURE: 000 000 65X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07 6/07/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
B103 01	6/27/07 6/27/07	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817 plans in inspection box
B105 01	6/29/07 6/29/07	BS AP	R*OPEN FLOOR VRU #: 001438449
R425 01	7/30/07 <u>7-30-07</u>	TX <u>DAB</u>	FOUR TRADE ROUGH IN VRU #: 001455419 call Michael with concerns at 427-5714

----- COMMENTS AND NOTES -----

ADDRESS . : 176 CURRAGH CV
 CONTRACTOR : STRONG BUILT HOMES OF NC, INC.
 OWNER . . : STRONG BUILT HOMES #19
 PARCEL . . : 08-0655- - -0067- -20-
 APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
 RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
 LOT 19 JB

SUBDIV: MAGNOLIA CREST 29LOTS
 PHONE : (919) 662-2624
 PHONE : (919) 662-2624

STRUCTURE: 000 000 65X50 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07 6/07/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
B103 01	6/27/07 6/27/07	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817 plans in inspection box
B105 01	6/29/07 6/29/07	BS AP	R*OPEN FLOOR VRU #: 001438449
R425 01	7/30/07 7/30/07	BS DA	FOUR TRADE ROUGH IN VRU #: 001455419 call Michael with concerns at 427-5714 1. Fireblock balloon framed wall at ceiling height above fireplace. 2. Need tempered window at rear door 3. Hurricane ties at rear porch not complete. ok to side/insulate
A814 01	8/14/07	TI	ADDRESS CONFIRMATION VRU #: 001466234
I129 01	8/14/07 8/13/07	TI CA	R*INSULATION INSPECTION VRU #: 001466242
R425 02	8/14/07 <u>8-14-07</u>	TI <u>APR</u>	FOUR TRADE ROUGH IN VRU #: 001466259

COMMENTS AND NOTES

ADDRESS : 176 CURRAGH CV SUBDIV: MAGNOLIA CREST 29LOTS
 CONTRACTOR : STRONG BUILT HOMES OF NC, INC. PHONE : (919) 662-2624
 OWNER : STRONG BUILT HOMES #19 PHONE : (919) 662-2624
 PARCEL : 08-0655- - -0067- -20-
 APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
 RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
 LOT 19 JB

STRUCTURE: 000 000 65X50 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
	6/07/07	AP	
B103 01	6/27/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817
	6/27/07	AP	plans in inspection box
B105 01	6/29/07	BS	R*OPEN FLOOR VRU #: 001438449
	6/29/07	AP	
R425 01	7/30/07	BS	FOUR TRADE ROUGH IN VRU #: 001455419
	7/30/07	DA	call Michael with concerns at 427-5714 1. Fireblock balloon framed wall at ceiling height above fireplace. 2. Need tempered window at rear door 3. Hurricaneties at rear porch not complete. ok to side/insulate
I129 01	8/14/07	TI	R*INSULATION INSPECTION VRU #: 001466242
	8/13/07	CA	
R425 02	8/14/07	BS	FOUR TRADE ROUGH IN VRU #: 001466259
	8/14/07	AP	
A814 01	8/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001466234
	8/15/07	AP	176 CURRAGH CV LOT 19
I129 02	8/16/07	TI	R*INSULATION INSPECTION VRU #: 001468008
	<u>8-16-07</u>	<u>APBS</u>	Michael @ 427-5714 with concerns. Thanks.

----- COMMENTS AND NOTES -----

ADDRESS : 176 CURRAGH CV SUBDIV: MAGNOLIA CREST 29LOTS
 CONTRACTOR : STRONG BUILT HOMES OF NC, INC. PHONE : (919) 662-2624
 OWNER : STRONG BUILT HOMES #19 PHONE : (919) 662-2624
 PARCEL : 08-0655- - -0067- -20-
 APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
 RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
 LOT 19 JB

STRUCTURE: 000 000 65X50 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
	6/07/07	AP	
B103 01	6/27/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817
	6/27/07	AP	plans in inspection box
B105 01	6/29/07	BS	R*OPEN FLOOR VRU #: 001438449
	6/29/07	AP	
R425 01	7/30/07	BS	FOUR TRADE ROUGH IN VRU #: 001455419
	7/30/07	DA	call Michael with concerns at 427-5714 1. Fireblock balloon framed wall at ceiling height above fireplace. 2. Need tempered window at rear door 3. Hurricaneties at rear porch not complete. ok to side/insulate
I129 01	8/14/07	TI	R*INSULATION INSPECTION VRU #: 001466242
	8/13/07	CA	
R425 02	8/14/07	BS	FOUR TRADE ROUGH IN VRU #: 001466259
	8/14/07	AP	
A814 01	8/14/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001466234
	8/15/07	AP	176 CURRAGH CV LOT 19
I129 02	8/16/07	BS	R*INSULATION INSPECTION VRU #: 001468008
	8/16/07	AP	Michael @ 427-5714 with concerns. Thanks.
H824 01	8/28/07	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001553692
	1/28/08	AP	
R431 01	1/28/08	TI	FOUR TRADE FINAL >2500 VRU #: 001549906
	1/25/08	CA	call Michael 427-5714 with questions thxs CANCELLED FINAL FOR 01/28/08. NO OPERATIONS PERMIT. NJT
R431 02	1/29/08	TI	FOUR TRADE FINAL >2500 VRU #: 001553957
		AP	Call Mike @ 427-5714 with questions.

DA-MR

COMMENTS AND NOTES

ADDRESS : 176 CURRAGH CV
CONTRACTOR : STRONG BUILT HOMES OF NC, INC.
OWNER : STRONG BUILT HOMES #19
PARCEL : 08-0655- - -0067- -20-
APPL NUMBER: 07-50017307 CP NEW RESIDENTIAL (SFD)

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 662-2624
PHONE : (919) 662-2624

DIRECTIONS : 401 N PAST RAWLS CHURCH RD LEFT ON
RAWLS CLUB RD INTO S/D 5TH LOT ON RIGHT
LOT 19 JB

STRUCTURE: 000 000 65X50 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

31594735

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/07/07 6/07/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001424613
B103 01	6/27/07 6/27/07	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001435817 plans in inspection box
B105 01	6/29/07 6/29/07	BS AP	R*OPEN FLOOR VRU #: 001438449
R425 01	7/30/07 7/30/07	BS DA	FOUR TRADE ROUGH IN VRU #: 001455419 call Michael with concerns at 427-5714 1. Fireblock balloon framed wall at ceiling height above fireplace. 2. Need tempered window at rear door 3. Hurricane ties at rear porch not complete. ok to side/insulate
I129 01	8/14/07 8/13/07	TI CA	R*INSULATION INSPECTION VRU #: 001466242
R425 02	8/14/07 8/14/07	BS AP	FOUR TRADE ROUGH IN VRU #: 001466259
A814 01	8/14/07 8/15/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001466234 ✓176 CURRAGH CV LOT 19
I129 02	8/16/07 8/16/07	BS AP	R*INSULATION INSPECTION VRU #: 001468008 Michael @ 427-5714 with concerns. Thanks.
H824 01	8/28/07 1/28/08	JM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001553692
R431 01	1/28/08 1/25/08	TI CA	FOUR TRADE FINAL >2500 VRU #: 001549906 call Michael 427-5714 with questions thxs CANCELLED FINAL FOR 01/28/08. NO OPERATIONS PERMIT. NJT
R431 02	1/29/08 1/29/08	MR DA	FOUR TRADE FINAL >2500 VRU #: 001553957 Call Mike @ 427-5714 with questions. 1. install secondary drain on AHU under house 2. install handrail on stairs -small section 3. run relief line to floor in garage 4. install numbers
R431 03	2/05/08 <u>2-58</u>	TI <u>AOB</u>	FOUR TRADE FINAL >2500 VRU #: 001557784 Phone Mike @427-5714 with concerns.

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SD
Type of Construction: IV
Owner of Building: Strong Built Homes
Building Address: 176 Burgess Ct
Zoning District: N/A
Zoning Permit No.: _____
Date: 2-5-18

Bud Sitt
Building Official

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: 015
Mech. Permit No.: _____
Envir. C.O. No.: _____

Zoning Official