

-----

ADDRESS . : 406 STRIKE EAGLE DR SUBDIV: PATTONS POINT  
 CONTRACTOR : D WALSH CONSTRUCTION LLC PHONE : (919) 542-4506  
 OWNER . . : D WALSH CONSTRUCTION PHONE : (919) 291-2087  
 PARCEL . . : 03-9597- - -0039- -81-  
 APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)

-----

DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
 TINGEN RD GO APPROX 1.3/10 MILES TURN  
 LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
 POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
 ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
 CALIBER DR LOT 87 JB

-----

**STRUCTURE: 000 000 44X39 3BDR**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338
	8/23/10	CA	T/S: 08/23/2010 08:39 AM JBROCK CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536
	<u>8-24-10</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 406 STRIKE EAGLE DR  
CONTRACTOR : D WALSH CONSTRUCTION LLC  
OWNER : D WALSH CONSTRUCTION  
PARCEL : 03-9597- - -0039- -81-  
APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)  
-----

SUBDIV: PATTONS POINT  
PHONE : (919) 542-4506  
PHONE : (919) 291-2087

-----  
DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
TINGEN RD GO APPROX 1.3/10 MILES TURN  
LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
CALIBER DR LOT 87 JB  
-----

-----  
**STRUCTURE: 000 000 44X39 3BDR**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00  
SEPTIC - EXISTING? . . . . : NEW  
PROPOSED USE . . . . . : SFD  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10 8/23/10	MR CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338 T/S: 08/23/2010 08:39 AM JBROCK ----- CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10 8/24/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536 T/S: 08/24/2010 12:53 PM MREARIC -----
B103 01	8/27/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001975544 -----

*8-27-10 AP.MR*

-----  
COMMENTS AND NOTES  
-----

-----

ADDRESS . . : 406 STRIKE EAGLE DR SUBDIV: PATTONS POINT  
 CONTRACTOR : D WALSH CONSTRUCTION LLC PHONE : (919) 542-4506  
 OWNER . . . : D WALSH CONSTRUCTION PHONE : (919) 291-2087  
 PARCEL . . . : 03-9597- - -0039- -81-  
 APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
 TINGEN RD GO APPROX 1.3/10 MILES TURN  
 LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
 POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
 ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
 CALIBER DR LOT 87 JB

-----

**STRUCTURE: 000 000 44X39 3BDR**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338
	8/23/10	CA	T/S: 08/23/2010 08:39 AM JBROCK ----- CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536
	8/24/10	AP	T/S: 08/24/2010 12:53 PM MREARIC -----
B103 01	8/27/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001975544
	8/27/10	AP	T/S: 08/27/2010 11:55 AM MREARIC -----
B105 01	8/31/10	TI	R*OPEN FLOOR VRU #: 001976286

*8-31-10 AP-nR*

----- COMMENTS AND NOTES -----

ADDRESS : 406 STRIKE EAGLE DR  
CONTRACTOR : D WALSH CONSTRUCTION LLC  
OWNER : D WALSH CONSTRUCTION  
PARCEL : 03-9597- - -0039- -81-  
APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
TINGEN RD GO APPROX 1.3/10 MILES TURN  
LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
CALIBER DR LOT 87 JB

STRUCTURE: 000 000 44X39 3BDR  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10 8/23/10	MR CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338 T/S: 08/23/2010 08:39 AM JBROCK CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10 8/24/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536 T/S: 08/24/2010 12:53 PM MREARIC
B103 01	8/27/10 8/27/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001975544 T/S: 08/27/2010 11:55 AM MREARIC
B105 01	8/31/10 8/31/10	MR AP	R*OPEN FLOOR VRU #: 001976286 T/S: 08/31/2010 12:21 PM MREARIC
A814 01	9/03/10 8/31/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001976295 T/S: 08/31/2010 04:11 PM TWARD 406 strike eagle dr lot 87 broadway 27505 T/S: 08/31/2010 04:11 PM TWARD
R425 01	9/24/10 <u>9/24/10</u>	TI <u>DPB</u>	FOUR TRADE ROUGH IN VRU #: 001986220 VOICE MESSAGE LEFT

COMMENTS AND NOTES

ADDRESS : 406 STRIKE EAGLE DR  
 CONTRACTOR : D WALSH CONSTRUCTION LLC  
 OWNER : D WALSH CONSTRUCTION  
 PARCEL : 03-9597- - -0039- -81-  
 APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT  
 PHONE : (919) 542-4506  
 PHONE : (919) 291-2087

DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
 TINGEN RD GO APPROX 1.3/10 MILES TURN  
 LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
 POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
 ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
 CALIBER DR LOT 87 JB

STRUCTURE: 000 000 44X39 3BDR  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00  
 SEPTIC - EXISTING? : NEW  
 PROPOSED USE : SFD

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10 8/23/10	MR CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338 T/S: 08/23/2010 08:39 AM JBROCK CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10 8/24/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536 T/S: 08/24/2010 12:53 PM MREARIC
B103 01	8/27/10 8/27/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001975544 T/S: 08/27/2010 11:55 AM MREARIC
B105 01	8/31/10 8/31/10	MR AP	R*OPEN FLOOR VRU #: 001976286 T/S: 08/31/2010 12:21 PM MREARIC
A814 01	9/03/10 8/31/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001976295 T/S: 08/31/2010 04:11 PM TWARD 406 strike eagle dr lot 87 broadway 27505 T/S: 08/31/2010 04:11 PM TWARD
R425 01	9/24/10 9/24/10	BS DP	FOUR TRADE ROUGH IN VRU #: 001986220 VOICE MESSAGE LEFT 1. Strap top plates in garage at elevation changes where top plates are not continuous. 2. First 2 trusses checked were not braced. Go through this house and install all truss bracing. Inspection stopped. DO NOT SIDE/INSULATE \$50. re fee
R425 02	9/28/10 9/28/10	TI CA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001987304 T/S: 09/27/2010 10:24 AM VBROWN T/S: 09/28/2010 08:16 AM NTART
R425 03	9/30/10 <u>9-30-10</u>	TI <u>AP MR</u>	FOUR TRADE ROUGH IN VRU #: 001987924

COMMENTS AND NOTES

ADDRESS : 406 STRIKE EAGLE DR  
 CONTRACTOR : D WALSH CONSTRUCTION LLC  
 OWNER : D WALSH CONSTRUCTION  
 PARCEL : 03-9597- - -0039- -81-  
 APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT  
 PHONE : (919) 542-4506  
 PHONE : (919) 291-2087

DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
 TINGEN RD GO APPROX 1.3/10 MILES TURN  
 LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
 POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
 ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
 CALIBER DR LOT 87 JB

STRUCTURE: 000 000 44X39 3BDR  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10 8/23/10	MR CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338 T/S: 08/23/2010 08:39 AM JBROCK CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10 8/24/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536 T/S: 08/24/2010 12:53 PM MREARIC
B103 01	8/27/10 8/27/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001975544 T/S: 08/27/2010 11:55 AM MREARIC
B105 01	8/31/10 8/31/10	MR AP	R*OPEN FLOOR VRU #: 001976286 T/S: 08/31/2010 12:21 PM MREARIC
A814 01	9/03/10 8/31/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001976295 T/S: 08/31/2010 04:11 PM TWARD 406 strike eagle dr lot 87 broadway 27505 T/S: 08/31/2010 04:11 PM TWARD
R425 01	9/24/10 9/24/10	BS DP	FOUR TRADE ROUGH IN VRU #: 001986220 VOICE MESSAGE LEFT 1. Strap top plates in garage at elevation changes where top plates are not continuous. 2. First 2 trusses checked were not braced. Go through this house and install all truss bracing. Inspection stopped. DO NOT SIDE/INSULATE \$50. re fee
R425 02	9/28/10 9/28/10	TI CA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001987304 T/S: 09/27/2010 10:24 AM VBROWN T/S: 09/28/2010 08:16 AM NTART
R425 03	9/30/10 9/30/10	MR AP	FOUR TRADE ROUGH IN VRU #: 001987924 T/S: 09/30/2010 10:48 AM MREARIC
I129 01	10/01/10	TI	R*INSULATION INSPECTION VRU #: 001988683

*10-1-10 AP-MR*

COMMENTS AND NOTES

-----  
 ADDRESS . . : 406 STRIKE EAGLE DR  
 CONTRACTOR : D WALSH CONSTRUCTION LLC  
 OWNER . . . : D WALSH CONSTRUCTION  
 PARCEL . . . : 03-9597- - -0039- -81-  
 APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)  
 SUBDIV: PATTONS POINT  
 PHONE : (919) 542-4506  
 PHONE : (919) 291-2087  
 -----

DIRECTIONS : TAKE 27 W APPROX 13 MILES TURN LEFT ON  
 TINGEN RD GO APPROX 1.3/10 MILES TURN  
 LEFT ONTO STRIKE EAGLE THIS IS PATTONS  
 POINT WE HAVE 8 LOTS IN THE CUL-DE-SAC  
 ON STRIKE EAGLE AND 2 LOTS ON FIFTY  
 CALIBER DR LOT 87 JB  
 -----

STRUCTURE: 000 000 44X39 3BDR  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3.00  
 SEPTIC - EXISTING? . . . . : NEW  
 PROPOSED USE . . . . . : SFD  
 -----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/10 8/23/10	MR CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973338 T/S: 08/23/2010 08:39 AM JBROCK CANCELED PER MIKE HAVING CUSTOMER CALL INTO OFFICE
B101 02	8/24/10 8/24/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001973536 T/S: 08/24/2010 12:53 PM MREARIC
B103 01	8/27/10 8/27/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001975544 T/S: 08/27/2010 11:55 AM MREARIC
B105 01	8/31/10 8/31/10	MR AP	R*OPEN FLOOR VRU #: 001976286 T/S: 08/31/2010 12:21 PM MREARIC
A814 01	9/03/10 8/31/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001976295 T/S: 08/31/2010 04:11 PM TWARD ✓406 strike eagle dr lot 87 broadway 27505 T/S: 08/31/2010 04:11 PM TWARD
R425 01	9/24/10 9/24/10	BS DP	FOUR TRADE ROUGH IN VRU #: 001986220 VOICE MESSAGE LEFT 1. Strap top plates in garage at elevation changes where top plates are not continuous. 2. First 2 trusses checked were not braced. Go through this house and install all truss bracing. Inspection stopped. DO NOT SIDE/INSULATE \$50. re fee
R425 02	9/28/10 9/28/10	TI CA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001987304 T/S: 09/27/2010 10:24 AM VBROWN T/S: 09/28/2010 08:16 AM NTART
R425 03	9/30/10 9/30/10	MR AP	FOUR TRADE ROUGH IN VRU #: 001987924 T/S: 09/30/2010 10:48 AM MREARIC
I129 01	10/01/10 10/01/10	MR AP	R*INSULATION INSPECTION VRU #: 001988683 T/S: 10/01/2010 10:46 AM MREARIC
H824 01	10/11/10 10/11/10	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001993120 T/S: 10/12/2010 09:24 AM SZIMMER T/S: 10/12/2010 09:25 AM SZIMMER
R429 01	11/30/10 11/30/10	MR CA	FOUR TRADE FINAL VRU #: 002012391 T/S: 11/30/2010 11:32 AM MREARIC
R429 02	12/07/10	TI	FOUR TRADE FINAL VRU #: 002015634

----- CONTINUED ONTO NEXT PAGE -----

PREPARED 12/06/10, 14:01:50  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 2  
DATE 12/07/10

-----  
ADDRESS . . : 406 STRIKE EAGLE DR  
CONTRACTOR : D WALSH CONSTRUCTION LLC  
OWNER . . . : D WALSH CONSTRUCTION  
PARCEL . . . : 03-9597- - -0039- -81-  
APPL NUMBER: 07-50017433 CP NEW RESIDENTIAL (SFD)  
-----

SUBDIV: PATTONS POINT  
PHONE : (919) 542-4506  
PHONE : (919) 291-2087

-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

-----

12-7-10 AP-MR

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: X Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3  
Name: D. Walsh Const.

Address: 406 Strike Eagle

Date: 12-7-10

Building Official: T. Marshall Keane

**Permit Numbers**

Building: 07-50017433

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: \_\_\_\_\_