

Improvement Permit

D Walsh Court

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Accent Home Builders

PROPERTY LOCATION: 113?

NEW REPAIR EXPANSION

SUBDIVISION: Ferguson Place Patton's Point LOT # 87

Type of Structure: SFD- 48x39 3BR

Site Improvements required prior to Construction Authorization Issuance:

Proposed Wastewater System Type: 25% Reduction System

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 50 feet

Permit valid for: Five years

Permit conditions: STUB OUT Plumbing shallow at ground level or higher where shown. maintain all set backs. Meet date No expiration

Keep water line & Power line 10' from septic & Repair Area

Authorized State Agent: Ju LORETTI

Date: 5-9-07 02-18-2010

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Accent Home Builders Court

PROPERTY LOCATION: 113?

Facility Type: SFD- 44x39 3BR New

SUBDIVISION: Ferguson Place Patton's Point LOT # 87

Basement? Yes No Basement Fixtures? Yes No

Expansion Repair

Type of Wastewater System** 25% Reduction System (Initial)

Wastewater Flow: 360 GPD

(See note below, if applicable) 290 LF of LCP (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Exact length of each trench 1x180 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size _____ gallons

Trenches shall be installed on contour at a

Soil Cover: 6 inches

Maximum Trench Depth of: 1824 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM

_____ inches below pipe

Conditions: _____

Aggregate Depth: _____ inches above pipe

_____ inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Ju LORETTI

Date: 5-9-07 02-18-2010

SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 5-9-2012 0218-2015

HTE# 07-50017433R

Permit # 23919

Harnett County Department of Public Health Site Sketch

Dan Walsh Const

ISSUED TO: Accent Home Builders

PROPERTY LOCATOR: 1139

SUBDIVISION Patton's Point

LOT # 87


Authorized State Agent:

J. L. WRENCH

Date: 5-9-07 02-11-2010

Lot 72

Lot 71



STUB OUT Plumbing
 shallow, at ground level
 or higher where shown
 MAINTAIN ALL set BACKS
 Install 1x180 of 25% Reduction
 SYSTEM AT 18' 24"
 Meet onsite.

Note Water Line & Power Line
 Must be 10' from any part of septic
 System or The Repair Area