
ADDRESS . . : 54 JACOB ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER . . : SCOTT LEE HOMES INC #18
PARCEL . . : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07 <i>6-26-07</i>	TI <i>ARB</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502

----- COMMENTS AND NOTES -----

ADDRESS . : 54 JACOB ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER . . : SCOTT LEE HOMES INC #18
PARCEL . . : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)
SUBDIV: JONATHAN RIDGE
PHONE : (919) 553-2085
PHONE : (919) 553-2085

DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502
	6/26/07	AP	
A814 02	7/10/07	TI	ADDRESS CONFIRMATION VRU #: 001442771
A814 01	7/10/07	TI	ADDRESS CONFIRMATION VRU #: 001442763
	7/09/07	CA	
B103 01	7/10/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001442789
	<u>7/10/07</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 54 JACOB ST SUBDIV: JONATHAN RIDGE
CONTRACTOR : SCOTT LEE HOMES INC PHONE : (919) 553-2085
OWNER . . : SCOTT LEE HOMES INC #18 PHONE : (919) 553-2085
PARCEL . . : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07 6/26/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502
A814 02	7/10/07	TI	ADDRESS CONFIRMATION VRU #: 001442771
A814 01	7/10/07 7/09/07	TI CA	ADDRESS CONFIRMATION VRU #: 001442763
B103 01	7/10/07 7/10/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001442789
B105 01	7/16/07	TI	R*OPEN FLOOR VRU #: 001446988

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . . : 54 JACOB ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER . . . : SCOTT LEE HOMES INC #18
PARCEL . . . : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

SUBDIV: JONATHAN RIDGE
PHONE : (919) 553-2085
PHONE : (919) 553-2085

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07 6/26/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502
A814 01	7/10/07 7/09/07	TI CA	ADDRESS CONFIRMATION VRU #: 001442763
B103 01	7/10/07 7/10/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001442789
A814 02	7/10/07 7/24/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001442771 54 Jacob St
B105 01	7/16/07 7/16/07	MR AP	R*OPEN FLOOR VRU #: 001446988
R427 01	8/16/07 8/16/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001468305 no plans at jobsite
R427 02	8/20/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001469998

8-20-07 JABS

----- COMMENTS AND NOTES -----

ADDRESS . : 54 JACOB ST SUBDIV: JONATHAN RIDGE
CONTRACTOR : SCOTT LEE HOMES INC PHONE : (919) 553-2085
OWNER . . : SCOTT LEE HOMES INC #18 PHONE : (919) 553-2085
PARCEL . . : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07 6/26/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502
A814 01	7/10/07 7/09/07	TI CA	ADDRESS CONFIRMATION VRU #: 001442763
B103 01	7/10/07 7/10/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001442789
A814 02	7/10/07 7/24/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001442771 54 Jacob St
B105 01	7/16/07 7/16/07	MR AP	R*OPEN FLOOR VRU #: 001446988
R427 01	8/16/07 8/16/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001468305 no plans at jobsite
R427 02	8/20/07 8/20/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001469998 1. Sheet inside garage wall 2. DWV test leaked down
I129 01	8/23/07 <u>8-23-07</u>	TI <u>APBS</u>	R*INSULATION INSPECTION VRU #: 001472885
R427 03	8/23/07 <u>8/23/07</u>	TI <u>J</u>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001472976

----- COMMENTS AND NOTES -----

ADDRESS : 54 JACOB ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER : SCOTT LEE HOMES INC #18
PARCEL : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

SUBDIV: JONATHAN RIDGE
PHONE : (919) 553-2085
PHONE : (919) 553-2085

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07 6/26/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502
A814 01	7/10/07 7/09/07	TI CA	ADDRESS CONFIRMATION VRU #: 001442763
B103 01	7/10/07 7/10/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001442789
A814 02	7/10/07 7/24/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001442771 ✓54 Jacob St
B105 01	7/16/07 7/16/07	MR AP	R*OPEN FLOOR VRU #: 001446988
R427 01	8/16/07 8/16/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001468305 no plans at jobsite
R427 02	8/20/07 8/20/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001469998 1. Sheet inside garage wall 2. DWV test leaked down
I129 01	8/23/07 8/23/07	BS AP	R*INSULATION INSPECTION VRU #: 001472885
R427 03	8/23/07 8/23/07	BS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001472976
H824 01	10/03/07 10/03/07	BM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001498682
R431 01	10/29/07 <u>10-29-07</u>	TI <u>DABS</u>	FOUR TRADE FINAL >2500 VRU #: 001511286

COMMENTS AND NOTES

Water on Panel, Broken Label, water cutoff washed in, Water Heater

ADDRESS : 54 JACOB ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER : SCOTT LEE HOMES INC #18
PARCEL : 05-0635- - -0103- -34-
APPL NUMBER: 07-50017497 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JONATHAN RIDGE #18 - 210 LEFT ON 55 TO
42 LEFT ONTO TRUELOVE RT ONTO ADRIAN ST
LEFT ONTO JACOB 3RD LOT ON RT. JD

SUBDIV: JONATHAN RIDGE
PHONE : (919) 553-2085
PHONE : (919) 553-2085

STRUCTURE: 000 000 49X48 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07 6/26/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435502
A814 01	7/10/07 7/09/07	TI CA	ADDRESS CONFIRMATION VRU #: 001442763
B103 01	7/10/07 7/10/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001442789
A814 02	7/10/07 7/24/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001442771 ✓54 Jacob St
B105 01	7/16/07 7/16/07	MR AP	R*OPEN FLOOR VRU #: 001446988
R427 01	8/16/07 8/16/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001468305 no plans at jobsite
R427 02	8/20/07 8/20/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001469998 1. Sheet inside garage wall 2. DWV test leaked down
I129 01	8/23/07 8/23/07	BS AP	R*INSULATION INSPECTION VRU #: 001472885
R427 03	8/23/07 8/23/07	BS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001472976
H824 01	10/03/07 10/03/07	BM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001498682
R431 01	10/29/07 10/29/07	BS DA	FOUR TRADE FINAL >2500 VRU #: 001511286 1. Wire in panel loose. 2. Bottom right breaker in panel not labelled. 3. Water service customer side at road washed in and inaccessible. 4. Water heater under house needs platform. 5. Secure service light under house. 6. Tie ductwork back away from light.
R431 02	10/30/07 <u>10-30-07</u>	TI <u>APBS</u>	FOUR TRADE FINAL >2500 VRU #: 001512029

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD
Type of Construction: 7
Owner of Building: Smalley Homes, Inc
Building Address: 54 Sycamore St.
Zoning District: 114
Zoning Permit No.: 10300
Date: 10/3/08

Building Official

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
Envir. C.O. No.: _____

Zoning Official