

ADDRESS . : 114 GRAHAMRIDGE LN
CONTRACTOR : CRABTREE, JASON
OWNER . . : ANDREWS DONALD R & MARGIE N #5
PARCEL . . : 04-0664- - -0038- -36-
APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
RAWLS CH RD RT IN S/D LEFT ON
GRAHAMRIDGE. JD

SUBDIV: WYNDHAM PLACE PH 2 13LOTS
PHONE : (919) 545-0376
PHONE : (919) 851-5474

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07 <i>6-27</i>	TI <i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742 <i>JCS</i>

COMMENTS AND NOTES

ADDRESS . : 114 GRAHAMRIDGE LN
CONTRACTOR : CRABTREE, JASON
OWNER . . : ANDREWS DONALD R & MARGIE N #5
PARCEL . . : 04-0664- - -0038- -36-
APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
RAWLS CH RD RT IN S/D LEFT ON
GRAHAMRIDGE. JD

SUBDIV: WYNDHAM PLACE PH 2 13LOTS
PHONE : (919) 545-0376
PHONE : (919) 851-5474

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07 6/27/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742
A814 01	7/06/07	TI	ADDRESS CONFIRMATION VRU #: 001441773
B103 01	7/06/07 <u>7-6-07</u>	TI <u>AEBS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441765

----- COMMENTS AND NOTES -----

ADDRESS . : 114 GRAHAMRIDGE LN
CONTRACTOR : CRABTREE, JASON
OWNER . . : ANDREWS DONALD R & MARGIE N #5
PARCEL . . : 04-0664- - -0038- -36-
APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
RAWLS CH RD RT IN S/D LEFT ON
GRAHAMRIDGE. JD

SUBDIV: WYNDHAM PLACE PH 2 13LOTS
PHONE : (919) 545-0376
PHONE : (919) 851-5474

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07 6/27/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742
A814 01	7/06/07 7/06/07	TI AP	ADDRESS CONFIRMATION VRU #: 001441773 114 GRAHAMRIDGE LN LOT 5
B103 01	7/06/07 7/05/07	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441765 Need engineering for front porch sawtooth to support B deck for slab. Must have engineering before rough in inspection, do not pour front porch.
E207 01	7/10/07 7/10/07	TI CA	R*ELEC TEMP SERVICE POLE VRU #: 001442581 BRAD SAID THAT HE HAD DONE THIS TSP ON 07/10/07. CANCELLED ON 07/10/07.
B105 01	<u>7/12/07</u> <u>7-12-07</u>	TI <u>APRS</u>	R*OPEN FLOOR VRU #: 001444342

----- COMMENTS AND NOTES -----

ADDRESS . : 114 GRAHAMRIDGE LN
CONTRACTOR : CRABTREE, JASON
OWNER . . : ANDREWS DONALD R & MARGIE N #5
PARCEL . . : 04-0664- - -0038- -36-
APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
RAWLS CH RD RT IN S/D LEFT ON
GRAHAMRIDGE. JD

SUBDIV: WYNDHAM PLACE PH 2 13LOTS
PHONE : (919) 545-0376
PHONE : (919) 851-5474

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07 6/27/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742
A814 01	7/06/07 7/06/07	TI AP	ADDRESS CONFIRMATION VRU #: 001441773 114 GRAHAMRIDGE LN LOT 5
B103 01	7/06/07 7/05/07	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441765 Need engineering for front porch sawtooth to support B deck for slab. Must have engineering before rough in inspection, do not pour front porch.
E207 01	7/10/07 7/10/07	TI CA	R*ELEC TEMP SERVICE POLE VRU #: 001442581 BRAD SAID THAT HE HAD DONE THIS TSP ON 07/10/07. CANCELLED ON 07/10/07.
B105 01	7/12/07 7/12/07	BS AP	R*OPEN FLOOR VRU #: 001444342
R427 01	8/09/07 <u>8/9/07</u>	TI <u>DA DT</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001462900

----- COMMENTS AND NOTES -----

ADDRESS : 114 GRAHAMRIDGE LN
 CONTRACTOR : CRABTREE, JASON
 OWNER : ANDREWS DONALD R & MARGIE N #5
 PARCEL : 04-0664- - -0038- -36-
 APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)

SUBDIV: WYNDHAM PLACE PH 2 13LOTS
 PHONE : (919) 545-0376
 PHONE : (919) 851-5474

DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
 RAWLS CH RD RT IN S/D LEFT ON
 GRAHAMRIDGE. JD

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07 6/27/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742
A814 01	7/06/07 7/06/07	TI AP	ADDRESS CONFIRMATION VRU #: 001441773 114 GRAHAMRIDGE LN LOT 5
B103 01	7/06/07 7/05/07	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441765 Need engineering for front porch sawtooth to support B deck for slab. Must have engineering before rough in inspection, do not pour front porch.
E207 01	7/10/07 7/10/07	TI CA	R*ELEC TEMP SERVICE POLE VRU #: 001442581 BRAD SAID THAT HE HAD DONE THIS TSP ON 07/10/07. CANCELLED ON 07/10/07.
B105 01	7/12/07 7/12/07	BS AP	R*OPEN FLOOR VRU #: 001444342
R427 01	8/09/07 8/09/07	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001462900 1. No gas pressure. 2. Fire caulk/rodent proof bathtub/shower and hole under stairs. 3. Downstairs bathroom exhaust fan that runs under house must terminate to outside by final. 4. Okay to side and insulate.
I129 01	8/15/07 8-15-07	TI CABS	R*INSULATION INSPECTION VRU #: 001466788
R427 02	8/15/07 J	TI J	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001467760

COMMENTS AND NOTES

ADDRESS : 114 GRAHAMRIDGE LN
 CONTRACTOR : CRABTREE, JASON
 OWNER : ANDREWS DONALD R & MARGIE N #5
 PARCEL : 04-0664- - -0038- -36-
 APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)

SUBDIV: WYNDHAM PLACE PH 2 13LOTS
 PHONE : (919) 545-0376
 PHONE : (919) 851-5474

DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
 RAWLS CH RD RT IN S/D LEFT ON
 GRAHAMRIDGE. JD

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742
	6/27/07	AP	
A814 01	7/06/07	TI	ADDRESS CONFIRMATION VRU #: 001441773
	7/06/07	AP	114 GRAHAMRIDGE LN LOT 5
B103 01	7/06/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441765
	7/05/07	AE	Need engineering for front porch sawtooth to support B deck for slab. Must have engineering before rough in inspection, do not pour front porch.
E207 01	7/10/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001442581
	7/10/07	CA	BRAD SAID THAT HE HAD DONE THIS TSP ON 07/10/07. CANCELLED ON 07/10/07.
B105 01	7/12/07	BS	R*OPEN FLOOR VRU #: 001444342
	7/12/07	AP	
R427 01	8/09/07	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001462900
	8/09/07	DA	1. No gas pressure. 2. Fire caulk/rodent proof bathtub/shower and hole under stairs. 3. Downstairs bathroom exhaust fan that runs under house must terminate to outside by final. 4. Okay to side and insulate.
I129 01	8/15/07	BS	R*INSULATION INSPECTION VRU #: 001466788
	8/15/07	CA	per michael shreives
R427 02	8/15/07	BS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001467760
	8/15/07	CA	
I129 02	8/20/07	TI	R*INSULATION INSPECTION VRU #: 001469972
	<u>8/20/07</u>	<u>APBS</u>	
R427 03	<u>8/20/07</u>	<u>TI</u>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001470269
	<u>8/20/07</u>	<u>APBS</u>	

COMMENTS AND NOTES

*Fire place out fo locatize; Test
Master Ball*

ADDRESS : 114 GRAHAMRIDGE LN SUBDIV: WYNDHAM PLACE PH 2 13LOTS
CONTRACTOR : CRABTREE, JASON PHONE : (919) 545-0376
OWNER : ANDREWS DONALD R & MARGIE N #5 PHONE : (919) 851-5474
PARCEL : 04-0664- - -0038- -36-
APPL NUMBER: 07-50017521 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WYNDHAM PLACE PH II #5 - 401N RT ON
RAWLS CH RD RT IN S/D LEFT ON
GRAHAMRIDGE. JD

STRUCTURE: 000 000 56X65 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/27/07 6/27/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435742
A814 01	7/06/07 7/06/07	TI AP	ADDRESS CONFIRMATION VRU #: 001441773 ✓114 GRAHAMRIDGE LN LOT 5
B103 01	7/06/07 7/05/07	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441765 Need engineering for front porch sawtooth to support B deck for slab. Must have engineering before rough in inspection, do not pour front porch.
E207 01	7/10/07 7/10/07	TI CA	R*ELEC TEMP SERVICE POLE VRU #: 001442581 BRAD SAID THAT HE HAD DONE THIS TSP ON 07/10/07. CANCELLED ON 07/10/07.
B105 01	7/12/07 7/12/07	BS AP	R*OPEN FLOOR VRU #: 001444342
R427 01	8/09/07 8/09/07	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001462900 1. No gas pressure. 2. Fire caulk/rodent proof bathtub/shower and hole under stairs. 3. Downstairs bathroom exhaust fan that runs under house must terminate to outside by final. 4. Okay to side and insulate.
I129 01	8/15/07 8/15/07	BS CA	R*INSULATION INSPECTION VRU #: 001466788 per michael shreives
R427 02	8/15/07 8/15/07	BS CA	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001467760
I129 02	8/20/07 8/20/07	BS AP	R*INSULATION INSPECTION VRU #: 001469972
R427 03	8/20/07 8/20/07	BS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001470269 move gas line for insert to a termination point other than the deck, leave gas test on for final inspection.
H824 01	8/29/07 8/29/07	BM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001477181
R431 01	10/29/07 <u>10/29/07</u>	TI <u>APR</u>	FOUR TRADE FINAL >2500 VRU #: 001511260

----- COMMENTS AND NOTES -----

COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>SFD</u>	Conditional Use Permit No.: _____
Type of Construction: <u>V</u>	Building Permit No.: _____
Owner of Building: <u>JASON CRABTREE</u>	Electrical Permit No.: _____
Building Address: <u>114 Cranberry Ridge Ln</u>	Insulation Permit No.: _____
Zoning District: <u>NA</u>	Plumbing Permit No.: <u>K-5</u>
Zoning Permit No.: _____	Mech. Permit No.: <u>D-5</u>
Date: <u>10-29-07</u>	Envir. C.O. No.: _____
<u>Bud Sizer</u>	
Building Official	Zoning Official