

PREPARED 6/10/08, 14:00:50
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 7
DATE 6/11/08

ADDRESS : 575 COKESBURY PARK LN SUBDIV: COKESBURY PARK
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : DUNCAN DEVELOPMENT LLC #50 PHONE :
PARCEL : 05-0635- - -0124- -12-
APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
RS TO COKESBURY S/D LOT 50 JB

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 <u>6-11-08</u>	TI <u>ADRS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289

----- COMMENTS AND NOTES -----

PREPARED 6/26/08, 14:01:29
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 6
DATE 6/27/08

ADDRESS : 575 COKESBURY PARK LN SUBDIV: COKESBURY PARK
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : DUNCAN DEVELOPMENT LLC #50 PHONE :
PARCEL : 05-0635- - -0124- -12-
APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
RS TO COKESBURY S/D LOT 50 JB

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289
A814 01	6/27/08	TI	ADDRESS CONFIRMATION VRU #: 001632991
B103 01	6/27/08 <u>6-27-08</u>	TI <u>APRS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633007

----- COMMENTS AND NOTES -----

704-510 4041 Willanna

ADDRESS : 575 COKESBURY PARK LN SUBDIV: COKESBURY PARK
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : DUNCAN DEVELOPMENT LLC #50 PHONE :
PARCEL : 05-0635- - -0124- -12-
APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
RS TO COKESBURY S/D LOT 50 JB

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289
A814 01	6/27/08 6/30/08	TI AP	ADDRESS CONFIRMATION VRU #: 001632991 575 COKESBURY PARK LN LOT 50
B103 01	6/27/08 6/27/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633007
B105 01	11/18/09 <u>11-18-09</u>	TI <u>APBS</u>	R*OPEN FLOOR TIME: 17:00 VRU #: 001851591 T/S: 11/17/2009 09:44 AM VBROWN

----- COMMENTS AND NOTES -----

Application number, type . . . : 07 50017562 CP NEW RESIDENTIAL (SFD)
Property address : 575 COKESBURY PARK LN

Type information, press Enter.

Joists at garage cantilever must be 12" OC. Will check at
rough in inspection

More...

F3=Exit F5=Copy F6=Insert F7=Delete F8=Time stamp
F12=Cancel F21=User defaults

ADDRESS . : 575 COKESBURY PARK LN SUBDIV: COKESBURY PARK
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER . . : DUNCAN DEVELOPMENT LLC #50 PHONE :
PARCEL . . : 05-0635- - -0124- -12-
APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
RS TO COKESBURY S/D LOT 50 JB

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289
A814 01	6/27/08 6/30/08	TI AP	ADDRESS CONFIRMATION VRU #: 001632991 575 COKESBURY PARK LN LOT 50
B103 01	6/27/08 6/27/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633007
B105 01	11/18/09 11/18/09	BS AE	R*OPEN FLOOR TIME: 17:00 VRU #: 001851591 T/S: 11/17/2009 09:44 AM VBROWN ----- Joists at garage cantilever must be 12" OC. Will check at rough in inspection
R425 01	1/07/10 <u>1-7-10</u>	TI <u>DAB</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868132 T/S: 01/06/2010 09:46 AM RDCONTE -----

----- COMMENTS AND NOTES -----

ADDRESS : 575 COKESBURY PARK LN SUBDIV: COKESBURY PARK
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : DUNCAN DEVELOPMENT LLC #50 PHONE :
PARCEL : 05-0635- - -0124- -12-
APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
RS TO COKESBURY S/D LOT 50 JB

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289
A814 01	6/27/08 6/30/08	TI AP	ADDRESS CONFIRMATION VRU #: 001632991 575 COKESBURY PARK LN LOT 50
B103 01	6/27/08 6/27/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633007
B105 01	11/18/09 11/18/09	BS AE	R*OPEN FLOOR TIME: 17:00 VRU #: 001851591 T/S: 11/17/2009 09:44 AM VBROWN ----- Joists at garage cantilever must be 12" OC. Will check at rough in inspection
R425 01	1/07/10 1/07/10	BS DP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868132 T/S: 01/06/2010 09:46 AM RDCONTE ----- 1. No plumbing under house, no tests, etc. 2. Install roof boots. Ok to side, DO NOT INSULATE. \$50 re fee
R425 02	1/08/10 <u>1-8-10</u>	TI <u>APBS</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868918 T/S: 01/07/2010 02:58 PM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS : 575 COKESBURY PARK LN SUBDIV: COKESBURY PARK
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER : DUNCAN DEVELOPMENT LLC #50 PHONE :
 PARCEL : 05-0635- - -0124- -12-
 APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
 RS TO COKESBURY S/D LOT 50 JB

STRUCTURE: 000 000 40X60 3BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289
	6/11/08	AP	
A814 01	6/27/08	TI	ADDRESS CONFIRMATION VRU #: 001632991
	6/30/08	AP	575 COKESBURY PARK LN LOT 50
B103 01	6/27/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633007
	6/27/08	AP	
B105 01	11/18/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001851591
	11/18/09	AE	T/S: 11/17/2009 09:44 AM VBROWN ----- Joists at garage cantilever must be 12" OC. Will check at rough in inspection
R425 01	1/07/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868132
	1/07/10	DP	T/S: 01/06/2010 09:46 AM RDCONTE ----- 1. No plumbing under house, no tests, etc. 2. Install roof boots. Ok to side, DO NOT INSULATE. \$50 re fee
			T/S: 01/07/2010 02:27 PM NTART -----
R425 02	1/08/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868918
	1/08/10	AP	T/S: 01/07/2010 02:58 PM NTART ----- T/S: January 08, 2010 01:15 PM BSUTTON -----
I129 01	1/14/10	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001870450
	<u>1.14.10</u>	<u>ADBS</u>	T/S: 01/13/2010 08:56 AM RDCONTE -----

COMMENTS AND NOTES

ADDRESS : 575 COKESBURY PARK LN
 CONTRACTOR : STANCIL BUILDERS INC.
 OWNER : DUNCAN DEVELOPMENT LLC #50
 PARCEL : 05-0635- - -0124- -12-
 APPL NUMBER: 07-50017562 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY
 RS TO COKESBURY S/D LOT 50 JB

SUBDIV: COKESBURY PARK
 PHONE : (919) 639-2073
 PHONE :

65203455

STRUCTURE: 000 000 40X60 3BDR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623289
A814 01	6/27/08 6/30/08	TI AP	ADDRESS CONFIRMATION VRU #: 001632991 <input checked="" type="checkbox"/> 575 COKESBURY PARK LN LOT 50
B103 01	6/27/08 6/27/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633007
B105 01	11/18/09 11/18/09	BS AE	R*OPEN FLOOR TIME: 17:00 VRU #: 001851591 T/S: 11/17/2009 09:44 AM VBROWN ----- Joists at garage cantilever must be 12" OC. Will check at rough in inspection
R425 01	1/07/10 1/07/10	BS DP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868132 T/S: 01/06/2010 09:46 AM RDCONTE ----- 1. No plumbing under house, no tests, etc. 2. Install roof boots. Ok to side, DO NOT INSULATE. \$50 re fee T/S: 01/07/2010 02:27 PM NTART -----
R425 02	1/08/10 1/08/10	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001868918 T/S: 01/07/2010 02:58 PM NTART ----- T/S: January 08, 2010 01:15 PM BSUTTON -----
I129 01	1/14/10 1/14/10	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001870450 T/S: 01/13/2010 08:56 AM RDCONTE ----- T/S: January 14, 2010 02:03 PM BSUTTON -----
H824 01	3/08/10 3/08/10	JM AP	<input checked="" type="checkbox"/> ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001893205 T/S: 03/10/2010 10:02 AM SSTEWARD ----- T/S: 03/10/2010 10:03 AM SSTEWARD -----
R429 01	3/11/10 <u>3-11-10</u>	TI <u>APBS</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 001893429 T/S: 03/10/2010 12:16 PM VBROWN -----

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Type of Construction: V

Owner of Building: Stancil Builders

Building Address: 575 Cokesbury Park

Zoning District: NA

Zoning Permit No.: NA

Date: 03-11-2010

Brad Sutton Brad Sutton

Building Official

Conditional Use Permit No.: _____

Building Permit No.: 07-50017562

Electrical Permit No.: 07-50017562

Insulation Permit No.: 07-50017562

Plumbing Permit No.: 07-50017562

Mech. Permit No.: 07-50017562

Envir. C.O. No.: 07-50017562

NA

Zoning Official