

-----  
ADDRESS : 605 COKESBURY PARK LN SUBDIV: COKESBURY PARK  
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073  
OWNER : DUNCAN DEVELOPMENT LLC #52 PHONE :  
PARCEL : 05-0635- - -0124- -14-  
APPL NUMBER: 07-50017564 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY  
RS TO COKESBURY S/D LOT 52 JB  
-----

STRUCTURE: 000 000 41.7X55 3BDR  
FLOOD ZONE : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 <u>6-11-08</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623305

-----  
COMMENTS AND NOTES  
-----

-----  
ADDRESS : 605 COKESBURY PARK LN SUBDIV: COKESBURY PARK  
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073  
OWNER : DUNCAN DEVELOPMENT LLC #52 PHONE :  
PARCEL : 05-0635- - -0124- -14-  
APPL NUMBER: 07-50017564 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY  
RS TO COKESBURY S/D LOT 52 JB  
-----

STRUCTURE: 000 000 41.7X55 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623305
A814 01	6/27/08	TI	ADDRESS CONFIRMATION VRU #: 001633056
B103 01	6/27/08 <u>6-27-08</u>	TI <u>APRS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633064

----- COMMENTS AND NOTES -----

ADDRESS : 605 COKESBURY PARK LN SUBDIV: COKESBURY PARK  
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073  
OWNER : DUNCAN DEVELOPMENT LLC #52 PHONE :  
PARCEL : 05-0635- - -0124- -14-  
APPL NUMBER: 07-50017564 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY  
RS TO COKESBURY S/D LOT 52 JB

STRUCTURE: 000 000 41.7X55 3BDR  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623305
A814 01	6/27/08 6/30/08	TI AP	ADDRESS CONFIRMATION VRU #: 001633056 605 COKESBURY PARK LN LOT 52
B103 01	6/27/08 6/27/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633064
B105 01	12/02/09 <i>12:2:09</i>	TI <i>AEBS</i>	R*OPEN FLOOR TIME: 17:00 VRU #: 001856392 T/S: 12/01/2009 08:38 AM RDCONTE -----

----- COMMENTS AND NOTES -----

Application number, type . . . : 07 50017564 CP NEW RESIDENTIAL (SFD)  
Property address . . . . . : 605 COKESBURY PARK LN

Type information, press Enter.

Nail ledgers where doubles are added. Will check at rough  
in  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

More...

F3=Exit    F5=Copy    F6=Insert    F7=Delete    F8=Time stamp  
F12=Cancel    F21=User defaults

-----  
ADDRESS : 605 COKESBURY PARK LN SUBDIV: COKESBURY PARK  
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073  
OWNER : DUNCAN DEVELOPMENT LLC #52 PHONE :  
PARCEL : 05-0635- - -0124- -14-  
APPL NUMBER: 07-50017564 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY  
RS TO COKESBURY S/D LOT 52 JB  
-----

STRUCTURE: 000 000 41.7X55 3BDR  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623305
	6/11/08	AP	
A814 01	6/27/08	TI	ADDRESS CONFIRMATION VRU #: 001633056
	6/30/08	AP	605 COKESBURY PARK LN LOT 52
B103 01	6/27/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633064
	6/27/08	AP	
B105 01	12/02/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001856392
	12/02/09	AE	T/S: 12/01/2009 08:38 AM RDCONTE ----- Nail ledgers where doubles are added. Will check at rough in
R425 01	1/14/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001869874
	<u>1.14.10</u>	<u>DAB</u>	T/S: 01/12/2010 11:10 AM RDCONTE -----

----- COMMENTS AND NOTES -----

ADDRESS : 605 COKESBURY PARK LN  
 CONTRACTOR : STANCIL BUILDERS INC.  
 OWNER : DUNCAN DEVELOPMENT LLC #52  
 PARCEL : 05-0635- - -0124- -14-  
 APPL NUMBER: 07-50017564 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY  
 RS TO COKESBURY S/D LOT 52 JB

SUBDIV: COKESBURY PARK  
 PHONE : (919) 639-2073  
 PHONE :

**STRUCTURE: 000 000 41.7X55 3BDR**

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08 6/11/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623305
A814 01	6/27/08 6/30/08	TI AP	ADDRESS CONFIRMATION VRU #: 001633056 605 COKESBURY PARK LN LOT 52
B103 01	6/27/08 6/27/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633064
B105 01	12/02/09 12/02/09	BS AE	R*OPEN FLOOR TIME: 17:00 VRU #: 001856392 T/S: 12/01/2009 08:38 AM RDCONTE ----- Nail ledgers where doubles are added. Will check at rough in
R425 01	1/14/10 1/14/10	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001869874 T/S: 01/12/2010 11:10 AM RDCONTE ----- 1. Add a stud and nail osb joint in gable window framing 2. Insulate plumbing trap in cantilever. 3. repair floor joist cut for plumbing.
I129 01	1/28/10 <u>1-28-10</u>	TI <u>APBS</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001876671 T/S: 01/27/2010 08:04 AM VBROWN -----
R425 02	1/28/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001876655 T/S: 01/27/2010 08:04 AM VBROWN -----

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Type of Construction: V

Owner of Building: Stancil Builders

Building Address: 605 Cokesbury Park

Zoning District: NA

Zoning Permit No.: NA

Date: 03-11-2010

Brad Sutton

Building Official

Conditional Use Permit No.: \_\_\_\_\_

Building Permit No.: 07-50017564

Electrical Permit No.: 07-50017564

Insulation Permit No.: 07-50017564

Plumbing Permit No.: 07-50017564

Mech. Permit No.: 07-50017564

Envir. C.O. No.: 07-50017564

NA

Zoning Official

ADDRESS : 605 COKESBURY PARK LN SUBDIV: COKESBURY PARK  
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073  
 OWNER : DUNCAN DEVELOPMENT LLC #52 PHONE :  
 PARCEL : 05-0635- - -0124- -14-  
 APPL NUMBER: 07-50017564 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 421 TO CHRISTIAN LIGHT RD TO COKESBURY  
 RS TO COKESBURY S/D LOT 52 JB

22329965

STRUCTURE: 000 000 41.7X55 3BDR  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/11/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001623305
	6/11/08	AP	
A814 01	6/27/08	TI	ADDRESS CONFIRMATION VRU #: 001633056
	6/30/08	AP	✓ 605 COKESBURY PARK LN LOT 52
B103 01	6/27/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001633064
	6/27/08	AP	
B105 01	12/02/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001856392
	12/02/09	AE	T/S: 12/01/2009 08:38 AM RDCONTE ----- Nail ledgers where doubles are added. Will check at rough in
R425 01	1/14/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001869874
	1/14/10	DA	T/S: 01/12/2010 11:10 AM RDCONTE ----- 1. Add a stud and nail osb joint in gable window framing 2. Insulate plumbing trap in cantilever. 3. repair floor joist cut for plumbing.
I129 01	1/28/10	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001876671
	1/28/10	AP	T/S: 01/27/2010 08:04 AM VBROWN ----- T/S: January 28, 2010 10:38 AM BSUTTON -----
R425 02	1/28/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001876655
	1/28/10	AP	T/S: 01/27/2010 08:04 AM VBROWN ----- T/S: January 28, 2010 10:38 AM BSUTTON -----
H824 01	3/09/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001893221
	3/09/10	AP	T/S: 03/10/2010 10:05 AM SSTEWARD ----- T/S: 03/10/2010 10:05 AM SSTEWARD -----
R429 01	3/11/10	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001893445
	<u>3-11-10</u>	<u>APB</u>	T/S: 03/10/2010 12:17 PM VBROWN -----

COMMENTS AND NOTES