

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: STANCI BIDDERS INC
NEW [X] REPAIR [] EXPANSION []
Type of Structure: EX SFD
Proposed Wastewater System Type: 25% Reduct
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [X] No
Pump Required: [X] Yes [] No [] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [X] Public [] Well Distance from well _____ feet
Permit conditions: _____

PROPERTY LOCATION: 51505 Selas Hayes RD
SUBDIVISION: Hunters Point LOT # 18
Site Improvements required prior to Construction Authorization Issuance: _____

Permit valid for: [X] Five years [] No expiration

Authorized State Agent: James E. Manhart Date: 3-28-17 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: STANCI BUILDERS INC
Facility Type: EX SFD [X] New [] Expansion [] Repair
Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No
Type of Wastewater System: Pump to 25% Reduct w/ (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable []) Pump to 25% Reduct w/ (Repair)

PROPERTY LOCATION: 51505 Selas Hayes RD
SUBDIVISION: Hunters Point LOT # 18

Installation Requirements/Conditions

Septic Tank Size 1000 gallons
Pump Tank Size 1000 gallons

Number of trenches _____
Exact length of each trench 240 feet
Trenches shall be installed on contour at a
Maximum Trench Depth of: 20-18 max inches
(Trench bottoms shall be level to +/-1/4"
in all directions)

Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
(Maximum soil cover shall not exceed
36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe
2 inches above pipe
12 inches total

Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manhart Date: 3-22-17
Construction Authorization Expiration Date: 3-28-22

HTE# 07-5-176572

Permit # 29195

Harnett County Department of Public Health Site Sketch

ISSUED TO: STANCO BIDCO TAX PROPERTY LOCATOR: 54565 Silas Hayes RD
SUBDIVISION: Hunter Point LOT # 18

Authorized State Agent: James E. Markon Date: 3-29-17

* Follow Consultants Layout

