

PREPARED 7/26/07, 14:01:00  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 29  
DATE 7/27/07

-----  
ADDRESS . . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : H & H CONSTRUCTORS INC #156  
PARCEL . . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB  
-----

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

-----  
STRUCTURE: 000 000 58X68 3BDR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 <u>7/27/07</u>	TI <u>DA DT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008

-----  
COMMENTS AND NOTES  
-----

ADDRESS . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . : H & H CONSTRUCTORS INC #156  
PARCEL . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

STRUCTURE: 000 000 58X68 3BDR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 <u>8/2/07</u>	TI <u>AP DT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826

----- COMMENTS AND NOTES -----

ADDRESS . . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : H & H CONSTRUCTORS INC #156  
PARCEL . . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

STRUCTURE: 000 000 58X68 3BDR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297

*Handwritten notes:*  
A  
~~DA TP~~  
DA TP

COMMENTS AND NOTES

*Handwritten notes:*  
AE - MR  
NO Survey

-----  
ADDRESS . . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : H & H CONSTRUCTORS INC #156  
PARCEL . . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB  
-----

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

-----  
STRUCTURE: 000 000 58X68 3BDR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07 8/07/07	MR AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297 different hoouse is now being built to fit lot... need plot plan...mr
B103 02	8/08/07 <u>8/8/07</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462713

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . : H & H CONSTRUCTORS INC #156  
PARCEL . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB  
-----

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

-----  
**STRUCTURE: 000 000 58X68 3BDR SFD**  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07 8/07/07	MR AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297 different hoouse is now being built to fit lot... need plot plan...mr
B103 02	8/08/07 8/08/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462713
P309 01	8/09/07	TI	R*PLUMB UNDER SLAB VRU #: 001463473

*AP-MR*

-----  
COMMENTS AND NOTES  
-----

-----  
ADDRESS . . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : H & H CONSTRUCTORS INC #156  
PARCEL . . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB  
-----

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

-----  
**STRUCTURE: 000 000 58X68 3BDR SFD**  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07 8/07/07	MR AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297 different hoouse is now being built to fit lot... need plot plan...mr
B103 02	8/08/07 8/08/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462713
P309 01	8/09/07 8/09/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001463473
B111 01	8/13/07 <u>8/13/07</u>	TI <u>AP DT</u>	R*BLDG SLAB INSP VRU #: 001464533

-----  
COMMENTS AND NOTES  
-----

ADDRESS . . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : H & H CONSTRUCTORS INC #156  
PARCEL . . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

STRUCTURE: 000 000 58X68 3BDR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07 8/07/07	MR AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297 different hoouse is now being built to fit lot... need plot plan...mr
B103 02	8/08/07 8/08/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462713
P309 01	8/09/07 8/09/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001463473
B111 01	8/13/07 8/13/07	DT AP	R*BLDG SLAB INSP VRU #: 001464533
A814 01	8/14/07 8/10/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001463482 111 Sonora Dr
R427 01	9/07/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001481852

*ARJH*

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 111 SONORA DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . : H & H CONSTRUCTORS INC #156  
PARCEL . . : 01-0536-04- -0028- -55-  
APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
WOODSHIRE DR LOT 156 JB  
-----

SUBDIV: WOODSHIRE  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

-----  
**STRUCTURE: 000 000 58X68 3BDR SFD**  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07 8/07/07	MR AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297 different hoouse is now being built to fit lot... need plot plan...mr
B103 02	8/08/07 8/08/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462713
P309 01	8/09/07 8/09/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001463473
B111 01	8/13/07 8/13/07	DT AP	R*BLDG SLAB INSP VRU #: 001464533
A814 01	8/14/07 8/10/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001463482 111 Sonora Dr
R427 01	9/07/07 9/07/07	JH AP	FOUR TRADE ROUGH IN >2500 VRU #: 001481852
I129 01	9/13/07 <u>9/13/07</u>	TI <u>AP DT</u>	R*INSULATION INSPECTION VRU #: 001485374

-----  
COMMENTS AND NOTES  
-----

ADDRESS . : 111 SONORA DR SUBDIV: WOODSHIRE  
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 OWNER . . : H & H CONSTRUCTORS INC #156 PHONE : (910) 486-4864  
 PARCEL . . : 01-0536-04- -0028- -55-  
 APPL NUMBER: 07-50017655 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
 NURSERY LEFT ON LEMUEL BLACK RD LEFT ON  
 WOODSHIRE DR LOT 156 JB

STRUCTURE: 000 000 58X68 3BDR SFD  
 FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455008 Footing dug 18 feet from existing house next store. Must have survey done to check 10 foot side setback.
B101 02	8/02/07 8/02/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001458826
B103 01	8/07/07 8/07/07	MR AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001461297 different hoouse is now being built to fit lot... need plot plan...mr
B103 02	8/08/07 8/08/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462713
P309 01	8/09/07 8/09/07	MR AP	R*PLUMB UNDER SLAB VRU #: 001463473
B111 01	8/13/07 8/13/07	DT AP	R*BLDG SLAB INSP VRU #: 001464533
A814 01	8/14/07 8/10/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001463482 ✓111 Sonora Dr
R427 01	9/07/07 9/07/07	JH AP	FOUR TRADE ROUGH IN >2500 VRU #: 001481852
I129 01	9/13/07 9/13/07	DT AP	R*INSULATION INSPECTION VRU #: 001485374
A814 02	9/25/07 9/24/07	TI CA	ADDRESS CONFIRMATION VRU #: 001489856 CANCELLED ADDRESS ALREADY SIGNED OFF.
H824 01	9/25/07 9/25/07	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001493329
R429 02	10/30/07	TI	FOUR TRADE FINAL VRU #: 001512011
R429 01	<u>10/30/07</u> 10/29/07	<u>AP DT</u> TI CA	FOUR TRADE FINAL VRU #: 001511997

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: \_\_\_\_\_  
Type of Construction: I Building Permit No.: \_\_\_\_\_  
Owner of Building: H+H Constructors Electrical Permit No.: \_\_\_\_\_  
Building Address: 111 Senora Dr. Insulation Permit No.: \_\_\_\_\_  
Zoning District: \_\_\_\_\_ Plumbing Permit No.: 07-50017655  
Zoning Permit No.: \_\_\_\_\_ Mech. Permit No.: \_\_\_\_\_  
Date: 10/30/07 Envir. C.O. No.: \_\_\_\_\_  
D. E. Taylor  
Building Official \_\_\_\_\_ Zoning Official \_\_\_\_\_