

PREPARED 7/16/07, 14:02:19
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 39
DATE 7/17/07

ADDRESS . . : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER . . . : BLACKMAN PERNELLA #1
PARCEL . . . : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
 .5MILES PAST COATS RT ON HODGES CHAPEL
 RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
 ON RT. JD
LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
 SPLIT FROM MAIN PARCEL

SUBDIV: BENNETT PLACE
PHONE : (919) 427-7524
PHONE :

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 <u>7-17</u>	TI <u>DA</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321

COMMENTS AND NOTES

ADDRESS . : 16 NATURES WAY
 CONTRACTOR : BANAH HOMES INC
 OWNER . . : BLACKMAN PERNELLA #1
 PARCEL . . : 02-1528- - -0073- -01-
 APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
 .5MILES PAST COATS RT ON HODGES CHAPEL
 RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
 ON RT. JD

LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
 SPLIT FROM MAIN PARCEL

SUBDIV: BENNETT PLACE
 PHONE : (919) 427-7524
 PHONE :

STRUCTURE: 000 000 45X62 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
A814 01	7/31/07	TI	ADDRESS CONFIRMATION VRU #: 001457118
E207 01	7/31/07 <u>7-31</u>	TI <u>AP</u> <u>KS</u>	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.

COMMENTS AND NOTES -----

ADDRESS . : 16 NATURES WAY SUBDIV: BENNETT PLACE
CONTRACTOR : BANAH HOMES INC PHONE : (919) 427-7524
OWNER . . : BLACKMAN PERNELLA #1 PHONE :
PARCEL . . : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
 .5MILES PAST COATS RT ON HODGES CHAPEL
 RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
 ON RT. JD
LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 16 Natures Way Lot 1
B103 01	8/06/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120

----- COMMENTS AND NOTES -----

ADDRESS : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER : BLACKMAN PERNELLA #1
PARCEL : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
.5MILES PAST COATS RT ON HODGES CHAPEL
RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
ON RT. JD
LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 <u>8/23</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001472855

COMMENTS AND NOTES

ADDRESS . : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER . . : BLACKMAN PERNELLA #1
PARCEL . . : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
.5MILES PAST COATS RT ON HODGES CHAPEL
RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
ON RT. JD
LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
SPLIT FROM MAIN PARCEL

SUBDIV: BENNETT PLACE
PHONE : (919) 427-7524
PHONE :

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 8/23/07	KS AP	R*OPEN FLOOR VRU #: 001472855
R425 01	9/06/07 9/06/07	KS CA	FOUR TRADE ROUGH IN VRU #: 001479013
R425 02	9/07/07 <u>9-7</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN VRU #: 001481175

----- COMMENTS AND NOTES -----

ADDRESS : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER : BLACKMAN PERNELLA #1
PARCEL : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENNETT PLACE
PHONE : (919) 427-7524
PHONE :

DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
.5MILES PAST COATS RT ON HODGES CHAPEL
RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
ON RT. JD

LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 8/23/07	KS AP	R*OPEN FLOOR VRU #: 001472855
R425 01	9/06/07 9/06/07	KS CA	FOUR TRADE ROUGH IN VRU #: 001479013
R425 02	9/07/07 9/07/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001481175 1. Need tempered glass in window in tub surround. 2. Rafters not doubled under gable end wall above garage. 3. You do not have 6 foot 8 inches headroom at top of stairs. 4. Drain line not sleeved through foundation for master bath tub. OK to side and insulate
I129 01	9/12/07 <u>9-12</u>	TI <u>DA</u>	R*INSULATION INSPECTION VRU #: 001483841
R425 03	9/12/07 <u>9-12</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001484773

----- COMMENTS AND NOTES -----

ADDRESS : 16 NATURES WAY SUBDIV: BENNETT PLACE
 CONTRACTOR : BANAH HOMES INC PHONE : (919) 427-7524
 OWNER : BLACKMAN PERNELLA #1 PHONE :
 PARCEL : 02-1528- - -0073- -01-
 APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
 .5MILES PAST COATS RT ON HODGES CHAPEL
 RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
 ON RT. JD
 LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 45X62 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 8/23/07	KS AP	R*OPEN FLOOR VRU #: 001472855
R425 01	9/06/07 9/06/07	KS CA	FOUR TRADE ROUGH IN VRU #: 001479013
R425 02	9/07/07 9/07/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001481175 1. Need tempered glass in window in tub surround. 2. Rafters not doubled under gable end wall above garage. 3. You do not have 6 foot 8 inches headroom at top of stairs. 4. Drain line not sleeved through foundation for master bath tub. . OK to side and insulate
I129 01	9/12/07 9/12/07	KS DP	R*INSULATION INSPECTION VRU #: 001483841 1. Rafters not doubled under gable end over garage. 2. Still do not have headroom at top of stairs.
R425 03	9/12/07 9/12/07	KS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001484773
R425 04	9/14/07 <u>9-14</u>	TI <u>AP</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001485994 <u>KS</u>

COMMENTS AND NOTES

ADDRESS : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER : BLACKMAN PERNELLA #1
PARCEL : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENNETT PLACE
PHONE : (919) 427-7524
PHONE :

DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
.5MILES PAST COATS RT ON HODGES CHAPEL
RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
ON RT. JD

LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 8/23/07	KS AP	R*OPEN FLOOR VRU #: 001472855
R425 01	9/06/07 9/06/07	KS CA	FOUR TRADE ROUGH IN VRU #: 001479013
R425 02	9/07/07 9/07/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001481175 1. Need tempered glass in window in tub surround. 2. Rafters not doubled under gable end wall above garage. 3. You do not have 6 foot 8 inches headroom at top of stairs. 4. Drain line not sleeved through foundation for master bath tub. OK to side and insulate
I129 01	9/12/07 9/12/07	KS DP	R*INSULATION INSPECTION VRU #: 001483841 1. Rafters not doubled under gable end over garage. 2. Still do not have headroom at top of stairs.
R425 03	9/12/07 9/12/07	KS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001484773
I129 02	9/14/07	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001486935
R425 04	9/14/07 9/14/07	KS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001485994

----- COMMENTS AND NOTES -----

ADDRESS : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER : BLACKMAN PERNELLA #1
PARCEL : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
.5MILES PAST COATS RT ON HODGES CHAPEL
RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
ON RT. JD
LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
SPLIT FROM MAIN PARCEL

SUBDIV: BENNETT PLACE
PHONE : (919) 427-7524
PHONE :

*clean out
AC drains
Insulation
Back splashes*

STRUCTURE: 000 000 45X62 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 ✓ 16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 8/23/07	KS AP	R*OPEN FLOOR VRU #: 001472855
R425 01	9/06/07 9/06/07	KS CA	FOUR TRADE ROUGH IN VRU #: 001479013
R425 02	9/07/07 9/07/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001481175 1. Need tempered glass in window in tub surround. 2. Rafters not doubled under gable end wall above garage. 3. You do not have 6 foot 8 inches headroom at top of stairs. 4. Drain line not sleeved through foundation for master bath tub. OK to side and insulate
I129 01	9/12/07 9/12/07	KS DP	R*INSULATION INSPECTION VRU #: 001483841 1. Rafters not doubled under gable end over garage. 2. Still do not have headroom at top of stairs.
R425 03	9/12/07 9/12/07	KS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001484773
I129 02	9/14/07 9/14/07	KS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001486935
R425 04	9/14/07 9/14/07	KS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001485994
H824 01	9/28/07 9/28/07	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001496033
R429 01	11/01/07 <i>11-01</i>	TP <i>DP</i>	FOUR TRADE FINAL VRU #: 001512433

----- COMMENTS AND NOTES -----

ADDRESS : 16 NATURES WAY
 CONTRACTOR : BANAH HOMES INC
 OWNER : BLACKMAN PERNELLA #1
 PARCEL : 02-1528- - -0073- -01-
 APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : BENNETT PLACE #1 - 421E LEFT ON 27
 .5MILES PAST COATS RT ON HODGES CHAPEL
 RD 1MILE RT ON NEIGHBORS RD S/D 1MILE
 ON RT. JD
 LAND NOTES : LXMN 6/18/04 BENNETT PLACE SD LOT#1
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 45X62 3BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/17/07 7/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001447321 1. Please remove footing plan from original plans. I spent 20 minutes with original plans and turned down footing. I discovered separate sheet when posting the violation.
E207 01	7/31/07 7/31/07	KS AP	R*ELEC TEMP SERVICE POLE VRU #: 001457126 SAYS STICKER IS NOT ON POLE.
A814 01	7/31/07 7/31/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001457118 ✓16 Natures Way Lot 1
B103 01	8/06/07 8/06/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001460120
B105 01	8/22/07 8/22/07	TI CA	R*OPEN FLOOR VRU #: 001472034
B105 02	8/23/07 8/23/07	KS AP	R*OPEN FLOOR VRU #: 001472855
R425 01	9/06/07 9/06/07	KS CA	FOUR TRADE ROUGH IN VRU #: 001479013
R425 02	9/07/07 9/07/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001481175 1. Need tempered glass in window in tub surround. 2. Rafters not doubled under gable end wall above garage. 3. You do not have 6 foot 8 inches headroom at top of stairs. 4. Drain line not sleeved through foundation for master bath tub. . OK to side and insulate
I129 01	9/12/07 9/12/07	KS DP	R*INSULATION INSPECTION VRU #: 001483841 1. Rafters not doubled under gable end over garage. 2. Still do not have headroom at top of stairs.
R425 03	9/12/07 9/12/07	KS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001484773
I129 02	9/14/07 9/14/07	KS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001486935
R425 04	9/14/07 9/14/07	KS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001485994
H824 01	9/28/07 9/28/07	JM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001496033
R429 01	11/01/07 11/01/07	KS DP	FOUR TRADE FINAL VRU #: 001512433 ✓1. No insulation in attice. ✓2. No cleanout bought up to grade ✓3. A/C drains open on air handler. ✓4. Sink back splashes not caulked. ✓5. Fill in sink hole around septic tank.
R429 02	11/06/07	TI	FOUR TRADE FINAL VRU #: 001516293

PREPARED 11/05/07, 14:01:42
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 16
DATE 11/06/07

ADDRESS . . : 16 NATURES WAY
CONTRACTOR : BANAH HOMES INC
OWNER . . . : BLACKMAN PERNELLA #1
PARCEL . . : 02-1528- - -0073- -01-
APPL NUMBER: 07-50017753 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENNETT PLACE
PHONE : (919) 427-7524
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Banah Homes Electrical Permit No.: _____
Building Address: 16 Natures Way Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: 1-50175
Date: 11-8-07 Envir. C.O. No.: 0

Ken Slath
Building Official

Zoning Official