

HTE# 07-50017763R

Harrison County Department of Public Health

24161

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Home PROPERTY LOCATION: N 27
NEW REPAIR EXPANSION SUBDIVISION Larval Valley LOT # 29

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD- 56 x 45 3 BR

Proposed Wastewater System Type: Pumpt. - Quick 4 Equalizer 36

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years No expiration

Permit conditions: Meet on site for final layout - maintain all 1st & 2nd
STUB out Plumbing shallow, at ground level or higher where shown
MUST BE IN 8 to 12" APPROVED COVER

Authorized State Agent: [Signature] Date: 06-27-07 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Home PROPERTY LOCATION: N 27
SUBDIVISION Larval Valley LOT # 29

Facility Type: SFD- 56 x 45 - 3 BR New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** Pumpt. Quick 4 Equalizer (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) LPP - 480 LFD LPP (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1 x 400 feet Trench Spacing: 6 Feet on Center

Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches

Maximum Trench Depth of: 12 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe

Aggregate Depth: _____ inches above pipe _____ inches total

Conditions: _____

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 06-27-07 SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 06-27-2012

HTE# 07-500 17763R

Permit # 24161

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Homes PROPERTY LOCATOR: NC27
 SUBDIVISION LAUREL VALLEY LOT # 29
 Authorized State Agent: J. [Signature] Date: 6-27-07

