

HTE# 07-5-17794

Harrison County Department of Public Health

24105

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: J.R. Stephenson Homes, Inc

PROPERTY LOCATION: SR 1705 Old Fairground Rd.

SUBDIVISION: Tilghman Ridge LOT # 55

NEW  REPAIR  EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD 70'x50'

Proposed Wastewater System Type: Convent. oned

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:  Five years  No expiration

Permit conditions:

Authorized State Agent: Bryan McSwain, R.S.

Date: 7/2/2007

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: J.R. Stephenson Homes, Inc

PROPERTY LOCATION: SR 1705

SUBDIVISION: Tilghman Ridge LOT # 55

Facility Type: SFD 70'x50'  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* Convent. oned (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable ) Accepted System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x300 feet Trench Spacing: 9 Feet on Center

Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Soil Cover: 6-12 inches

Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe 2 inches above pipe

Conditions: Run ditches on contour. Stepdowns may be needed 12 inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Bryan McSwain, R.S.

Date: 7/2/2007

SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 7/2/2012

HTE# 07-5-17794

Permit # 24105

# Harnett County Department of Public Health Site Sketch

ISSUED TO: J.L. Stephenson Homes, Inc. PROPERTY LOCATOR: 521705 Old Fairground  
SUBDIVISION: Tilghman Ridge LOT # 65

Authorized State Agent: Bryan McLean R.S. Date: 7/2/2007

