

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Regency Homes PROPERTY LOCATION: 1210  
NEW  REPAIR  EXPANSION  SUBDIVISION: Persimmon Hill LOT # 9

Type of Structure: SFD-52x43-4 BR Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_  
Proposed Wastewater System Type: 2' wide chamber

Projected Daily Flow: 480 GPD  
Number of bedrooms: \_\_\_\_\_ Number of Occupants: 8 max

Basement  Yes  No  
Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well 100 feet Permit valid for:  Five years  No expiration

Permit conditions: Meet onsite for final layout maintain all set backs  
STUB out plumbing shallow at ground level or higher where shown  
Must be in 8" x 12" of approved cover

Authorized State Agent: Ju LARJ Date: 9-12-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Regency Homes PROPERTY LOCATION: 1210  
FACILITY TYPE: SFD-52x43-4 BR  New  Expansion  Repair  
SUBDIVISION: Persimmon Hill LOT # 9

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 2' wide chamber (Initial) Wastewater Flow: 480 GPD  
(See note below, if applicable )

2' wide chamber (Repair)

Installation Requirements/Conditions  
Septic Tank Size 1000 gallons  
Pump Tank Size \_\_\_\_\_ gallons

Number of trenches 1  
Exact length of each trench 540 feet  
Trench Spacing: 7 Feet on Center

Trenches shall be installed on contour at a  
Maximum Trench Depth of: 12 inches  
Soil Cover: 6 inches  
(Maximum soil cover shall not exceed

36" above the trench bottom)  
in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe  
Aggregate Depth: \_\_\_\_\_ inches above pipe

Conditions: \_\_\_\_\_ inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Ju LARJ Date: 09-12-08

Construction Authorization Expiration Date: 09-12-2013

HTE# 07-500 17801 RR

Permit # 25060

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Regency Homes


PROPERTY LOCATION: 1210

SUBDIVISION Perdemon Hill

LOT # 9

Authorized State Agent: Ju Lopez

Date: 6-9-12-08



Meet onsite for Final  
Layout  
maintain all setbacks  
Stub out Plumbing  
shallow, at ground level  
or higher where shown

Install 54" x 2'  
wide chamber at  
12"

MUST Bring in  
8" to 12" of approved  
cover