

HTE# 07-50017850

Harnett County Department of Public Health

24169

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Home; PROPERTY LOCATION: 1115; SUBDIVISION: Crestview Est.; LOT #: 193; NEW [checked]; REPAIR []; EXPANSION []; Type of Structure: SED-56x36-302; Proposed Wastewater System Type: 25% Reduction system; Projected Daily Flow: 360 GPD; Number of bedrooms: 3; Number of Occupants: 6 max; Basement: [] Yes [x] No; Pump Required: [] Yes [x] No; Type of Water Supply: [] Community [x] Public [] Well; Distance from well: 50 feet; Permit valid for: [x] Five years [] No expiration; Permit conditions: SUB at Plumbing shallow, At ground level or higher where shown maintain All set-backs meet on-site if Problems or Questions arise

Authorized State Agent: [Signature] Date: 07-03-07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Home; PROPERTY LOCATION: 1115; SUBDIVISION: Crestview Est.; LOT #: 193; Facility Type: SED-56x36-302 [x] New [] Expansion [] Repair; Basement? [] Yes [x] No; Basement Fixtures? [] Yes [x] No; Type of Wastewater System: 25% Reduction System (Initial); Wastewater Flow: 360 GPD; (See note below, if applicable [x]) 240 LF of LPE Repair (Repair)

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons; Pump Tank Size: _____ gallons; Exact length of each trench: 1x150 feet; Trench Spacing: 9 Feet on Center; Trenches shall be installed on contour at a Maximum Trench Depth of: 18.24 inches (Maximum soil cover shall not exceed 36" above the trench bottom) in all directions; Pump Requirements: _____ ft. TDH vs. _____ GPM; Aggregate Depth: _____ inches below pipe _____ inches above pipe _____ inches total; Conditions: _____

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 07-03-07 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 07-03-2012

HTE# 0750017850

Permit # 24169

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Home

PROPERTY LOCATOR: 1115


SUBDIVISION CRESTVIEW CRT.

LOT # 193

Authorized State Agent:

Jon L. [Signature]

Date: 07-03-07



STUB at Plumbing
 shallow, at ground level
 or higher where shown
 MAINTAIN ALL setBACKS
 INSTALL 1x150 1/2 25%
 Reduction system at
 18 to 24" Deep.
 Meet onsite if problems
 or question Arise.