

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Homes PROPERTY LOCATION: 1115  
 SUBDIVISION: CRESTVIEW LOT # 251

NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD-55x37 302

Proposed Wastewater System Type: Pump to 25% Reduc. Sys.

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well 50 feet Permit valid for:  Five years  No expiration

Permit conditions: Meet onsite maintain All set Backs  
STUB out Plumbing shallow at ground level or higher where shown  
Acc. P 181-24" Ditch Depth can be maintained then pump may not be need

Authorized State Agent: Ju LA Date: 07-27-07 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumber Incl Homes PROPERTY LOCATION: 1115  
 SUBDIVISION: CRESTVIEW LOT # 251

Facility Type: SFD-55x37 302  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* Pump to 25% Reduc. Sys. (Initial) Wastewater Flow: \_\_\_\_\_ GPD

(See note below, if applicable ) 290 LF 4 LPP (Repair)

**Installation Requirements/Conditions**

Septic Tank Size 1000 gallons Exact length of each trench 12180 feet Trench Spacing: 9 Feet on Center

Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches

Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe

Aggregate Depth: \_\_\_\_\_ inches above pipe \_\_\_\_\_ inches total

Conditions: \_\_\_\_\_

\*\*If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Ju LA Date: 07-27-07 SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 07-27-2012

HTE# 07-50017913R

Permit # 24251 24251

# Harnett County Department of Public Health Site Sketch


ISSUED TO: Cumberland Homes

PROPERTY LOCATOR: 1115  
SUBDIVISION: Crestview

LOT # 251

Authorized State Agent: J. L. ...

Date: 07-27-07



Meet onsite  
 Maintain all set backs  
 STUB OUT Plumbing shallow  
 At ground level or higher  
 where shown and pump  
 may not be required  
 if 18 to 24" ditch depth  
 can be maintained  
 Install 1x180 of 25%  
 Reduction system at  
 18 to 24