



July 26, 2007

Blackwell Homes, Inc.
P O Box 427
Mamers, NC 27552

**Re: Status of Improvement Permit Application #07-5-17970 Lt 23 Summer Hill
#07-5-17969 Lt 10 Summer Hill
#07-5-17968 Lt 9 Summer Hill**

To Whom It May Concern,

On July 25, 2007, an attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Property lines/corners not marked or labeled
- 2. House corners not marked or labeled
- 3. Directions not clear to property
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required
- 6. Other – See below

Due to house size, lot size, and easements on each of these lots, you must have your private consultant provide proposed septic system and repair system lay out for each lot. Also, with the gravel/rock encountered at less than 24" in the soil backhoe pits will also be needed.

Your application will be put on hold until the selected items above have been addressed.

When completed please call 910-893-7527 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Joe West, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/ss

Copy: Central Permitting