
ADDRESS . . : 622 PINEVALLEY LN
CONTRACTOR : CUMBERLAND HOMES INC
OWNER . . . : SILVERADO HOMES LLC #253
PARCEL . . . : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	TT <i>AP JH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693 <i>10 - T-pole</i>

COMMENTS AND NOTES

ADDRESS . : 622 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : SILVERADO HOMES LLC #253 PHONE : (910) 892-4345
PARCEL . . : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693
	8/17/07	AP	no t-pole
B103 01	9/06/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001480463

 DA-MP

----- COMMENTS AND NOTES -----

ADDRESS . : 622 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : SILVERADO HOMES LLC #253 PHONE : (910) 892-4345
PARCEL . . : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693
	8/17/07	AP	no t-pole
B103 01	9/06/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001480463
	9/06/07	DA	1. porch outer foundation wall misses the required 2" projection at right end
A814 01	9/11/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001480472
	9/06/07	AP	622 PINEVALLEY LN LOT 253
B103 02	10/01/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001496082
B105 02	10/01/07	TI	R*OPEN FLOOR VRU #: 001496108
		<i>AP MR</i>	THEY SAID THAT THEY WERE INSTRUCTED BY THE INSPECTOR TO CALL BOTH OF THESE IN AT THE SAME TIME.
B105 01	10/01/07	TI	R*OPEN FLOOR VRU #: 001496041
	9/28/07	CA	

----- COMMENTS AND NOTES -----

ADDRESS : 622 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS
CONTRACTOR : CUMBERLAND HOMES INC. PHONE : (910) 892-4345
OWNER : SILVERADO HOMES LLC #253 PHONE : (910) 892-4345
PARCEL : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693
	8/17/07	AP	no t-pole
B103 01	9/06/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001480463
	9/06/07	DA	1. porch outer foundation wall misses the required 2" projection at right end
A814 01	9/11/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001480472
	9/06/07	AP	622 PINEVALLEY LN LOT 253
B103 02	10/01/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001496082
	10/01/07	AP	
B105 02	10/01/07	MR	R*OPEN FLOOR VRU #: 001496108
	10/01/07	AP	THEY SAID THAT THEY WERE INSTRUCTED BY THE INSPECTOR TO CALL BOTH OF THESE IN AT THE SAME TIME.
B105 01	10/01/07	TI	R*OPEN FLOOR VRU #: 001496041
	9/28/07	CA	
R425 01	10/23/07	TI	FOUR TRADE ROUGH IN VRU #: 001508985

DA-MR

COMMENTS AND NOTES

Flashing at Front Porch
Low Water Press.

ADDRESS . . : 622 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : SILVERADO HOMES LLC #253 PHONE : (910) 892-4345
PARCEL . . : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693
	8/17/07	AP	no t-pole
B103 01	9/06/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001480463
	9/06/07	DA	1. porch outer foundation wall misses the required 2" projection at right end
A814 01	9/11/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001480472
	9/06/07	AP	622 PINEVALLEY LN LOT 253
B103 02	10/01/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001496082
	10/01/07	AP	
B105 02	10/01/07	MR	R*OPEN FLOOR VRU #: 001496108
	10/01/07	AP	THEY SAID THAT THEY WERE INSTRUCTED BY THE INSPECTOR TO CALL BOTH OF THESE IN AT THE SAME TIME.
B105 01	10/01/07	TI	R*OPEN FLOOR VRU #: 001496041
	9/28/07	CA	
R425 01	10/23/07	MR	FOUR TRADE ROUGH IN VRU #: 001508985
	10/23/07	DA	1. flashing at front porch before pour 2. low water pressure
R425 02	10/24/07	TI	FOUR TRADE ROUGH IN VRU #: 001509744

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 622 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : SILVERADO HOMES LLC #253 PHONE : (910) 892-4345
PARCEL : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693
	8/17/07	AP	no t-pole
B103 01	9/06/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001480463
	9/06/07	DA	1. porch outer foundation wall misses the required 2" projection at right end
A814 01	9/11/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001480472
	9/06/07	AP	622 PINEVALLEY LN LOT 253
B103 02	10/01/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001496082
	10/01/07	AP	
B105 02	10/01/07	MR	R*OPEN FLOOR VRU #: 001496108
	10/01/07	AP	THEY SAID THAT THEY WERE INSTRUCTED BY THE INSPECTOR TO CALL BOTH OF THESE IN AT THE SAME TIME.
B105 01	10/01/07	TI	R*OPEN FLOOR VRU #: 001496041
	9/28/07	CA	
R425 01	10/23/07	MR	FOUR TRADE ROUGH IN VRU #: 001508985
	10/23/07	DA	1. flashing at front porch before pour 2. low water pressure
R425 02	10/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001509744
	10/24/07	AP	
I129 01	10/26/07	TI	R*INSULATION INSPECTION VRU #: 001510940
	<u>10/24/07</u>	<u>AP DT</u>	

COMMENTS AND NOTES

ADDRESS : 622 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : SILVERADO HOMES LLC #253 PHONE : (910) 892-4345
PARCEL : 03-9587-14- -0020- -10-
APPL NUMBER: 07-50017982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #253-27W LEFT ON
BUFFALO LAKES RD LEFT INTO S/D ON
CRESTHAVEN LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 56X46 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07 8/17/07	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468693 no t-pole
B103 01	9/06/07 9/06/07	MR DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001480463 1. porch outer foundation wall misses the required 2" projection at right end
A814 01	9/11/07 9/06/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001480472 ✓622 PINEVALLEY LN LOT 253
B103 02	10/01/07 10/01/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001496082
B105 02	10/01/07 10/01/07	MR AP	R*OPEN FLOOR VRU #: 001496108 THEY SAID THAT THEY WERE INSTRUCTED BY THE INSPECTOR TO CALL BOTH OF THESE IN AT THE SAME TIME.
B105 01	10/01/07 9/28/07	TI CA	R*OPEN FLOOR VRU #: 001496041
R425 01	10/23/07 10/23/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001508985 1. flashing at front porch before pour 2. low water pressure
R425 02	10/24/07 10/24/07	MR AP	FOUR TRADE ROUGH IN VRU #: 001509744
I129 01	10/26/07 10/26/07	DT AP	R*INSULATION INSPECTION VRU #: 001510940
H824 01	11/13/07 11/13/07	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001519826
R429 01	1/04/08	TI	FOUR TRADE FINAL VRU #: 001542315

AP JH

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD
Type of Construction: ✓
Owner of Building: Silverado Homes
Building Address: 622 Pinevalley Ln
Zoning District: _____
Zoning Permit No.: _____

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
Envir. C.O. No.: _____

Date: 1-4-08
James Hall
Building Official

07-50017987
Zoning Official