

-----  
ADDRESS . : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER . . : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL . . : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD  
-----

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783

AP-MR

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER . . : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL . . : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD  
-----

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
	8/06/07	AP	
B103 01	8/21/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802

AP-MR

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER . . : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL . . : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD  
-----

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07 8/06/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
B103 01	8/21/07 8/21/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
B105 01	8/24/07	TI	R*OPEN FLOOR VRU #: 001473008
A814 01	8/24/07 8/20/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811 524 Pinevalley Ln

----- COMMENTS AND NOTES -----  
-----

ADDRESS : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
	8/06/07	AP	
B103 01	8/21/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
	8/21/07	AP	
B105 01	8/24/07	MR	R*OPEN FLOOR VRU #: 001473008
	8/24/07	AP	
A814 01	8/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811
	8/20/07	AP	524 Pinevalley Ln
R425 01	9/18/07	TI	FOUR TRADE ROUGH IN VRU #: 001487883

*DA-MR*

COMMENTS AND NOTES

ADDRESS : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
	8/06/07	AP	
B103 01	8/21/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
	8/21/07	AP	
B105 01	8/24/07	MR	R*OPEN FLOOR VRU #: 001473008
	8/24/07	AP	
A814 01	8/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811
	8/20/07	AP	524 Pinevalley Ln
R425 01	9/18/07	MR	FOUR TRADE ROUGH IN VRU #: 001487883
	9/18/07	DA	<ul style="list-style-type: none"> <li>1. no water pressure</li> <li>2. nailplate needed over washer at pvc line</li> <li>3. fireblock dining room ceiling</li> <li>4. outlet needed at small wall in kitch, and living room /stair s wall</li> <li>5. fireblock small triangular nook by mbr bath</li> <li>6. no gas pressure</li> </ul>
R425 02	9/19/07	TI	FOUR TRADE ROUGH IN VRU #: 001489020

9-19-7 AP

FS

COMMENTS AND NOTES

200 P5 /

ADDRESS : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
	8/06/07	AP	
B103 01	8/21/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
	8/21/07	AP	
B105 01	8/24/07	MR	R*OPEN FLOOR VRU #: 001473008
	8/24/07	AP	
A814 01	8/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811
	8/20/07	AP	524 Pinevalley Ln
R425 01	9/18/07	MR	FOUR TRADE ROUGH IN VRU #: 001487883
	9/18/07	DA	1. no water pressure 2. nailplate needed over washer at pvc line 3. fireblock dining room ceiling 4. outlet needed at small wall in kitch, and living room /stair s wall 5. fireblock small triangular nook by mbr bath 6. no gas pressure
R425 02	9/19/07	FS	FOUR TRADE ROUGH IN VRU #: 001489020
	9/19/07	AP	
I129 01	9/21/07	TI	R*INSULATION INSPECTION VRU #: 001490788

*DA-MR*

COMMENTS AND NOTES

-----  
ADDRESS . : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER . . : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL . . : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD  
-----

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07 8/06/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
B103 01	8/21/07 8/21/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
B105 01	8/24/07 8/24/07	MR AP	R*OPEN FLOOR VRU #: 001473008
A814 01	8/24/07 8/20/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811 524 Pinevalley Ln
R425 01	9/18/07 9/18/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001487883 1. no water pressure 2. nailplate needed over washer at pvc line 3. fireblock dining room ceiling 4. outlet needed at small wall in kitch, and living room /stair s wall 5. fireblock small triangular nook by mbr bath 6. no gas pressure
R425 02	9/19/07 9/19/07	FS AP	FOUR TRADE ROUGH IN VRU #: 001489020
I129 01	9/21/07 9/21/07	MR DA	R*INSULATION INSPECTION VRU #: 001490788
I129 02	9/24/07	TI	R*INSULATION INSPECTION VRU #: 001491992

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
OWNER : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
PARCEL : 03-9587-14- -0020- -05-  
APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
BUFFALO LAKES RD LEFT INTO S/D ON  
CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 57X42 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
	8/06/07	AP	
B103 01	8/21/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
	8/21/07	AP	
B105 01	8/24/07	MR	R*OPEN FLOOR VRU #: 001473008
	8/24/07	AP	
A814 01	8/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811
	8/20/07	AP	524 Pinevalley Ln
R425 01	9/18/07	MR	FOUR TRADE ROUGH IN VRU #: 001487883
	9/18/07	DA	1. no water pressure 2. nailplate needed over washer at pvc line 3. fireblock dining room ceiling 4. outlet needed at small wall in kitch, and living room /stair s wall 5. fireblock small triangular nook by mbr bath 6. no gas pressure
R425 02	9/19/07	FS	FOUR TRADE ROUGH IN VRU #: 001489020
	9/19/07	AP	
I129 01	9/21/07	MR	R*INSULATION INSPECTION VRU #: 001490788
	9/21/07	DA	
I129 02	9/24/07	MR	R*INSULATION INSPECTION VRU #: 001491992
	9/24/07	AP	
H824 01	11/13/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001519834
	11/13/07	AP	
R429 01	11/14/07	TI	FOUR TRADE FINAL VRU #: 001520014

~~DA-MR~~  
DA-MR

COMMENTS AND NOTES

number 5  
washer box low



ADDRESS : 524 PINEVALLEY LN SUBDIV: CRESTVIEW PH 5 15 LOTS  
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345  
 OWNER : CUMBERLAND HOMES INC #258 PHONE : (910) 892-4345  
 PARCEL : 03-9587-14-- -0020- -05-  
 APPL NUMBER: 07-50017995 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : CRESTVIEW ESTATES #258-27W LEFT ON  
 BUFFALO LAKES RD LEFT INTO S/D ON  
 CRESTHAVEN DR LEFT ON PINEVALLEY LN. JD

STRUCTURE: 000 000 57X42 3BR W/GARAGE  
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/06/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001459783
	8/06/07	AP	
B103 01	8/21/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001470802
	8/21/07	AP	
B105 01	8/24/07	MR	R*OPEN FLOOR VRU #: 001473008
	8/24/07	AP	
A814 01	8/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001470811
	8/20/07	AP	✓524 Pinevalley Ln
R425 01	9/18/07	MR	FOUR TRADE ROUGH IN VRU #: 001487883
	9/18/07	DA	1. no water pressure 2. nailplate needed over washer at pvc line 3. fireblock dining room ceiling 4. outlet needed at small wall in kitch, and living room /stair s wall 5. fireblock small triangular nook by mbr bath 6. no gas pressure
R425 02	9/19/07	FS	FOUR TRADE ROUGH IN VRU #: 001489020
	9/19/07	AP	
I129 01	9/21/07	MR	R*INSULATION INSPECTION VRU #: 001490788
	9/21/07	DA	
I129 02	9/24/07	MR	R*INSULATION INSPECTION VRU #: 001491992
	9/24/07	AP	
H824 01	11/13/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001519834
	11/13/07	AP	
R429 01	11/14/07	MR	FOUR TRADE FINAL VRU #: 001520014
	11/14/07	DA	house numbers washer box too low
R429 02	11/20/07	TI	FOUR TRADE FINAL VRU #: 001522978

11/20/07

AP  
 FS

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification:   J  

Conditional Use Permit No.:   N/A  

Type of Construction:   Home  

Building Permit No.:   7-5-17995  

Owner of Building:   CUMBERLAND  

Electrical Permit No.:   7-5-17995  

Building Address:   524 PINEVALE  

Insulation Permit No.:   7-5-17995  

Zoning District:   RA25P  

Plumbing Permit No.:   7-5-17995  

Zoning Permit No.:   7-5-17995  

Mech. Permit No.:   7-5-17995  

Envir. C.O. No.:   7-5-17995  

Date:   11-20-7  

  Fred Sperry    
Building Official

\_\_\_\_\_  
Zoning Official