

PREPARED 7/26/07, 14:01:00
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 47
DATE 7/27/07

ADDRESS . . : 11 FARRAH-SHEA WAY
CONTRACTOR : PULLEN, WILLIAM E.
OWNER . . . : PULLEN CUSTOM HOMES INC
PARCEL . . . : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 557-8002
PHONE : (919) 639-9500

STRUCTURE: 000 000 50X44 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 <u>7-27-07</u>	TI <u>DAKS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666

----- COMMENTS AND NOTES -----

ADDRESS : 11 FARRAH-SHEA WAY
CONTRACTOR : PULLEN, WILLIAM E.
OWNER : PULLEN CUSTOM HOMES INC
PARCEL : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 557-8002
PHONE : (919) 639-9500

DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

STRUCTURE: 000 000 50X44 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	BS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666 pier footings missing for drop girder under living room carrying point loads from above.
B101 02	7/30/07 <u>7-30</u>	TI <u>MP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001456276 Brad said it was okay to por footings except for the missing piers. We were concerned about rain.

----- COMMENTS AND NOTES -----

ADDRESS : 11 FARRAH-SHEA WAY
CONTRACTOR : PULLEN, WILLIAM E.
OWNER : PULLEN CUSTOM HOMES INC
PARCEL : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 557-8002
PHONE : (919) 639-9500

STRUCTURE: 000 000 50X44 3BDR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	BS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666 pier footings missing for drop girder under living room carrying point loads from above.
B101 02	7/30/07 7/30/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001456276 Brad said it was okay to por footings except for the missing piers. We were concerned about rain.
A814 01	8/08/07	TI	ADDRESS CONFIRMATION VRU #: 001462373
B103 01	<u>8/08/07</u> 8-8	<u>TI</u> AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462381

COMMENTS AND NOTES

ADDRESS . : 11 FARRAH-SHEA WAY SUBDIV: BRIAN KEITH MEADOW 25LOTS
CONTRACTOR : PULLEN, WILLIAM E. PHONE : (919) 557-8002
OWNER . . : PULLEN CUSTOM HOMES INC PHONE : (919) 639-9500
PARCEL . . : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

STRUCTURE: 000 000 50X44 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	BS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666 pier footings missing for drop girder under living room carrying point loads from above.
B101 02	7/30/07 7/30/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001456276 Brad said it was okay to por footings except for the missing piers. We were concerned about rain.
A814 01	8/08/07	TI	ADDRESS CONFIRMATION VRU #: 001462373
B103 01	8/08/07 8/08/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462381
B105 01	8/13/07 <u>8-13-07</u>	TI <u>APRS</u>	R*OPEN FLOOR VRU #: 001465269

----- COMMENTS AND NOTES -----

ADDRESS : 11 FARRAH-SHEA WAY SUBDIV: BRIAN KEITH MEADOW 25LOTS
CONTRACTOR : PULLEN, WILLIAM E. PHONE : (919) 557-8002
OWNER : PULLEN CUSTOM HOMES INC PHONE : (919) 639-9500
PARCEL : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

STRUCTURE: 000 000 50X44 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	BS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666 pier footings missing for drop girder under living room carrying point loads from above.
B101 02	7/30/07 7/30/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001456276 Brad said it was okay to por footings except for the missing piers. We were concerned about rain.
B103 01	8/08/07 8/08/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462381
A814 01	8/08/07 8/10/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001462373 11 Farrah-Shea Way
B105 01	8/13/07 8/13/07	BS AP	R*OPEN FLOOR VRU #: 001465269
R427 01	9/19/07 <u>9-19</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001489142

----- COMMENTS AND NOTES -----

Violation Notice
Do Not Remove

Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-4876 Fax (910) 893-2793

07-50017581

1. Nuts and washer missing on left side of garage when facing out
2. Load point missing from valley and ridge to bonus room.
3. Need test on gas line.

Ok to side and insulate.

Code Enforcement Official

Signature Ken Slattum 910-984-4766_____

ADDRESS : 11 FARRAH-SHEA WAY SUBDIV: BRIAN KEITH MEADOW 25LOTS
CONTRACTOR : PULLEN, WILLIAM E. PHONE : (919) 557-8002
OWNER : PULLEN CUSTOM HOMES INC PHONE : (919) 639-9500
PARCEL : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

STRUCTURE: 000 000 50X44 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07 7/27/07	BS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666 pier footings missing for drop girder under living room carrying point loads from above.
B101 02	7/30/07 7/30/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001456276 Brad said it was okay to por footings except for the missing piers. We were concerned about rain.
B103 01	8/08/07 8/08/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462381
A814 01	8/08/07 8/10/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001462373 11 Farrah-Shea Way
B105 01	8/13/07 8/13/07	BS AP	R*OPEN FLOOR VRU #: 001465269
R427 01	9/19/07 9/19/07	KS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001489142 1. Nuts in garage wing wall. 2. Brace valley rafter as circled on plan. 3. Brace ridge in bonus room 4. Gas pressure test at 0.
I129 01	9/21/07 9-21	TI <i>AP</i>	R*INSULATION INSPECTION VRU #: 001490853
R427 02	9/21/07 9-21	TI <i>AP</i>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001491398

COMMENTS AND NOTES

ADDRESS : 11 FARRAH-SHEA WAY
CONTRACTOR : PULLEN, WILLIAM E.
OWNER : PULLEN CUSTOM HOMES INC
PARCEL : 04-0662- - -0024- -26-
APPL NUMBER: 07-50018000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 TO HARNETT CENTRAL RD TURN LEFT GO
APPROX 1/2 MILE BKM ON RIGHT LOT 22 JB

SUBDIV: BRIAN KEITH MEADOW 25LOTS
PHONE : (919) 557-8002
PHONE : (919) 639-9500

STRUCTURE: 000 000 50X44 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001455666
	7/27/07	DA	pier footings missing for drop girder under living room carrying point loads from above.
B101 02	7/30/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001456276
	7/30/07	AP	Brad said it was okay to por footings except for the missing piers. We were concerned about rain.
B103 01	8/08/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001462381
	8/08/07	AP	
A814 01	8/08/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001462373
	8/10/07	AP	11 Farrah-Shea Way
B105 01	8/13/07	BS	R*OPEN FLOOR VRU #: 001465269
	8/13/07	AP	
R427 01	9/19/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001489142
	9/19/07	DA	1. Nuts in garage wing wall. 2. Brace valley rafter as circled on plan. 3. Brace ridge in bonus room 4. Gas pressure test at 0.
I129 01	9/21/07	KS	R*INSULATION INSPECTION VRU #: 001490853
	9/21/07	AP	
R427 02	9/21/07	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001491398
	9-21	KS AP	
H824 01	10/02/07	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001497932
	10/02/07	AP	
R431 01	12/27/07	TI	FOUR TRADE FINAL >2500 VRU #: 001539400
	12-27-07	APBS	

COMMENTS AND NOTES

83230655

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>SED</u>	Conditional Use Permit No.: _____
Type of Construction: <u>IV</u>	Building Permit No.: _____
Owner of Building: <u>Pullen Custom Homes</u>	Electrical Permit No.: _____
Building Address: <u>11 Farrah - Shia</u>	Insulation Permit No.: _____
Zoning District: _____	Plumbing Permit No.: _____
Zoning Permit No.: <u>N/A</u>	Mech. Permit No.: _____
Date: <u>12.27.07</u>	Envir. C.O. No.: <u>07-5-18000</u>
<u>Brad Suter</u> Building Official	_____ Zoning Official