

-----  
ADDRESS . . : 45 SWEET SAMANTHA CT  
CONTRACTOR : KEITH BULLOCK BUILDERS INC.  
OWNER . . . : ATKINS PLACE LLC  
PARCEL . . . : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BRENAMOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB  
-----

SUBDIV: DEXTERFIELD  
PHONE : (919) 639-7424  
PHONE :

-----  
**STRUCTURE: 000 000 60X60 3BDR**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 <u>5-8-08</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686

-----  
COMMENTS AND NOTES  
-----

*A128*

ADDRESS : 45 SWEET SAMANTHA CT  
CONTRACTOR : KEITH BULLOCK BUILDERS INC.  
OWNER : ATKINS PLACE LLC  
PARCEL : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BENDAMOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB

SUBDIV: DEXTERFIELD  
PHONE : (919) 639-7424  
PHONE :

**STRUCTURE: 000 000 60X60 3BDR**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 <u>5.15.08</u>	TI <u>AEBS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218

COMMENTS AND NOTES

*26802122*

-----  
ADDRESS : 45 SWEET SAMANTHA CT SUBDIV: DEXTERFIELD  
CONTRACTOR : KEITH BULLOCK BUILDERS INC. PHONE : (919) 639-7424  
OWNER : ATKINS PLACE LLC PHONE :  
PARCEL : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BRENAMOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB  
-----

STRUCTURE: 000 000 60X60 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 5/15/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218 need damproofing
A814 01	5/20/08 5/19/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001609227 45 SWEET SAMANTHA CT LOT 36
B105 01	5/22/08 <u>5-22-08</u>	TI <u>APBS</u>	R*OPEN FLOOR VRU #: 001613187

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 45 SWEET SAMANTHA CT SUBDIV: DEXTERFIELD  
CONTRACTOR : KEITH BULLOCK BUILDERS INC. PHONE : (919) 639-7424  
OWNER : ATKINS PLACE LLC PHONE :  
PARCEL : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BRENAMOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB  
-----

STRUCTURE: 000 000 60X60 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 5/15/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218 need damproofing
A814 01	5/20/08 5/19/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001609227 45 SWEET SAMANTHA CT LOT 36
B105 01	5/22/08 5/22/08	BS AP	R*OPEN FLOOR VRU #: 001613187
R425 01	6/26/08 <i>6-26-08</i>	TI <i>DAB</i>	FOUR TRADE ROUGH IN VRU #: 001632111

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 45 SWEET SAMANTHA CT  
CONTRACTOR : KEITH BULLOCK BUILDERS INC.  
OWNER : ATKINS PLACE LLC  
PARCEL : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BRENDA MOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB  
-----

SUBDIV: DEXTERFIELD  
PHONE : (919) 639-7424  
PHONE :

-----  
STRUCTURE: 000 000 60X60 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 5/15/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218 need damproofing
A814 01	5/20/08 5/19/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001609227 45 SWEET SAMANTHA CT LOT 36
B105 01	5/22/08 5/22/08	BS AP	R*OPEN FLOOR VRU #: 001613187
R425 01	6/26/08 6/26/08	BS DA	FOUR TRADE ROUGH IN VRU #: 001632111 Insulation on attic supply duct shall be r-8 min
R125 01	7/01/08 <u>7-1-08</u>	TI <u>APBS</u>	ONE TRADE ROUGH IN VRU #: 001635047

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 45 SWEET SAMANTHA CT SUBDIV: DEXTERFIELD  
CONTRACTOR : KEITH BULLOCK BUILDERS INC. PHONE : (919) 639-7424  
OWNER . . : ATKINS PLACE LLC PHONE :  
PARCEL . . : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BRENDAMOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB  
-----

**STRUCTURE: 000 000 60X60 3BDR**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 5/15/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218 need damproofing
A814 01	5/20/08 5/19/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001609227 45 SWEET SAMANTHA CT LOT 36
B105 01	5/22/08 5/22/08	BS AP	R*OPEN FLOOR VRU #: 001613187
R425 01	6/26/08 6/26/08	BS DA	FOUR TRADE ROUGH IN VRU #: 001632111 Insulation on attic supply duct shall be r-8 min
R125 01	7/01/08 7/01/08	BS AP	ONE TRADE ROUGH IN VRU #: 001635047
I129 01	7/08/08 <u>7.8.08</u>	TI	R*INSULATION INSPECTION VRU #: 001637456

----- COMMENTS AND NOTES -----

ADDRESS : 45 SWEET SAMANTHA CT  
CONTRACTOR : KEITH BULLOCK BUILDERS INC.  
OWNER : ATKINS PLACE LLC  
PARCEL : 08-0653- - -0030- -36-  
APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
DEXTERFIELD DR RIGHT ON BRENDAMOORE  
LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
36 JB

SUBDIV: DEXTERFIELD  
PHONE : (919) 639-7424  
PHONE :

STRUCTURE: 000 000 60X60 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 5/15/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218 need damproofing
A814 01	5/20/08 5/19/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001609227 45 SWEET SAMANTHA CT LOT 36
B105 01	5/22/08 5/22/08	BS AP	R*OPEN FLOOR VRU #: 001613187
R425 01	6/26/08 6/26/08	BS DA	FOUR TRADE ROUGH IN VRU #: 001632111 Insulation on attic supply duct shall be r-8 min
R125 01	7/01/08 7/01/08	BS AP	ONE TRADE ROUGH IN VRU #: 001635047
I129 01	7/08/08 7/08/08	BS AP	R*INSULATION INSPECTION VRU #: 001637456
H824 01	8/29/08 8/29/08	OT AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001670611
R429 01	10/01/08 <u>10-1-08</u>	TI <i>DAB</i>	FOUR TRADE FINAL VRU #: 001684868

----- COMMENTS AND NOTES -----

ADDRESS : 45 SWEET SAMANTHA CT  
 CONTRACTOR : KEITH BULLOCK BUILDERS INC.  
 OWNER : ATKINS PLACE LLC  
 PARCEL : 08-0653- - -0030- -36-  
 APPL NUMBER: 07-50018002 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 401 N LEFT ON CHAYLBEATE RD LEFT ON  
 DEXTERFIELD DR RIGHT ON BRENDA MOORE  
 LEFT ON SWEET SAMANTHA LOT ON LEFT LOT  
 36 JB

SUBDIV: DEXTERFIELD  
 PHONE : (919) 639-7424  
 PHONE :

**STRUCTURE: 000 000 60X60 3HDR**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/08/08 5/08/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001605686 t pole 50 a gfci is missing tie handle. Will check at foundation
B103 01	5/15/08 5/15/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001609218 need damproofing
A814 01	5/20/08 5/19/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001609227 ✓45 SWEET SAMANTHA CT LOT 36
B105 01	5/22/08 5/22/08	BS AP	R*OPEN FLOOR VRU #: 001613187
R425 01	6/26/08 6/26/08	BS DA	FOUR TRADE ROUGH IN VRU #: 001632111 Insulation on attic supply duct shall be r-8 min
R125 01	7/01/08 7/01/08	BS AP	ONE TRADE ROUGH IN VRU #: 001635047
I129 01	7/08/08 7/08/08	BS AP	R*INSULATION INSPECTION VRU #: 001637456
H824 01	8/29/08 8/29/08	OT AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001670611
R429 01	10/01/08 10/01/08	BS DA	FOUR TRADE FINAL VRU #: 001684868 No handrail in rec room stairway. 2. Must have 2 seperate circuits for septic pump and alarm
R131 01	10/03/08	TI	ONE TRADE FINAL VRU #: 001685929

COMMENTS AND NOTES

*4509-267-616*



**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Owner: W. M. Bullock Builders Inc

911 Address: 45 Sweet Smooth Ct

FV

State: NC Zip Code: 27526

Date: 10-3-08

Brian Sutton

Building Official

PERMIT NUMBERS

Building Permit No.: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

Insulation Permit No.: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

MFG. Home: \_\_\_\_\_

*07-5-1802*