

Site:
 Property ID:
 Lot #:
 File #:
 Code:

**SOIL SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____
 Address: _____
 Proposed Facility: *SFD* Design Flow (.1949): *300*
 Location of Site: _____
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: *07-5-18008*
 Date Evaluated: *7-17-07*
 Property Size: *7-22-23-07*
 Property Recorded: _____
 Spring Other

Profile #	1940 Landscape Position Slope %	Horizon Depth (IN)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class. & LTAR
			1941 Structural Texture	1941 Consistence Mineralogy	1942 Soil Wetness Color	1943 Soil Depth (IN)	1944 Signal Class	1945 Profile Horiz	
1	<i>L 6%</i>	<i>0-14</i>	<i>SL</i>	<i>HR GR NSNP</i>					<i>.3</i>
		<i>14-40</i>	<i>SC</i>	<i>HR 1/8" S.P.</i>	<i>38" 7.5% 4.2</i>				
2	<i>L 6%</i>	<i>0-18</i>	<i>SL</i>	<i>HR GR NSNP</i>					<i>.3</i>
		<i>18-40</i>	<i>SC-</i>	<i>HR 1/8" S.P.</i>	<i>35" 7.6% 4.2</i>				
3	<i>L 6%</i>	<i>0-18</i>	<i>SL</i>	<i>HR GR NSNP</i>					<i>.3</i>
		<i>18-38</i>	<i>SC</i>	<i>HR 1/8" S.P.</i>	<i>36" 7.5% 4.2</i>				
4	<i>L 6%</i>	<i>0-18</i>	<i>SL</i>	<i>HR GR NSNP</i>					<i>.3</i>
		<i>18-36</i>	<i>SC</i>	<i>HR 1/8" S.P.</i>	<i>36" 7.5% 4.2</i>				

Description	Initial System	Repair System
available Space (.1945)		
ystem Type(s)	<i>2590</i>	<i>2590</i>
ite LTAR	<i>.3</i>	<i>.3</i>

Other Factors (.1946): _____
 Site Classification (.1948): *BS*
 Evaluated By: *[Signature]*
 Others Present: _____


COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE	IV	CL-CLAY LOAM	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SIC-SILTY CLAY		EFI-EXTREMELY FIRM	NP-NON-PLASTIC
FP-FLOOD PLAN		C-CLAY			SP-SLIGHTLY STICKY
		SC-SANDY CLAY			P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



Weatherby


Delta Angle = 54° 41' 16"
Radius = 50.00'
Length = 47.72'
Chord = 45.93'
Chord Bearing = S 60° 54' 51" W

Hunters Pt
Map #:

SITE PLAN APPROVAL
DISTRICT #BEDROOMS
#BEDROOMS 3
USE SFR

ZONING ADMINISTRATOR
2/12/07
(23)

NEAR
NORTH
move the
fence to
school
or side



(21)