
ADDRESS . : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
OWNER . . : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
PARCEL . . : 03-9587-14- -0020- -17-
APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
CRYSTAL SPRING DR RT ONTO ROLLING STONE
CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502

_____ *AP-MR*

----- COMMENTS AND NOTES -----

ADDRESS . . : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
OWNER . . . : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
PARCEL . . . : 03-9587-14- -0020- -17-
APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
CRYSTAL SPRING DR RT ONTO ROLLING STONE
CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07 9/25/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
A814 01	10/03/07	TI	ADDRESS CONFIRMATION VRU #: 001497858
B103 01	10/03/07	TI <i>AP-MB</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841

----- COMMENTS AND NOTES -----

ADDRESS . : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
OWNER . . : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
PARCEL . . : 03-9587-14- -0020- -17-
APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
CRYSTAL SPRING DR RT ONTO ROLLING STONE
CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07 9/25/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
B103 01	10/03/07 10/03/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841
A814 01	10/03/07 10/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001497858 164 ROLLING STONE CT LOT 212
B105 01	11/05/07	TI	R*OPEN FLOOR VRU #: 001514942

_____ *AP-MR*

----- COMMENTS AND NOTES -----

ADDRESS : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
OWNER : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
PARCEL : 03-9587-14- -0020- -17-
APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
CRYSTAL SPRING DR RT ONTO ROLLING STONE
CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07 9/25/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
B103 01	10/03/07 10/03/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841
A814 01	10/03/07 10/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001497858 164 ROLLING STONE CT LOT 212
B105 01	11/05/07 11/05/07	MR AP	R*OPEN FLOOR VRU #: 001514942
R427 01	12/13/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001534403

DA-MR

COMMENTS AND NOTES

ADDRESS . . : 164 ROLLING STONE CT
 SUBDIV: CRESTVIEW EST PH 6 9LOTS
 CONTRACTOR : JASON PRICE CONST. INC
 PHONE : (910) 897-8811
 OWNER . . : JASON PRICE CONSTRUCTION #212
 PHONE : (910) 897-8811
 PARCEL . . : 03-9587-14- -0020- -17-
 APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
 BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
 ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
 CRYSTAL SPRING DR RT ONTO ROLLING STONE
 CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07 9/25/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
B103 01	10/03/07 10/03/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841
A814 01	10/03/07 10/03/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001497858 164 ROLLING STONE CT LOT 212
B105 01	11/05/07 11/05/07	MR AP	R*OPEN FLOOR VRU #: 001514942
R427 01	12/13/07 12/13/07	MR DA	FOUR TRADE ROUGH IN >2500 VRU #: 001534403 1. Fireblock outside wall at dining nook 2. outlet needed - small wall in dining room 3. three outlets needed in kitchen- one at laundry wall and one on each side of pantry 4. fireblock bevel wall on stair landing 5. no water in drain pipe 6. studs missing by upstairs bath 7. OK to insulate and side
I129 01	12/17/07	TI DA-MR	R*INSULATION INSPECTION VRU #: 001535996
R427 02	12/17/07	TI DP-MR	FOUR TRADE ROUGH IN >2500 VRU #: 001535988

b-1 panel

----- COMMENTS AND NOTES -----

ADDRESS : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
 PARCEL : 03-9587-14- -0020- -17-
 APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
 BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
 ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
 CRYSTAL SPRING DR RT ONTO ROLLING STONE
 CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
	9/25/07	AP	
B103 01	10/03/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841
	10/03/07	AP	
A814 01	10/03/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001497858
	10/03/07	AP	164 ROLLING STONE CT LOT 212
B105 01	11/05/07	MR	R*OPEN FLOOR VRU #: 001514942
	11/05/07	AP	
R427 01	12/13/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001534403
	12/13/07	DA	1 Fireblock outside wall at dining nook 2 outlet needed - small wall in dining room 3 three outlets needed in kitchen- one at laundry wall and one on each side of pantry 4 fireblock bevel wall on stair landing 5 no water in drain pipe 6 studs missing by upstairs bath 7 OK to insulate and side
I129 01	12/17/07	MR	R*INSULATION INSPECTION VRU #: 001535996
	12/17/07	DA	rough not done
R427 02	12/17/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001535988
	12/17/07	DP	1. previously noted items- 1,3,4 of the dining room nook window 2. outlet still needed in kitchen wall by panel 3. fireblock small bevel area at stair landing to keep fire from going into the floor trusses from the vertical wall 4. all items previously noted 1.
I129 02	12/18/07	TI	R*INSULATION INSPECTION VRU #: 001536887
		<u>AP-MR</u>	
R427 03	12/18/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001536895
		<u>AP-MR</u>	

COMMENTS AND NOTES

 ADDRESS . : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER . . : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
 PARCEL . . : 03-9587-14- -0020- -17-
 APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
 BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
 ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
 CRYSTAL SPRING DR RT ONTO ROLLING STONE
 CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
	9/25/07	AP	
B103 01	10/03/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841
	10/03/07	AP	
A814 01	10/03/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001497858
	10/03/07	AP	164 ROLLING STONE CT LOT 212
B105 01	11/05/07	MR	R*OPEN FLOOR VRU #: 001514942
	11/05/07	AP	
R427 01	12/13/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001534403
	12/13/07	DA	1 Fireblock outside wall at dining nook 2 outlet needed - small wall in dining room 3 three outlets needed in kitchen- one at laundry wall and one on each side of pantry 4 fireblock bevel wall on stair landing 5 no water in drain pipe 6 studs missing by upstairs bath 7 OK to insulate and side
I129 01	12/17/07	MR	R*INSULATION INSPECTION VRU #: 001535996
	12/17/07	DA	rough not done
R427 02	12/17/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001535988
	12/17/07	DP	1. previously noted items- 1,3,4 of the dining room nook window 2. outlet still needed in kitchen wall by panel 3. fireblock small bevel area at stair landing to keep fire from going into the floor trusses from the vertical wall 4. all items previously noted 1.
I129 02	12/18/07	MR	R*INSULATION INSPECTION VRU #: 001536887
	12/18/07	AP	
R427 03	12/18/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001536895
	12/18/07	AP	
H824 01	1/25/08	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001553700
	1/25/08	AP	
R431 01	2/15/08	TI	FOUR TRADE FINAL >2500 VRU #: 001563865
	2/14/08	CA	
R431 02	2/18/08	TI	FOUR TRADE FINAL >2500 VRU #: 001564418
		DA JV	DOOR HARDWARE Ladder for attic access 6" in 10' grade away from house 2 beds

COMMENTS AND NOTES

ADDRESS : 164 ROLLING STONE CT SUBDIV: CRESTVIEW EST PH 6 9LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER : JASON PRICE CONSTRUCTION #212 PHONE : (910) 897-8811
 PARCEL : 03-9587-14- -0020- -17-
 APPL NUMBER: 07-50018087 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : CRESTVIEW ESTATES #212-27 LEFT ON
 BUFFALO TO S/D ON LEFT IMMEDIATE LEFT
 ONTO 1ST ST RT ONTO SPRING DR LEFT ONTO
 CRYSTAL SPRING DR RT ONTO ROLLING STONE
 CT LOT ON RT. JD

STRUCTURE: 000 000 57X41 3BR W/GARAGE
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001492502
	9/25/07	AP	
B103 01	10/03/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001497841
	10/03/07	AP	
A814 01	10/03/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001497858
	10/03/07	AP	✓ 164 ROLLING STONE CT LOT 212
B105 01	11/05/07	MR	R*OPEN FLOOR VRU #: 001514942
	11/05/07	AP	
R427 01	12/13/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001534403
	12/13/07	DA	1 Fireblock outside wall at dining nook 2 outlet needed - small wall in dining room 3 three outlets needed in kitchen- one at laundry wall and one on each side of pantry 4 fireblock bevel wall on stair landing 5 no water in drain pipe 6 studs missing by upstairs bath 7 OK to insulate and side
I129 01	12/17/07	MR	R*INSULATION INSPECTION VRU #: 001535996
	12/17/07	DA	rough not done
R427 02	12/17/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001535988
	12/17/07	DP	1. previously noted items- 1,3,4 of the dining room nook window 2. outlet still needed in kitchen wall by panel 3. fireblock small bevel area at stair landing to keep fire from going into the floor trusses from the vertical wall 4. all items previously noted 1.
I129 02	12/18/07	MR	R*INSULATION INSPECTION VRU #: 001536887
	12/18/07	AP	
R427 03	12/18/07	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001536895
	12/18/07	AP	
H824 01	1/25/08	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001553700
	1/25/08	AP	
R431 01	2/15/08	TI	✓ FOUR TRADE FINAL >2500 VRU #: 001563865
	2/14/08	CA	
R431 02	2/18/08	TI	FOUR TRADE FINAL >2500 VRU #: 001564418
	2/18/08	DA	ⓧ Door hardware needs to be on @ final. ⓧ Ladder for attic access. ⓧ Need 6" in 10' away from house in back under deck & @ sun room.
R431 03	2/22/08	TI	FOUR TRADE FINAL >2500 VRU #: 001566918

AP JH

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD
Type of Construction: V
Owner of Building: Jason Price
Building Address: 164 Rolling Stone Ct
Zoning District: _____
Zoning Permit No.: _____

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
Envir. C.O. No.: _____

07-5016087

James Hall Date: 2-22-08
Building Official

Zoning Official