

PREPARED 8/20/07, 14:01:35
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 43
DATE 8/21/07

ADDRESS . : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . . : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL . . : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

SCANNED

DATE

STRUCTURE: 000 000 48X71 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	8/21/07	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
	<u>8/21/07</u>	<u>AP DT</u>	

COMMENTS AND NOTES

ADDRESS . : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . . : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL . . : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

STRUCTURE: 000 000 48X71 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/07	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
	8/21/07	AP	
B103 01	8/24/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001473658

P. Z. Y. DA

----- COMMENTS AND NOTES -----

ADDRESS : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

STRUCTURE: 000 000 48X71 4BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/07	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
	8/21/07	AP	
B103 01	8/24/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001473658
	8/24/07	DA	1. foundation not cleaned down footing. excess dirt and mud will not be probed thru.
A814 01	8/27/07	TI	ADDRESS CONFIRMATION VRU #: 001474774
B103 02	8/27/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474782

----- COMMENTS AND NOTES -----

8-27 AP

ADDRESS : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

STRUCTURE: 000 000 48X71 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/07 8/21/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
B103 01	8/24/07 8/24/07	KS CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001473658 1. foundation not cleaned down footing. excess dirt and mud will not be probed thru.
A814 01	8/27/07 8/27/07	KS AP	ADDRESS CONFIRMATION VRU #: 001474774 1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B103 02	8/27/07 8/27/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474782 1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
A814 02	8/28/07 8/27/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001475649 321 Planters Ln
B105 01	9/06/07 <u>9-C</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001480847

COMMENTS AND NOTES

ADDRESS : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

STRUCTURE: 000 000 48X71 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/07	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
	8/21/07	AP	
B103 01	8/24/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001473658
	8/24/07	CA	1. foundation not cleaned down footing. excess dirt and mud will not be probed thru.
A814 01	8/27/07	KS	ADDRESS CONFIRMATION VRU #: 001474774
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B103 02	8/27/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474782
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
A814 02	8/28/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001475649
	8/27/07	AP	321 Planters Ln
B105 01	9/06/07	KS	R*OPEN FLOOR VRU #: 001480847
	9/06/07	AP	
R427 01	10/24/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001509344

1024 AP

----- COMMENTS AND NOTES -----

ADDRESS : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

STRUCTURE: 000 000 48X71 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/07 8/21/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
B103 01	8/24/07 8/24/07	KS CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001473658 1. foundation not cleaned down footing. excess dirt and mud will not be probed thru.
A814 01	8/27/07 8/27/07	KS AP	ADDRESS CONFIRMATION VRU #: 001474774 1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B103 02	8/27/07 8/27/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474782 1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
A814 02	8/28/07 8/27/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001475649 321 Planters Ln
B105 01	9/06/07 9/06/07	KS AP	R*OPEN FLOOR VRU #: 001480847
R427 01	10/24/07 10/24/07	KS AP	FOUR TRADE ROUGH IN >2500 VRU #: 001509344
I129 01	10/26/07 <u>10-26</u>	TI <u>IVR</u>	R*INSULATION INSPECTION VRU #: 001510751 VOICE MESSAGE LEFT

----- COMMENTS AND NOTES -----

ADDRESS : 321 PLANTERS LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : WHITTENTON BUILDERS INC PHONE : (919) 894-5591
PARCEL : 02-1507- - -0005- -34-
APPL NUMBER: 07-50018138 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILE S/D ON LEFT PLANTER LANE TO
LOT 11 JB

STRUCTURE: 000 000 48X71 4BDR (FUTURE POOL & GARAGE)

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/07	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001470964
	8/21/07	AP	
B103 01	8/24/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001473658
	8/24/07	CA	1. foundation not cleaned down footing. excess dirt and mud will not be probed thru.
A814 01	8/27/07	KS	ADDRESS CONFIRMATION VRU #: 001474774
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B103 02	8/27/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474782
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
A814 02	8/28/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001475649
	8/27/07	AP	321 Planters Ln
B105 01	9/06/07	KS	R*OPEN FLOOR VRU #: 001480847
	9/06/07	AP	
R427 01	10/24/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001509344
	10/24/07	AP	
I129 01	10/26/07	KS	R*INSULATION INSPECTION VRU #: 001510751
	10/26/07	AP	VOICE MESSAGE LEFT
H824 01	1/18/08	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001551548
	1/18/08	AP	
R431 01	1/29/08	TI	FOUR TRADE FINAL >2500 VRU #: 001553875

1-29-08 APBS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD Type V

Owner: Whitman Bldrs

911 Address: 321 Planters Ln

State: NC Zip Code: _____

Date: 1-29-08
Brad Sutton

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

~~MFG. Home~~ _____

075-18138