



Harnett County Government Complex  
307 Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550  
fax: 910-893-9429

August 30, 2007

Bill Clark Homes  
400 Westwood Shopping Center, Suite 220  
Fayetteville, NC 28314

**Re: Status of Improvement Permit Application #07-5-18221  
Patton's Point Lt. 103**

To Whom It May Concern,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Property lines/corners not marked or labeled
- 2. House corners not marked or labeled
- 3. Directions not clear to property
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required

**6. Other – Due to the lot being cut, lot size, and shape, drainage easement, and house size, you must reduce the home to three bedrooms maximum. Please submit changes to Central Permitting.**

Your application will be put on hold until the selected items above have been addressed. When completed please call **910-893-7527** to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Joe West, R. S.  
Environmental Health Specialist  
Harnett County Department of Public Health

JW/ss

Copy: Central Permitting