HTE# 07-530182212 Harnett County Department of Public Health 24358 Improvement Permit

A building permit cannot be issued with only an Improvement Permit ISSUED TO: B. 11 Clark Home PROPERTY LOCATION: 1137
SUBDIVISION Catters Point NEW Z Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFN- 64x45-3BR Proposed Wastewater System Type: 25% Red to System Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 Basement TYes Pump Required: ☐Yes ☐ No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well 50 feet

Permit conditions: Mcc+ on the for Final Layort, 57430 Permit valid for: ¥☐ Five years Shallow, ATGROUND LEVEL OR HIGHET where shown All Set Backs treep dranting 8" Below Fill Krapdrain Lines Kripdrain Lines 15 from Rear Property Line Authorized State Agent:: _____ Date: <u>の</u>?-*み*コ-ココ SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Bill Clark Homes PROPERTY LOCATION: 1139 SUBDIVISION PAHONO Pant LOT # 103 Facility Type: SF0-64x45-3BR D New Expansion Repair Basement? Yes No Basement Fixtures? Yes Type of Wastewater System** 25% Red-ction Cy. (Initial) Wastewater Flow: 36- GPD (See note below, if applicable (2) Installation Requirements/Conditions Exact length of each trench 1 X 153 feet Trench Spacing: 7 Feet on Center Septic Tank Size 1000 gallons Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ft. TDH vs. ____ GPM _____ inches below pipe Aggregate Depth: inches above pipe Conditions: inches total **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 09:00-07

Construction Authorization Expiration Date: 09:20:2012 Authorized State Agent:

HTE# 07-500-18221R

Harnett County Department of Public Health Site Sketch

ISSUED TO: B. 1 Clark Hones SUBDIVISION PAHAN POINT LOT # 103
Authorized State Agents Ce Date: 09-20-07
Mect on site
maintain All Set Back,
STUB out Plumbing Shallow, At Ground level
orhigher, where shown.
Install 1×150 125% Reduction System
At 18 % 24" Deep. Itecp drain Lines
8" Below Fill
Keep dran Lines 15 from Rear
Madaine II
23
6:
15
176
Made
25%
no la des
27 Martier
15 17
10 EAXEMENT 15
$\partial_{\Omega} \circ \dot{\Omega}$