

-----  
ADDRESS . : 1082 MELODY LN SUBDIV: FOREST RIDGE  
CONTRACTOR : SHOWALTER TODD PHONE : (919) 770-5934  
OWNER . . : SHOWMORE PROPERTIES LLC #2 PHONE : (919) 718-0198  
PARCEL . . : 01-9594- - -0048- -21-  
APPL NUMBER: 07-50018227 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TO HWY 87 HWY 87 S PASS  
FOOD LION TURN RIGHT ON MELODY LANE  
FOLLOW APPROX. 1-1.5 MILES HOUSE ON  
RIGHT 1082 MELODY LANE LOT 2 JB  
-----

STRUCTURE: 000 000 64X110 4BDR (HOUSE EXS NEVER FINISHED)  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	9/24/07 <i>9-24-07</i>	TI <i>AP</i>	R*ELEC TEMP SERVICE POLE VRU #: 001492040

----- COMMENTS AND NOTES -----  
*ES*

-----  
ADDRESS . . : 1082 MELODY LN  
CONTRACTOR : SHOWALTER TODD  
OWNER . . . : SHOWMORE PROPERTIES LLC #2  
PARCEL . . . : 01-9594- - -0048- -21-  
APPL NUMBER: 07-50018227 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TO HWY 87 HWY 87 S PASS  
FOOD LION TURN RIGHT ON MELODY LANE  
FOLLOW APPROX. 1-1.5 MILES HOUSE ON  
RIGHT 1082 MELODY LANE LOT 2 JB  
-----

STRUCTURE: 000 000 64X110 4BDR (HOUSE EXS NEVER FINISHED)  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	9/24/07	FS	R*ELEC TEMP SERVICE POLE VRU #: 001492040
	9/24/07	AP	
E207 02	9/26/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001493816
	<u>9/24/07</u>	<u>AP DT</u>	<del>WRONG POLE INSTALLED</del> - please inspect new pole.

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS . . : 1082 MELODY LN  
CONTRACTOR : SHOWALTER TODD  
OWNER . . . : SHOWMORE PROPERTIES LLC #2  
PARCEL . . . : 01-9594- - -0048- -21-  
APPL NUMBER: 07-50018227 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TO HWY 87 HWY 87 S PASS  
FOOD LION TURN RIGHT ON MELODY LANE  
FOLLOW APPROX. 1-1.5 MILES HOUSE ON  
RIGHT 1082 MELODY LANE LOT 2 JB  
-----

STRUCTURE: 000 000 64X110 4BDR (HOUSE EXS NEVER FINISHED)  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
R425 02	11/28/07	TI	FOUR TRADE ROUGH IN VRU #: 001525997
	<i>11/28/07</i>	<i>AP DT</i>	

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 1082 MELODY LN SUBDIV: FOREST RIDGE  
CONTRACTOR : SHOWALTER TODD PHONE : (919) 770-5934  
OWNER . . : SHOWMORE PROPERTIES LLC #2 PHONE : (919) 718-0198  
PARCEL . . : 01-9594- - -0048- -21-  
APPL NUMBER: 07-50018227 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TO HWY 87 HWY 87 S PASS  
FOOD LION TURN RIGHT ON MELODY LANE  
FOLLOW APPROX. 1-1.5 MILES HOUSE ON  
RIGHT 1082 MELODY LANE LOT 2 JB  
-----

STRUCTURE: 000 000 64X110 4BDR (HOUSE EXS NEVER FINISHED)  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 02	11/28/07 11/28/07	DT AP	FOUR TRADE ROUGH IN VRU #: 001525997 1. Washer box must be a minimum 34 inches from floor at final. 2. Need receptacle accessible from grade on rear of house.
R425 01	11/29/07 11/27/07	TI CA	FOUR TRADE ROUGH IN VRU #: 001525989
I129 01	12/18/07 <u>12/18/07</u>	TI <u>AP DT</u>	R*INSULATION INSPECTION VRU #: 001536200

----- COMMENTS AND NOTES -----

ADDRESS : 1082 MELODY LN  
CONTRACTOR : SHOWALTER TODD  
OWNER : SHOWMORE PROPERTIES LLC #2  
PARCEL : 01-9594- - -0048- -21-  
APPL NUMBER: 07-50018227 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TO HWY 87 HWY 87 S PASS  
FOOD LION TURN RIGHT ON MELODY LANE  
FOLLOW APPROX. 1-1.5 MILES HOUSE ON  
RIGHT 1082 MELODY LANE LOT 2 JB

SUBDIV: FOREST RIDGE  
PHONE : (919) 770-5934  
PHONE : (919) 718-0198

STRUCTURE: 000 000 64X110 3BDR (HOUSE EXS NEVER FINISHED)

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 02	11/28/07 11/28/07	DT AP	FOUR TRADE ROUGH IN VRU #: 001525997 1. Washer box must be a minimum 34 inches from floor at final. 2. Need receptacle accessible from grade on rear of house.
R425 01	11/29/07 11/27/07	TI CA	FOUR TRADE ROUGH IN VRU #: 001525989
I129 01	12/18/07 12/18/07	DT AP	R*INSULATION INSPECTION VRU #: 001536200
H824 01	8/22/08 8/22/08	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001667674
R429 01	3/06/09 <i>3-5-9</i>	TI <i>AP</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 001740810 INSPECTOR PLEASE CALL TODD SHOWALTER BEFORE GOING SO HE CAN HAVE THE HOUSE UNLOCKED. (919) 770-5934.***** *****

*FS*

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: V

PERMIT NUMBERS

Owner: TEAD SHOWALTER

Building Permit No.: 7-5-18227

911 Address: 1882 MESSY

Electrical Permit No.: 7-5-18227

Insulation Permit No.: 7-5-18227

Plumbing Permit No.: 7-5-18227

Mech. Permit No.: 7-5-18227

MFG. Home: \_\_\_\_\_

State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

Date: 3-2-9

Fred Sperry  
Building Official